

13585 N.E. Whitaker Way • Portland, OR 97230
Phone (503)255-5050 • Fax (503)255-0505
www.montrose-env.com

Project No. 5702

SOURCE EVALUATION REPORT


**Bullseye Glass Company
Portland, Oregon**

**Glass Furnace T7
Baghouse BH-1 (Inlet & Outlet)
Particulate Matter
Total Chromium and Hexavalent Chromium Data Collection**

Test Dates: April 26 – 29, 2016
Report Issued: June 9, 2016

Test Site:
Bullseye Glass Company
3722 SE 21st Ave
Portland, OR 97202

Report ID: HORIZON ENGINEERING 16-5702



Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

TABLE OF CONTENTS

	<u>Page #</u>
1. QUALITY STATEMENT	5
2. CERTIFICATION	6
3. INTRODUCTION	7
4. SUMMARY OF RESULTS	8
5. SOURCE DESCRIPTION AND OPERATION	13
6. SAMPLING AND ANALYTICAL PROCEDURES	15
7. DISCUSSION	17

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

APPENDIX	<u>Page #</u>
Abbreviations & Acronyms	20
Nomenclature & Drift Correction Documentation	23
PM & Flow Rate	
Results and Example Calculations	26
Field Data	31
Sample Recovery Field Data & Worksheets	55
Blank Corrections	59
Laboratory Results, Worksheets & COC	61
Traverse Point Locations	128
Cyclonic Flow Measurement	131
Production/Process Data	132
Calibration Information	
Meter Boxes	144
Calibration Critical Orifices	148
Standard Meter	150
Pitots	151
Shortridge Micromanometer	157
Magnehelic Gauge	159
Thermocouples and Indicators	160
Nozzle Diameters	173
Barometer	174
QA/QC Documentation	
Procedures	176

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

Correspondence

Source Test Plan and Correspondence 180

Quality Assurance Documentation

MAQS QSTI/QI Certification Dates 198

Qualified Individual (QI) Certificates 199

QMS Statements of Conformance 205

Personnel Qualifications

219

Total Chromium and Hexavalent Chromium Data Collection

Description of Total Chromium and Hexavalent Chromium Testing 235

Raw Analytical Test Results for Cr and Cr⁺⁶ 236


Field Data Sheets Relating to Cr and Cr⁺⁶ Testing 249

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

1. QUALITY STATEMENT

I certify that this testing was performed in accordance with Montrose Air Quality Services (MAQS) Quality Assurance Manual (QAM).

Thomas Rhodes, EIT, QSTI
District Manager

Signature  Date 5/26/16

Name, Telephone Number and E-mail address of AETB

Horizon Engineering, an affiliate of Montrose Environmental
503-255-5050
trhodes@montrose-env.com

Name and E-mail Address of the Qualification Exam Provider

Source Evaluation Society (SES)
gstiprogram@gmail.com


Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

2. CERTIFICATION

2.1 Project Manager

I hereby certify that the test detailed in this report, to the best of my knowledge, was accomplished in conformance with applicable rules and good practices. The results submitted herein are accurate and true to the best of my knowledge.


Name: Jason French, QSTI

Signature  Date 5/25/16

2.2 Senior Report Review

I hereby certify that I have reviewed this report and find it to be true and accurate, and in conformance with applicable rules and good practices, to the best of my knowledge.

Name: Andy Vella, PE, QSTI

Signature  Date 2016.05.26

2.3 Report Review

I hereby certify that I have reviewed this report and find it to be true and accurate, and in conformance with applicable rules and good practices, to the best of my knowledge.

Name: Michael E. Wallace, PE

Signature  Date 5/25/16

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

3. INTRODUCTION

3.1 Test Site: Bullseye Glass Company
3722 SE 21st Ave
Portland, OR 97202

3.2 Mailing Address: Same as above

3.3 Test Log:
Baghouse, BH-1, Inlet and Outlet: PM

Test Date	Run No.	Test Time
April 26 – 27, 2016	1	17:30 (4/26) – 09:30 (4/27)
April 27 – 28, 2016	2	17:30 (4/27) – 09:30 (4/28)
April 28 – 29, 2016	3	17:00 (4/28) – 09:00 (4/29)

Summary: Three valid runs: (All runs were valid runs) Inlet and outlet of baghouse was tested simultaneously.

3.4 Test Purpose: Performance testing for baghouse, BH-1.

3.5 Background Information: None

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

3.6 Participants:

Montrose Air Quality Services Personnel:

Jason French, QSTI, Team Leader, Calculations, and Report Review

Chris Hinson, QSTI, Field Technician

Joe Heffernan, QSTI, Field Technician

John Lewis, QSTI, Field Technician

Mihai Voivod, QSTI, Field Technician

Brett Sherwood, QI, Field Technician

Patrick Todd, Field Technician

Brandon Crawford, Field Technician

Josh Muswieck, Field Technician

Paul Berce, Field Technician

Sleight Halley, Field Technician

Thomas Rhodes, EIT, QSTI, Project Coordinator & Report Review

Michael E. Wallace, PE, Data Reduction, Calculations and QA/QC

Andy Vella, PE, QSTI, Senior Report Review

Mauri Fabio, Technical Writer

Test Arranged by: Dan Schwoerer, Bullseye Glass Company

Observers:

Plant Personnel: Dan Schwoerer, Bullseye Glass Company

Consultants: John Browning, Bridgewater Group

Agency Personnel: Michael Eisele, P.E., ODEQ, Mark Ludwiczak, ODEQ; Zach Hedgepeth, US EPA

Test Plan Sent to: Michael Eisele, P.E. & George Davis, ODEQ

4. SUMMARY OF RESULTS

4.1 Tables of Results:

Table 1					
Baghouse BH-1 Inlet PM Emissions Results					
	Units	Runs 1	Run 2	Run 3	Averages
Test Dates:		17:30 (4/26)	17:30 (4/27)	17:00 (4/28)	
		09:30 (4/27)	09:30 (4/28)	09:00 (4/29)	
Sampling Time	minutes	820	895	880	865
Sampling Results					
Filterable PM					
Filterable PM Concentration	gr/dscf	0.077	0.083	0.095	0.085
Rate	lb/hr	0.30	0.28	0.31	0.30
	lb/ton	8.58	8.12	8.84	8.51
Sample Weight, Filterable	mg	1,192	1,289	1,369	1,283
Condensable PM					
Condensable PM Concentration	gr/dscf	0.00046	0.00037	0.00058	0.00047
Rate	lb/hr	0.002	0.001	0.002	0.002
	lb/ton	0.051	0.036	0.054	0.047
Sample Weight, Condensable	mg	7.1	5.7	8.3	7.0
Total PM					
Total PM Concentration	gr/dscf	0.077	0.083	0.096	0.085
Rate	lb/hr	0.30	0.28	0.31	0.30
	lb/ton	8.63	8.16	8.89	8.56
Sample Weight, Total	mg	1,199	1,295	1,377	1,290
Sample Volume	dscf	240.6	239.8	222.6	234.3
Flow Rate					
Flow Rate (Actual)	acf/min	538	481	475	498
Flow Rate (Standard)	dscf/min	455	397	378	410
Temperature	°F	148	161	179	163
Moisture	%	2.6	3.4	4.3	3.4
Percent Isokinetic	%	97	102	101	100

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

Table 2
Baghouse BH-1 Outlet PM Emissions Results

	Units	Runs 1	Run 2	Run 3	Averages
Test Dates:		17:30 (4/26)	17:30 (4/27)	17:00 (4/28)	
		09:30 (4/27)	09:30 (4/28)	09:00 (4/29)	
Sampling Time	minutes	938	950	930	939
Sampling Results					
Filterable PM					
Filterable PM Concentration	gr/dscf	0.00004	0.00001	0.00012	0.00006
Rate	lb/hr	0.00024	0.00005	0.00061	0.00030
	lb/ton	0.0070	0.0013	0.0176	0.0086
Sample Weight, Filterable	mg	1.5	0.30	3.9	1.9
Condensable PM					
Condensable PM Concentration	gr/dscf	0.00034	0.00025	0.00015	0.00025
Rate	lb/hr	0.0019	0.0012	0.0007	0.0013
	lb/ton	0.0543	0.0349	0.0208	0.0366
Sample Weight, Condensable	mg	11.7	8.0	4.6	8.1
Total PM					
Total PM Concentration	gr/dscf	0.00038	0.00026	0.00027	0.00031
Rate	lb/hr	0.0021	0.0013	0.0013	0.0016
	lb/ton	0.0612	0.0362	0.0384	0.0453
Sample Weight, Total	mg	13.2	8.3	8.5	10.0
Sample Volume	dscf	534.4	488.2	481.8	501.5
Flow Rate					
Flow Rate (Actual)	acf/min	764	653	674	697
Flow Rate (Standard)	dscf/min	651	559	572	594
Temperature	°F	143	142	147	144
Moisture	%	2.6	3.1	3.1	2.9
Percent Isokinetic	%	96	101	100	99

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
 April 26 – 29, 2016

Table 3

Removal Efficiency

Removal Efficiency	Unit	Run 1	Run 2	Run 3	Average
Filterable PM	%	99.92	99.98	99.80	99.90
Condensable PM	%	-4.72 ¹	-0.93	62.00	18.78
Total PM	%	99.29	99.56	99.57	99.47

Table 4

Process/Production Data

Process/Production Data	Unit	Run 1	Run 2	Run 3	Average
Natural Gas Usage	ft ³ /hr	322	322	327	324
Furnace Temperature	°F	2415	2410	2443	2423
Baghouse Pressure Drop	inches, H ₂ O	5.5	5.3	5.7	5.5
Duration of Charging Period	minutes	5	5	5	5
Duration or Refining Period	hours	8	8	8	8

¹ lb/hr Condensable PM is higher at the outlet than on the inlet for Run 1, making removal efficiency calculation irrelevant. Higher exhaust flows in dscf/min compared to the inlet flow is the reason for this reading.

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
 April 26 – 29, 2016

4.2 Description of Collected Samples:

Inlet:

PM Filters: Green

Impinger Contents: Clear

Outlet:

PM Filters: White

Impinger Contents: Clear

4.3 Discussion of Method Errors and Quality Assurance Procedures:

This table is taken from a paper entitled "Significance of Errors in Stack Sampling Measurements," by R.T. Shigehara, W.F. Todd and W.S. Smith. It summarizes the maximum error expressed in percent, which may be introduced into the test procedures by equipment or instrument limitations.

Measurement	% Max Error
Stack Temperature T_s	1.4
Meter Temperature T_m	1.0
Stack Gauge Pressure P_s	0.42
Meter Gauge Pressure P_m	0.42
Atmospheric Pressure P_{atm}	0.21
Dry Molecular Weight M_d	0.42
Moisture Content B_{ws} (Absolute)	1.1
Differential Pressure Head ΔP	10.0
Orifice Pressure Differential ΔH	5.0
Pitot Tube Coefficient C_p	2.4
Orifice Meter Coefficient K_m	1.5
Diameter of Probe Nozzle D_n	0.80

4.3.1 Manual Methods: QA procedures outlined in the test methods were followed, including equipment specifications and operation, calibrations, sample recovery and handling, calculations and performance tolerances.

On-site quality control procedures include pre- and post-test leak checks on the sampling system and pitot lines. If pre-test checks indicate problems, the system is fixed and rechecked before starting testing. If post-test leak checks are not acceptable, the test run is voided and the run

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

is repeated. The results of the leak checks for the test runs are on the Field Data sheets.

Thermocouples used to measure the exhaust temperature are calibrated in the field using EPA Alternate Method 11. A single-point calibration on each thermocouple system using a reference thermometer is performed. Thermocouples must agree within $\pm 2^{\circ}\text{F}$ with the reference thermometer. Also, prior to use, thermocouple systems are checked for ambient temperature before heaters are started or readings are taken. Nozzles are inspected for nicks or dents and pitots are examined before and after each use to confirm that they are still aligned. The results were within allowable tolerances. Pre- and post-test calibrations on the meter boxes are included with the report along with semi-annual calibrations of critical orifices, pitots, nozzles, and thermocouples (sample box impinger outlet and oven, meter box inlet and outlet, and thermocouple indicators), as specified by ODEQ.

4.3.2 Audit Requirement: The EPA Stationary Source Audit Sample Program was restructured and promulgated on September 30, 2010 and was made effective 30 days after that date. The Standard requires that the Facility or their representative must order audit samples if they are available, with the exception of the methods listed in 40 CFR 60, 60.8(g)(1). The TNI website is referred to for a list of available accredited audit Providers and audits (www.nelac-institute.org/ssas/). If samples are not available from at least two accredited Providers they are not required. Currently, accredited Providers offer audit samples for EPA Methods 6, 7,

8, 12, 13A, 13B, 26, 26A, 29 and 101A. Based on the above, Bullseye Glass is not required to obtain audit samples for this test program.

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
April 26 – 29, 2016

5. SOURCE DESCRIPTION AND OPERATION

5.1 Process and Control Device Description and Operation:

Single natural gas fired colored art glass manufacturing tank furnace with an approximate operating capacity of 1,550 pound per batch; installed pre-2007.

Unspecified manufacturer baghouse filtration unit consisting of 14 filter bags and a design inlet gas flow rate of 1,000 acfm.

5.2 Test Ports:

5.2.1 Test Duct Characteristics:

Source: Baghouse, BH-1, Inlet

Source: Baghouse, BH-1, Outlet

Construction: Steel

Construction: Steel

Shape: Circular

Shape: Circular

Size: 12 inches inside diameter

Size: 12.5 (E), 12.25 (W) inches inside diameter

Orientation: Horizontal

Orientation: Vertical

Flow straighteners: None

Flow straighteners: None

Extension: None

Extension: None

Cyclonic Flow: None expected

Cyclonic Flow: None expected

Meets EPA Method 1 Criteria: Yes

Meets EPA Method 1 Criteria: Yes

Note: Outlet is warped, making it difficult to measure exact diameter

5.3 Operating Parameters: See Production/Process Data section of Appendix.

5.4 Process Startups/Shutdowns or Other Operational Changes During Tests: Process was continuous during testing.

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
 April 26 – 29, 2016

6. SAMPLING AND ANALYTICAL PROCEDURES

6.1 Sampling Procedures:

6.1.1 Sampling and Analytical Methods: Testing was in accordance with procedures and methods listed in the Source Test Plan dated March 24 & April 25, 2016 (see Correspondence Section in the Appendix), including the following: EPA methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, from the Electronic Code of Federal Regulations (www.ecfr.gov), January, 2014; Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, April, 2015.

Baghouse, BH-1 – Inlet & Outlet

Flow Rate:	EPA Methods 1 and 2 (S-type pitot w/ isokinetic traverses)
Fixed Gases:	EPA Method 3C (gas chromatograph with a thermal conductivity detector)
Moisture:	EPA Method 4 (incorporated w/ ODEQ Method 5)
PM:	ODEQ Method 5 (filterable and condensable PM; isokinetic impinger train technique)

6.1.2 Sampling Notes: During sample recovery it was discovered that the filter for Run 3 at the baghouse outlet had torn. This most likely happened during the post-test leak check. ODEQ Method 5 is a Total Particulate method so this should not affect the Total PM results. Results for Run 3 are comparable to Run 1 and Run 2 so it is included in the run average.

The recommended 72 hour holding time for Tedlar bags was exceeded for the EPA Method 3C samples. Due to the low permeability of the material and stability of the compounds analyzed, we do not believe this affected the results for the molecular weight determination. The CO₂ results for the samples are consistent with the theoretical values based on the measured moisture content of the exhaust for the combustion of natural gas with O₂.

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
 April 26 – 29, 2016

6.1.3 Laboratory Analysis:

Analyte	Laboratory
FPM & CPM	Antech, Corbett, OR
Fixed Gases	ALS, Simi Valley, CA

6.2 Sampling Train Diagram:

Figure 1
 ODEQ Method 5 Particulate Matter Sample Train Diagram




Figure 5-1. Particulate Sampling Train

Note: An unheated jumper was used from the outlet of the filter over to the first impinger.

Bullseye Glass Company, Portland, Oregon, Baghouse BH-1 (Inlet & Outlet)
 April 26 – 29, 2016

6.3 MAQS Test Equipment:


6.3.1 Manual Methods:

Equipment Name	Identification
Isokinetic Meter Boxes	CAE Express, Horizon No. 3 & No. 25
Probe Liners	Borosilicate Glass
Pitots and Thermocouples	2-4, 3-5, 3-6, I-30, I-40, I-41 GN-2, OS-51 (oven), JF, MV, PT, JH, BS, JM, JL, BC, CH, PLB, SH
Shortridge Micromanometer	SR #1 and SR #5
Magnehelic Gauge	97
Stainless Steel Nozzles	S-635, S-512
Barometer	Calibrated Barometer


7. DISCUSSION

The results of the testing should be valid in all respects. All quality assurance checks including leak checks, instrument checks, and calibrations, were within method-allowable tolerances. By following the EPA methods referenced for this testing, we expect a 3-run average to sufficiently describe the data as precise, accurate, representative and complete.

APPENDIX



Abbreviations & Acronyms



Abbreviations and Acronyms Used in the Report

AAC	Atmospheric Analysis & Consulting, Inc.
ACDP	Air Contaminant Discharge Permit
ADEC	Alaska Department of Environmental Conservation
ADL	Above Detection Limit
BAAQMD	Bay Area Air Quality Management District
BACT	Best Achievable Control Technology
BCAA	Benton Clean Air Agency
BDL	Below Detection Limit
BHP	Boiler Horsepower
BIF	Boiler and Industrial Furnace
BLS	Black Liquor Solids
C	Carbon
C ₃ H ₈	Propane
CAS	Columbia Analytical Laboratory
CEM	Continuous Emissions Monitor
CEMS	Continuous Emissions Monitoring System
CERMS	Continuous Emissions Rate Monitoring System
CET	Calibration Error Test
CFR	Code of Federal Regulations
CGA	Cylinder Gas Audit
CH ₂ O	Formaldehyde
CH ₄	Methane
Cl ₂	Chlorine
ClO ₂	Chlorine Dioxide
CNCG	Concentrated Non-Condensable Gas
CO	Catalytic Oxidizer
CO ₂	Carbon Dioxide
COC	Chain of Custody
CTM	Conditional Test Method
CTO	Catalytic Thermal Oxidizer
DE	Destruction Efficiency
Dioxins	Polychlorinated Dibenzo-p-dioxins (PCDD's)
DLL	Detection Level Limited
DNCG	Dilute Non-Condensable Gas
dscf	Dry Standard Cubic Feet
EIT	Engineer in Training
EPA	Environmental Protection Agency
ESP	Electrostatic Precipitator
EU	Emission Unit
FID	Flame Ionization Detector
Furans	Polychlorinated Dibenzofurans (PCDF's)
GC	Gas Chromatography
gr/dscf	Grains Per Dry Standard Cubic Feet
H ₂ S	Hydrogen Sulfide
HAP	Hazardous Air Pollutant
HCl	Hydrogen Chloride
HHV	Higher Heating Value
HRSG	Heat Recovery Steam Generator
IDEQ	Idaho Department of Environmental Quality
lb/hr	Pounds Per Hour
LHV	Lower Heating Value
LRAPA	Lane Regional Air Protection Agency
MACT	Maximum Achievable Control Technology
MDI	Methylene Diphenyl Diisocyanate
MDL	Method Detection Limit
MEK	Methyl Ethyl Ketone
MeOH	Methanol
MMBtu	Million British Thermal Units
MRL	Method Reporting Limit
MS	Mass Spectrometry
MSF	Thousand Square Feet
NCASI	National Council for Air and Steam Improvement

Abbreviations and Acronyms Used in the Report

NCG	Non-condensable Gases
NCUAQMD	North Coast Unified Air Quality Management District
NDIR	Non-dispersive Infrared
NESHAP	National Emissions Standards for Hazardous Air Pollutants
NIOSH	National Institute for Occupational Safety and Health
NIST	National Institute of Standards and Technology
NMC	Non-Methane Cutter
NMOC	Non-Methane Organic Compounds
NMVOC	Non-Methane Volatile Organic Compounds
NWCAA	Northwest Clean Air Agency
NO _x	Nitrogen Oxides
NPD	Nitrogen Phosphorus Detector
O ₂	Oxygen
ODEQ	Oregon Department of Environmental Quality
ORCAA	Olympic Region Clean Air Agency
PAHs	Polycyclic Aromatic Hydrocarbons
PCWP	Plywood and Composite Wood Products
PE	Professional Engineer
PM	Particulate Matter
ppbv	Parts Per Billion by Volume
ppmv	Parts Per Million by Volume
PS	Performance Specification
PSCAA	Puget Sound Clean Air Agency
PSEL	Plant Site Emission Limits
psi	pounds per square inch
PTE	Permanent Total Enclosure
PST	Performance Specification Test
PTM	Performance Test Method
QA/QC	Quality Assurance and Quality Control
QSTI	Qualified Source Testing Individual
RA	Relative Accuracy
RAA	Relative Accuracy Audit
RACT	Reasonably Available Control Technology
RATA	Relative Accuracy Test Audit
RCTO	Rotary Concentrator Thermal Oxidizer
RM	Reference Method
RTO	Regenerative Thermal Oxidizer
SCD	Sulfur Chemiluminescent Detector
SCR	Selective Catalytic Reduction System
SO ₂	Sulfur Dioxide
SOG	Stripper Off-Gas
SRCAA	Spokane Regional Clean Air Agency
SWCAA	Southwest Clean Air Agency
TAP	Toxic Air Pollutant
TCA	Thermal Conductivity Analyzer
TCD	Thermal Conductivity Detector
TGNEMOC	Total Gaseous Non-Ethane Non-Methane Organic Compounds
TGNMOC	Total Gaseous Non-Methane Organic Compounds
TGOC	Total Gaseous Organic Compounds
THC	Total Hydrocarbon
TIC	Tentatively Identified Compound
TO	Thermal Oxidizer
TO	Toxic Organic (as in EPA Method TO-15)
TON	ton=2000 pounds
TPH	Tons Per Hour
TRS	Total Reduced Sulfur
TTE	Temporary Total Enclosure
VE	Visible Emissions
VOC	Volatile Organic Compounds
WC	Inches Water Column
WDOE	Washington Department of Ecology

Nomenclature & Drift Correction Documentation

1870-1871

NOMENCLATURE

Constants	Value	Units	Definition	Ref
Pstd(1)	29.92126	inHg	Standard Pressure	CRC
Pstd(2)	2116.22	lbf / ft ²	Ideal Gas Constant	CRC
Tstd	527.67	°R	Standard Temperature	CRC
R	1545.33	ft lbf / lbmol °R	Ideal Gas Constant	CRC
MW-air	28.96456422	lbm / lbmole	Atmospheric (20.946 %O ₂ , 0.033% CO ₂ , Balance N ₂ +Ar)	
MW-C	12.011	lbm / lbmole	Carbon	CRC
MW-CO	28.0104	lbm / lbmole	Carbon Monoxide	CRC
MW-CO ₂	44.0098	lbm / lbmole	Carbon Dioxide	CRC
MW-H ₂ O	18.01534	lbm / lbmole	Water	CRC
MW-NO ₂	46.0055	lbm / lbmole	Nitrogen Dioxide	CRC
MW-O ₂	31.9988	lbm / lbmole	Oxygen	CRC
MW-SO ₂	64.0628	lbm / lbmole	Sulfur Dioxide	CRC
MW-N ₂ +Ar	28.15446807	lbm / lbmole (Balance with 98.82% N ₂ & 1.18% Ar)	Emission balance	
C1	385.3211297	ft ³ / lbmol	Ideal Gas Constant @ Standard Conditions	
C2	816.5455228	inHg in ² / °R ft ²	Isokenitics units correction constant	
Kp	5129.4	ft / min [(inHg lbm/mole) / (°R inH ₂ O)] ^{1/2}	Pitot tube constant	Ref 2.5.1
Symbol	Units	Definition	Calculating Equation or Source of Data	EPA
As	in ²	Area, Stack		
An	in ²	Area, Nozzle		
Bws	%	Moisture, % Stack gas	[100 Vw(std) / [Vw(std)+Vm(std)]]	Eq. 5-3
C	ppmv-C	Carbon (General Reporting Basis for Organics)		
C1	ft ³ /lbmol	Gas Constant @ Standard Conditions	[R Tstd / Pstd(2)]	
C2	inHg in ² / °R ft ²		[14,400 Pstd / Tstd]	
Cd	lbm-GAS / MMBdscf	Mass of gas per unit volume	[Cgas MWgas / C1]	
cg	gr/dscf	Grain Loading, Actual	[15.432 mn / Vm(std) 1,000]	Eq. 5-6
cg @ X%CO ₂	gr/dscf	Grain Loading Corrected to X% Carbon Dioxide	[X% / CO ₂ %]	
cg @ X%O ₂	gr/dscf	Grain Loading Corrected to X% Oxygen	[(20.946-X) / (20.946-O ₂)]	
Cgas	ppmv, %	Gas Concentration, (Corrected)		
Cgas @ X%CO ₂	ppmv	Gas Concentration Correction to X% Carbon Dioxide	[X% / CO ₂ %]	
Cgas @ X%O ₂	ppmv	Gas Concentration Correction to X% Oxygen	[(20.946-X%) / (20.946-O ₂ %)]	
Cgas	ppmv		Mgas (lbm/hr) * 1,000,000/385.3211/60*Qsd*mw	
CO	ppmv	Carbon Monoxide		
Co	ft	Outer Circumference of Circular Stack		
Ci	ft	Inner Circumference of Circular Stack		
CO ₂	%	Carbon Dioxide		
Cp		Pitot tube coefficient		
Ct	lb/hr	Particulate Mass Emissions	[60 cg Qsd / 7,000]	
dH	in H ₂ O	Pressure differential across orifice		
Dn	in	Diameter, Nozzle		
dp ^{1/2}	in	Average square root of velocity pressure		
Ds	in	Diameter, Stack		
E	lb / MMBtu	Pollutant Emission Rate	Cgas Fd MWgas (20.946 / (20.946-O ₂)) / (1,000,000 C1)	
Fd	dscf / MMBtu	F Factor for Various Fuels		Table 19-1
I	%	Percent Isokinetic	[C2 Ts(abs) Vm(std) / {vs Ps mfg An Ø}]	Eq. 5-8*
Md	lbm / lbmole	Molecular weight, Dry Stack Gas	[(1-%O ₂ -%CO ₂)(MWn2+ar)+(%O ₂ MW-O ₂)+(%CO ₂ MW-CO ₂)]	Eq. 3-1*
mfg		Mole fraction of dry stack gas	[1-Bws/100]	
Mgas	lbm/hr	Gaseous Mass Emissions	[60 Cgas(ppmv) MW Pstd(2) Qsd / 1,000,000 R Tstd]	
mn	mg	Particulate lab sample weight		
Ms	lbm / lbmole	Molecular weight, Wet Stack	[Md mfg +MW-H ₂ O (1-mfg)]	Eq. 2-5
MW	lbm / lbmole	Molecular Weight		
NO ₂	ppmv-NO ₂	Nitrogen Dioxide (General Reporting Basis for NOx)		
NOx	ppmv-NO ₂	Nitrogen Oxides (Reported as NO ₂)		
O ₂	%	Oxygen		
OPC	%	Opacity		
Pbar	in Hg	Pressure, Barometric		
Pg	in H ₂ O	Pressure, Static Stack		
Po	in Hg	Pressure, Absolute across Orifice	[Pbar + dH / 13.5951]	
Ps	in Hg	Pressure, Absolute Stack	[Pbar + Pg / 13.5951]	Eq. 2-6*
Qa	acf/min	Volumetric Flowrate, Actual	[As vs / 144]	
Qsd	dscf/min	Volumetric Flowrate, Dry Standard	[Qa Tstd mfg Ps] / [Pstd(1) Ts(abs)]	Eq. 2-10*
Rf	MMBtu/hr		1,000,000 Mgas (20.946-O ₂) / [Cd Fd 20.946]	
SO ₂	ppmv-SO ₂	Sulfur Dioxide		
t	in	Wall thickness of a stack or duct		
TGOC	ppmv-C	Total Gaseous Organic Concentration (Reported as C)		
Tm	°F	Temperature, Dry gas meter		
Tm(abs)	°R	Temperature, Absolute Dry Meter	[Tm + 459.67]	
Ts	°F	Temperature, Stack gas		
Ts(abs)	°R	Temperature, Absolute Stack gas	[Ts + 459.67]	
Vlc	ml	Volume of condensed water		
Vm	dcf	Volume, Gas sample		
Vm(std)	dscf	Volume, Dry standard gas sample	[Y Vm Tstd Po] / [Pstd(1) Tm(abs)]	Eq. 5-1
vs	fpm	Velocity, Stack gas	Kp Cp dp ^{1/2} [Ts(abs) / (Ps Ms)] ^{1/2}	Eq. 2-9*
Vw(std)	scf	Volume, Water Vapor	0.04707 Vlc	Eq. 5-2
Y		Dry gas meter calibration factor		Fig. 5.6
Ø	min	Time, Total sample		

* Based on equation.



13585 NE Whitaker Way • Portland, OR 97230
Phone (503) 256-5050 • Fax (503) 256-0505
www.horizonengineering.com

DRIFT CORRECTION DOCUMENTATION

EPA Drift Equations:

- Method 3A: Oxygen and Carbon Dioxide, Follow Section 12.0 of Method 7E
- Method 6C: Sulfur Dioxide, Follow Section 12.0 of Method 7E
- Method 7E: Nitrogen Oxides, Section 12.0

$$C_{gas} = \frac{C_{ma}(C - C_o)}{(C_m - C_o)} \quad (\text{Eq. 7E-5b})$$

- Method 10: Carbon Monoxide, Follow Section 12.0 of Method 7E
- Method 25A: Total Gaseous Organic Concentration (TGOC), this method does not mention correcting for drift although there are established limits.

Horizon Engineering Drift Correction Equations:

$$C_{gas} = \frac{(C_{id} - Z_x)(C_{ma} - C_{oa})}{(S_x - Z_x)} \quad S_x = \frac{(C_{mf} - C_{mi})(T_x - T_{ci})}{(T_{cf} - T_{ci})} + C_{mi}$$

$$Z_x = \frac{(C_{of} - C_{oi})(T_x - T_{ci})}{(T_{cf} - T_{ci})} + C_{oi} \quad T_x = \frac{(T_{te} - T_{ts})}{2} + T_{ts}$$

EPA	Definition	Horizon
C_{gas}	Effluent gas concentration, dry basis	C_{gas}
C_{ma}	Actual upscale calibration gas concentration	C_{ma}
C_{oa}	Actual zero/low calibration gas concentration	C_{oa}
C_m	Average of initial and final system upscale calibration bias responses	
	Initial system upscale calibration bias response	C_{mi}
	Final system upscale calibration bias response	C_{mf}
C_o	Average of initial and final system zero/low calibration bias responses	
	Initial system zero/low calibration bias response	C_{oi}
	Final system zero/low calibration bias response	C_{of}
C	Average gas concentration indicated by gas analyzer, dry basis	C_{id}
	Starting test time	T_{ts}
	Ending test time	T_{te}
	Initial system bias calibration response time	T_{ci}
	Final system bias calibration response time	T_{cf}
	Mid-point of test time or gas sampling interval to be analyzed	T_x
	Approximate upscale response at mid-point test time	S_x
	Approximate zero/low response at mid-point test time	Z_x
	Carbon count of TGOC calibration gas. ($CH_4=1$, $C_3H_8=3...$)	K
	Carbon response factor basis on a state basis (example Propane carbon basis)	R


Notes or exceptions:

TGOC is first recorded on a wet basis, then corrected to a dry basis

The TGOC instruments used by Horizon have some historic data on instrument response to different hydrocarbons.

06/02/10

PM & Flow Rate
Results & Example Calculations
Field Data
Sample Recovery Field Data & Worksheets
Blank Corrections
Laboratory Results, Worksheets, & COC
Traverse Point Locations
Cyclonic Flow Measurement



Particulate Emissions

Client BULLSEYE
 Source GLASS FURNACE T7-INLET
 Location PORTLAND OR
 ODEQ5
 26-Apr-16 Date
 SH,JL,JF,BC,JM,CH,JH Operator
 mew Analyst/QA

Definitions	Symbol	Units	Run 1	Run 2	Run 3	Average
Date, Starting			4/26/16	4/27/16	4/28/16	
Time, Starting			17:30	17:30	17:00	
Time, Ending			9:30	9:30	9:00	
Interval		hrs	16.0	16.0	16.0	
Date, Ending			4/27/16	4/28/16	4/29/16	
Filter, Front			15-8-756	15-8-714	15-8-713	
Volume, Gas sample	Vm	dcf	248.154	244.186	229.429	240.59
Temperature, Dry gas meter	Tm	°F	84.19	80.76	87.31	84.09
Temperature, Stack gas	Ts	°F	147.95	161.49	178.79	162.74
Temperature, Stack Dry Bulb	Tdb	°F	na	na	na	
Temperature, Stack Wet Bulb	Twb	°F	na	na	na	
Pressure differential across orifice	dH	in H2O	0.285	0.236	0.230	0.25
Average square root velocity pressure	dp ^{1/2}	in H2O ^{1/2}	0.188	0.169	0.164	
Diameter, Nozzle	Dn	in	0.309	0.309	0.309	
Pitot tube coefficient	Cp		0.8472	0.8363	0.8363	
Dry gas meter calibration factor	Y		0.99916	0.99916	0.99916	
Pressure, Barometric	Pbar	in Hg	29.90	30.10	30.10	
Pressure, Static Stack	Pg	in H2O	-0.3	-0.3	-0.3	
Time, Total sample	Ø	min	820	895	880	865
Stack Area	As	in ²	113.1	113.1	113.1	
Nozzle Area	An	in ²	0.0750	0.0750	0.0750	
Volume of condensed water	Vlc	ml	135.6	178.7	211.7	175.3
Oxygen		% O2	20.62	20.60	20.74	20.65
Carbon Dioxide		% CO2	1.38	1.46	1.01	1.28
Molecular weight, Dry Stack	Md	lbm / lbmole	29.17	29.18	29.11	29.15
Pressure, Absolute Stack	Ps	in Hg	29.88	30.08	30.08	30.01
Pressure, avg across orifice	Po	in Hg	29.92	30.12	30.12	30.05
Volume, Dry standard gas sample	Vm(std)	dscf	240.56	239.78	222.59	234.31
Volume, Water Vapor	Vw(std)	scf	6.38	8.41	9.97	8.25
Moisture, % Stack (EPA 4)	Bws(1)	%	2.58	3.39	4.29	3.42
Moisture, % Stack (Psychrometry-Sat)	Bws(2)	%	24.07	33.24	49.48	35.60
Moisture, % Stack (Theoretical)	Bws(3)	%	na	na	na	
Moisture, % Stack (Psychrometry)	Bws(4)	%	na	na	na	
Moisture, % Stack (Predicted)	Bws(5)	%	na	na	na	
Mole Fraction dry Gas	mfg		97.4%	96.6%	95.7%	96.6%
Molecular weight, Wet Stack	Ms	lbm / lbmole	28.88	28.80	28.64	28.77
Velocity, Stack gas	vs	fpm	685.3	612.6	604.4	634.1
Volumetric Flowrate, Actmal	Qa	acf/min	538.2	481.1	474.7	498.0
Volumetric Flowrate, Dry Standard	Qsd	dscf/min	454.6	396.9	377.5	409.7
Percent Isokinetic	I	%	97.3	101.8	101.1	100.1
Glass production		lb	1,112	1,112	1,112	1,112
		tons/hr	0.0347	0.0347	0.0347	0.0347
Total PM						
Particulate sample weight-Total	mn	mg	1,199.2	1,294.6	1,376.9	1,290.2
Grain Loading, Actual	cg	gr / dscf	0.0769	0.0833	0.0955	0.0852
		mg / dscm	176.04	190.67	218.45	195.05
Particulate Mass Emissions	Ct	lbm / hr	0.300	0.283	0.309	0.297
		gm / hr	135.98	128.58	140.11	134.89
Production basis		lbm/ton	8.63	8.16	8.89	8.56
Filterable PM						
Particulate sample weight-Filterable	mn	mg	1,192.1	1,288.9	1,368.6	1,283.2
Grain Loading, Actual	cg	gr / dscf	0.0765	0.0830	0.0949	0.0848
		mg / dscm	175.00	189.83	217.13	193.99
Particulate Mass Emissions	Ct	lbm / hr	0.298	0.282	0.307	0.296
		gm / hr	135.18	128.01	139.26	134.15
Production basis		lbm/ton	8.58	8.12	8.84	8.51
Condensable PM						
Particulate sample weight-Condensable	mn	mg	7.10	5.70	8.30	7.03
Grain Loading, Actual	cg	gr / dscf	0.000455	0.000367	0.000575	0.000466
		mg / dscm	1.04	0.84	1.32	1.07
Particulate Mass Emissions	Ct	lbm / hr	0.0018	0.0012	0.0019	0.0016
		gm / hr	0.81	0.57	0.84	0.74
Production basis		lbm/ton	0.051	0.036	0.054	0.047

Particulate Emissions

Client BULLSEYE
 Source GLASS FURNACE T7-OUTLET
 Location PORTLAND OR
 ODEQ5
 26-Apr-16 Date
 PT,BS,JH,MV,JF Operator
 mew Analyst/OA

Definitions	Symbol	Units	Run 1	Run 2	Run 3	Average
Date, Starting			4/26/16	4/27/16	4/28/16	
Time, Starting			17:30	17:30	17:00	
Time, Ending			9:30	9:30	9:00	
Interval		hrs	16.0	16.0	16.0	
Date, Ending			4/27/16	4/28/16	4/29/16	
Filter, Front			15-8-756	15-8-757	15-8-764	
Volume, Gas sample	Vm	def	539.204	490.014	486.652	505.29
Temperature, Dry gas meter	Tm	°F	69.28	69.73	73.23	70.75
Temperature, Stack gas	Ts	°F	143.33	141.54	147.00	143.95
Temperature, Stack Dry Bulb	Tdb	°F	130	na	na	
Temperature, Stack Wet Bulb	Twb	°F	120	na	na	
Pressure differential across orifice	dH	in H2O	1.108	0.907	0.945	0.99
Average square root velocity pressure	dp ^½	in H2O ^½	0.255	0.219	0.224	
Diameter, Nozzle	Dn	in	0.3735	0.3735	0.3735	
Pitot tube coefficient	Cp		0.8378	0.8378	0.8378	
Dry gas meter calibration factor	Y		0.99150	0.99150	0.99150	
Pressure, Barometric	Pbar	in Hg	29.90	30.10	30.10	
Pressure, Static Stack	Pg	in H2O	0.1	0.1	0.1	
Time, Total sample	Ø	min	938	950	930	939
Stack Area	As	in ²	120.3	120.3	120.3	
Nozzle Area	An	in ²	0.1096	0.1096	0.1096	
Volume of condensed water	Vlc	ml	305.9	334.0	323.2	321.0
Oxygen		% O2	20.62	20.60	20.74	20.65
Carbon Dioxide		% CO2	1.38	1.46	1.01	1.28
Molecular weight, Dry Stack	Md	lbm / lbmole	29.17	29.18	29.11	29.15
Pressure, Absolute Stack	Ps	in Hg	29.91	30.11	30.11	30.04
Pressure, avg across orifice	Po	in Hg	29.98	30.17	30.17	30.11
Volume, Dry standard gas sample	Vm(std)	dscf	534.40	488.23	481.75	501.46
Volume, Water Vapor	Vw(std)	scf	14.40	15.72	15.21	15.11
Moisture, % Stack (EPA 4)	Bws(1)	%	2.62	3.12	3.06	2.93
Moisture, % Stack (Psychrometry-Sat)	Bws(2)	%	21.41	20.32	23.33	21.68
Moisture, % Stack (Theoretical)	Bws(3)	%	na	na	na	
Moisture, % Stack (Psychrometry)	Bws(4)	%	11.19	na	na	
Moisture, % Stack (Predicted)	Bws(5)	%	na	na	na	
Mole Fraction dry Gas	mfg		97.38%	96.88%	96.94%	97.07%
Molecular weight, Wet Stack	Ms	lbm / lbmole	28.87	28.83	28.77	28.83
Velocity, Stack gas	vs	fpm	915.0	782.0	806.7	834.6
Volumetric Flowrate, Actual	Qa	acfm/min	764.2	653.1	673.7	697.0
Volumetric Flowrate, Dry Standard	Qsd	dscf/min	650.9	558.8	571.6	593.8
Percent Isokinetic	I	%	96.1	100.9	99.5	98.8
Glass production		lb tons/hr	1,112 0.0347	1,112 0.0347	1,112 0.0347	1,112 0.0347
Total PM						
Particulate sample weight-Total	mn	mg	13.20	8.30	8.50	10.00
Grain Loading, Actual	eg	gr / dscf	0.00038	0.00026	0.00027	0.00031
		mg / dscm	0.872	0.600	0.623	0.699
Particulate Mass Emissions	Ct	lbm / hr gm / hr	0.00213 0.96	0.00126 0.57	0.00133 0.61	0.00157 0.71
Production basis		lbm/ton	0.0612	0.0362	0.0384	0.0453
Filterable PM						
Particulate sample weight-Filterable	mn	mg	1.50	0.30	3.90	1.90
Grain Loading, Actual	eg	gr / dscf	0.00004	0.00001	0.00012	0.00006
		mg / dscm	0.099	0.022	0.286	0.136
Particulate Mass Emissions	Ct	lbm / hr gm / hr	0.00024 0.11	0.00005 0.02	0.00061 0.28	0.00030 0.14
Production basis		lbm/ton	0.0070	0.0013	0.0176	0.0086
Condensable PM						
Particulate sample weight-Condensable	mn	mg	11.70	8.00	4.60	8.10
Grain Loading, Actual	eg	gr / dscf	0.00034	0.00025	0.00015	0.00025
		mg / dscm	0.773	0.579	0.337	0.563
Particulate Mass Emissions	Ct	lbm / hr gm / hr	0.00188 0.86	0.00121 0.55	0.00072 0.33	0.00127 0.58
Production basis		lbm/ton	0.0543	0.0349	0.0208	0.0366

INLET						
Filterable Particulate Mass Emissions	Ct	lbm / hr	0.298	0.282	0.307	0.296
Condensable Particulate Mass Emissions			0.0018	0.0012	0.0019	0.0016
Total Particulate Mass Emissions			0.300	0.283	0.309	0.297
Filterable Removal Efficiency			99.92%	99.98%	99.80%	99.90%
Condensable Removal Efficiency			-4.72%	-0.93%	62.00%	18.78%
Total Removal Efficiency			99.29%	99.56%	99.57%	99.47%

Sample Calculations – Basic Method 1-5 Flow, Isokinetics, Concentration, Rate

Client: Bullseye Glass CompanyDate 4/26-4/29/16Source Baghouse BH-1 OutletProject # 5702Run # 1**Molecular Weights (lb/lbmol):**

CO ₂ =44.0	O ₂ =32.0	N ₂ +Ar=28.0	H ₂ O=18.0	atm=29.0
-----------------------	----------------------	-------------------------	-----------------------	----------

Constants:

Pstd(1)=29.92129 in Hg	Tstd=527.67 °R	Kp=5129.4	C2=816.5455 inHg in ² /°R ft ²
------------------------	----------------	-----------	--

Pressure, Absolute Stack (Ps):

$$P_s, \text{ inHg} = P_{\text{Barometric}} + \frac{P_{\text{static}}}{13.6} = 29.90 \text{ inHg} + \frac{0.1 \text{ in H}_2\text{O}}{13.6} = 29.91 \text{ inHg}$$

Volume, Dry Standard Gas Sample (Vm[std]): $T_m = 69.28^\circ\text{F} + 459.7 = 528.98^\circ\text{R}$

$$\text{Orifice Pressure} = P_b + \frac{1.108 \Delta H}{13.6} = 29.90 \text{ inHg} + \frac{1.108 \Delta H}{13.6} = 29.98 \text{ inHg}$$

$$V_m(\text{std}) \text{ ft}^3 = \frac{Y \times \text{Meter Vol} \times T_{\text{std}} \times \text{Orifice Pressure}(P_o)}{P_{\text{std}}(1) \times T_m \text{ °R}}$$

$$= \frac{0.99150 \times 539.204 \text{ ft}^3 \times 528^\circ\text{R} \times (P_o \text{ } 29.98 \text{ inHg})}{29.92 \text{ inHg} \times 528.98^\circ\text{R}} = 534.70 \text{ dscf}$$

Moisture, % Stack Gas (bws): $V_{\text{wstd}} = 0.04706 \times \text{Cond. H}_2\text{O}, \text{ ml} = 0.04706 \times 305.9 \text{ ml} = 14.40 \text{ scf}$

$$\text{bws} = 100 \times \frac{V_{\text{wstd}}}{V_{\text{wstd}} + V_{\text{mstd}}} = \frac{14.40 \text{ scf}}{14.40 \text{ scf} + 534.70 \text{ dscf}} = 2.62 \%$$

Mole Fraction Gas (mfg): $1 - \frac{\text{bws}}{100} = 1 - \frac{2.62\%}{100} = 0.9738$ **Molecular Weight, Dry, Stack (Md):**

$$M_d \frac{\text{lb}}{\text{lbmol}} = \left[\left(1 - \frac{O_2}{100} - \frac{CO_2}{100} \right) \times \text{MolWtN}_2\text{Ar} \right] + \left[\frac{O_2}{100} \times \text{MolWtO}_2 \right] + \left[\frac{CO_2}{100} \times \text{MolWtCO}_2 \right]$$

$$= \left[\left(1 - \frac{20.62\% O_2}{100} - \frac{1.38\% CO_2}{100} \right) \times 28.0 \frac{\text{lb}}{\text{lbmol}} \right] + \left[\frac{20.62\% O_2}{100} \times 32.0 \frac{\text{lb}}{\text{lbmol}} \right] +$$

$$\left[\frac{1.38\% CO_2}{100} \times 44.0 \frac{\text{lb}}{\text{lbmol}} \right]$$

$$= 29.05 \frac{\text{lb}}{\text{lbmol}}$$

Molecular Weight, Wet, Stack (Ms):

$$M_s \frac{\text{lb}}{\text{lbmol}} = (M_d \times \text{mfg}) + (\text{MolWtH}_2\text{O} \times (1 - \text{mfg})) = \left(29.05 \frac{\text{lb}}{\text{lbmol}} \times 0.9738 \right) + (18.0 \times (1 - 0.9738))$$

$$= 28.76 \frac{\text{lb}}{\text{lbmol}}$$

Client: Bullseye Glass CompanyDate 4/26-4/29/16Stack gas (vs): $T_s = 143.33 \text{ } ^\circ\text{F} + 459.7 = 603.03 \text{ } ^\circ\text{R}$

$$= vs \frac{\text{feet}}{\text{min}} = K_p \times C_p \times dp \sqrt{\text{inH}_2\text{O}} \times \sqrt{\frac{T_s \text{ } ^\circ\text{R}}{P_s \times M_s}}$$

$$= 5129.4 \text{ ft/min} \dots \times \underline{0.8378} \times \underline{0.255} dp \sqrt{\text{inH}_2\text{O}} \times \sqrt{\frac{603.03 \text{ } ^\circ\text{R}}{29.91 \text{ inHg} \times 28.76 \frac{\text{lb}}{\text{lbmol}}}} = \underline{917.5} \frac{\text{ft}}{\text{min}}$$

Flow Rate, Actual (Qa):

$$Q_a \frac{\text{actualCubicFeet}}{\text{min}} = \frac{\text{AreaStack} \times vs}{144} = \frac{120.3 \text{ in}^2 \times 917.5 \frac{\text{ft}}{\text{min}}}{144} = \underline{766.5} \text{ acfm}$$

Flow Rate, Dry Standard (Qsd):

$$Q_{sd} \frac{\text{dryStdFt}^3}{\text{min}} = \frac{Q_a \times T_{std} \times mfg \times P_s}{P_{std}(l) \times T_s \text{ } ^\circ\text{R}} = \frac{766.5 \text{ acfm} \times 528 \text{ } ^\circ\text{R} \times 0.9738 \times 29.91 \text{ inHg}}{29.92 \text{ inHg} \times 603.03 \text{ } ^\circ\text{R}}$$

$$= \underline{653.3} \frac{\text{dscf}}{\text{min}}$$

Percent Isokinetic (I):

$$I\% = \frac{C_2 \times T_s \text{ } ^\circ\text{R} \times Vm(\text{std})}{vs \times P_s \times mfg \times A_n \times \theta}$$

$$= \frac{816.5455 \text{ inHg} \cdot \text{in}^2 / ^\circ\text{R} \cdot \text{ft}^2 \times 603.03 \text{ } ^\circ\text{R} \times 534.70 \text{ dscf}}{917.5 \text{ fpm} \times 29.91 \text{ inHg} \times 0.9738 \times 0.1096 \text{ in}^2 \times 938 \text{ min}}$$

$$= \underline{95.8} \%$$

Grain Loading, actual (cg):

$$cg \frac{\text{gr}}{\text{dscf}} = \frac{15.432 \text{ gr}}{\text{g}} \times \frac{1 \text{ g}}{1000 \text{ mg}} \times \frac{\text{mgSample}}{Vm(\text{std})} = \frac{15.432 \text{ gr}}{\text{g}} \times \frac{1 \text{ g}}{1000 \text{ mg}} \times \frac{13.20 \text{ mg}}{534.70 \text{ dscf}}$$

$$= \underline{0.00038} \frac{\text{gr}}{\text{dscf}}$$

Total
PM

Mass Emissions (Ct):

$$C_t \frac{\text{lb}}{\text{hr}} = \frac{60 \times cg \times Q_{sd}}{7000 \text{ grains / lb}} = \frac{60 \times 0.00038 \frac{\text{gr}}{\text{dscf}} \times 653.3 \text{ dscf / min}}{7000 \text{ gr / lb}} = \underline{0.00213} \frac{\text{lb}}{\text{hr}}$$

Client: Bullseye Glass Company Source Bayhouse BH-1 Outlet
 Date 4/26-4/29/16 Project # 5702 Run # 3 Total PM

PM Emissions Production Based: lb/ton glass production:

Measured PM Results, lb/hr 0.00133

Glass Production, lb/batch 1,111.81 lbs

Equation:
$$\frac{\text{lbPM}}{\text{tonGlass}} = \left(\frac{\text{lbPM}}{\text{hr}} \right) \times \left(\frac{\text{batch}}{\text{lbGlass}} \right) \times \left(\frac{16\text{hrs}}{\text{batch}} \right)$$

Calculation:

$$\left(\frac{0.00133 \text{ lbPM}}{\text{hr}} \right) \times \left(\frac{\text{batch}}{1,111.81 \text{ lbGlass}} \right) \times \left(\frac{16\text{hrs}}{\text{day}} \right) \times (2000 \text{ lbGlass} / 1 \text{ tonGlass}) = \frac{0.0383 \text{ lbPM}}{\text{tonGlass}}$$

$$\begin{aligned} \% \text{ removal efficiency} &= \frac{\text{PM}_{\text{in}} (\text{lb/hr}) - \text{PM}_{\text{out}} (\text{lb/hr})}{\text{PM}_{\text{in}} (\text{lb/hr})} \times 100 \\ \text{Total PM Outlet} & \\ \text{Run: 2} & \\ &= \frac{0.283 \text{ lb/hr} - 0.00126 \text{ lb/hr}}{0.283 \text{ lb/hr}} \times 100 \\ &= 99.55\% \end{aligned}$$

10/31

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

A11-11

Client: BOLLYE GLASS
Facility Location: Portland OR
Source: T-7
Sample Location: Inlet

Date: 4/16/16
Test Method: 5
Concurrent Testing: Yes
Run #: 1

Glass Nozzle Measurements

1 -
2 -
3 - 309

Probe: 3-5 (C/S) Cp .8472 Heat Set 250 °F
Post-Test Pitot Inspection: (N) no change, D=damaged
Pitot Lk Rate: Pre: HI 0 @ 3 Post 0 @ 3
in H2O @ in H2O: Lo 0 @ 4 0 @ 5

Operator: SM Support: ALT-011
Temperature, Ambient: 80 (Ta)
Moisture: - Tdb: - Twb: -
Press., Static (Pstat): 23 Press., Bar (Pb): 29.9
Cyclonic Flow Expected? NO If yes, avg. null angle: - degrees

Std TC (ID/RF): 84 JL
Stack TC (ID/RF): 84 3-5
Continuity Check: (D) ↓

Nozzle: 5-12 Oven: 05-51 Imp. Outlet: 6N-2
Filter: 158756 Heat Set: 250 °F
Meter Box: 25 dH@ 1.79729 Y. 99916


Meter Pretest: 0.00 cfm 16 inHg
Leak Check Post: 0.087 cfm 9 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg	METER Outlet	Pump Vacuum inHg (Pv)
							T (Ts)	F (Tp)	F (To)	F (Ti)	F (Tin-in)	F (Tin-out)	
		<u>1730</u>	<u>522 .971</u>										
1	10		<u>526 .345</u>	<u>.065</u>	<u>.0998</u>	<u>.05</u>	<u>130</u>	<u>250</u>	<u>250</u>	<u>67</u>	<u>77</u>	<u>79</u>	<u>1.5</u>
2	20		<u>530 .402</u>	<u>.067</u>	<u>.524</u>	<u>.52</u>	<u>119</u>	<u>250</u>	<u>250</u>	<u>76</u>	<u>80</u>	<u>79</u>	<u>1.5</u>
3	30		<u>534 .423</u>	<u>.066</u>	<u>.52</u>	<u>.52</u>	<u>171</u>	<u>250</u>	<u>250</u>	<u>60</u>	<u>85</u>	<u>80</u>	<u>1.5</u>
4	40		<u>537 .803</u>	<u>.053</u>	<u>.366</u>	<u>.37</u>	<u>195</u>	<u>250</u>	<u>250</u>	<u>55</u>	<u>86</u>	<u>81</u>	<u>1.5</u>
5	50		<u>540 .918</u>	<u>.045</u>	<u>.311</u>	<u>.31</u>	<u>195</u>	<u>250</u>	<u>249</u>	<u>54</u>	<u>86</u>	<u>82</u>	<u>1</u>
6	60		<u>543 .952</u>	<u>.041</u>	<u>.295</u>	<u>.2830</u>	<u>162</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>86</u>	<u>83</u>	<u>1</u>
7	1:10	<u>1840/1830</u>	<u>547 .456</u>	<u>.053</u>	<u>.399</u>	<u>.40</u>	<u>191</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>88</u>	<u>84</u>	<u>1.5</u>
8	1:20		<u>550 .976</u>	<u>.052</u>	<u>.376</u>	<u>.38</u>	<u>166</u>	<u>250</u>	<u>251</u>	<u>56</u>	<u>86</u>	<u>85</u>	<u>1.5</u>
9	1:30		<u>554 .643</u>	<u>.050</u>	<u>.397</u>	<u>.40</u>	<u>109</u>	<u>250</u>	<u>258</u>	<u>54</u>	<u>89</u>	<u>86</u>	<u>1.5</u>
10	1:40		<u>557 .754</u>	<u>.039</u>	<u>.310</u>	<u>.31</u>	<u>215</u>	<u>250</u>	<u>250</u>	<u>58</u>	<u>90</u>	<u>87</u>	<u>1.5</u>
11	1:50		<u>560 .692</u>	<u>.038</u>	<u>.266</u>	<u>.27</u>	<u>186</u>	<u>250</u>	<u>251</u>	<u>61</u>	<u>91</u>	<u>88</u>	<u>1.5</u>
12	2:00		<u>563 .682</u>	<u>.037</u>	<u>.278</u>	<u>.28</u>	<u>141</u>	<u>250</u>	<u>250</u>	<u>60</u>	<u>91</u>	<u>88</u>	<u>1.5</u>
13	2:10		<u>566 .856</u>	<u>.041</u>	<u>.309</u>	<u>.31</u>	<u>143</u>	<u>250</u>	<u>245</u>	<u>60</u>	<u>90</u>	<u>89</u>	<u>1.5</u>
14	2:20		<u>569 .749</u>	<u>.035</u>	<u>.264</u>	<u>.26</u>	<u>150</u>	<u>250</u>	<u>250</u>	<u>54</u>	<u>90</u>	<u>89</u>	<u>1.5</u>
15	2:30		<u>572 .691</u>	<u>.071</u>	<u>.268</u>	<u>.27</u>	<u>232</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>91</u>	<u>89</u>	<u>1.5</u>
16	2:40		<u>575 .566</u>	<u>.035</u>	<u>.256</u>	<u>.26</u>	<u>158</u>	<u>250</u>	<u>250</u>	<u>62</u>	<u>90</u>	<u>89</u>	<u>1.5</u>
17	2:50		<u>578 .669</u>	<u>.040</u>	<u>.293</u>	<u>.293</u>	<u>155</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>90</u>	<u>89</u>	<u>1.5</u>
18	3:00		<u>581 .571</u>	<u>.036</u>	<u>.264</u>	<u>.26</u>	<u>164</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>90</u>	<u>89</u>	<u>1.5</u>
19	3:10		<u>584 .518</u>	<u>.037</u>	<u>.276</u>	<u>.28</u>	<u>146</u>	<u>250</u>	<u>250</u>	<u>61</u>	<u>89</u>	<u>88</u>	<u>1.5</u>
20	3:20		<u>587 .589</u>	<u>.042</u>	<u>.289</u>	<u>.29</u>	<u>196</u>	<u>250</u>	<u>250</u>	<u>59</u>	<u>89</u>	<u>88</u>	<u>1.5</u>
21	3:30		<u>590 .454</u>	<u>.039</u>	<u>.259</u>	<u>.26</u>	<u>230</u>	<u>250</u>	<u>250</u>	<u>58</u>	<u>88</u>	<u>85</u>	<u>1.5</u>
22	3:40		<u>593 .499</u>	<u>.043</u>	<u>.286</u>	<u>.29</u>	<u>227</u>	<u>250</u>	<u>250</u>	<u>58</u>	<u>88</u>	<u>85</u>	<u>1.5</u>
23	3:50	<u>1130/1130</u>	<u>596 .754</u>	<u>.050</u>	<u>.333</u>	<u>.33</u>	<u>220</u>	<u>250</u>	<u>249</u>	<u>58</u>	<u>88</u>	<u>87</u>	<u>1.5</u>
24	4:00		<u>600 .642</u>	<u>.057</u>	<u>.453</u>	<u>.45</u>	<u>170</u>	<u>250</u>	<u>250</u>	<u>59</u>	<u>87</u>	<u>87</u>	<u>1.5</u>
25	4:10		<u>604 .554</u>	<u>.056</u>	<u>.460</u>	<u>.46</u>	<u>150</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>89</u>	<u>87</u>	<u>1.5</u>

Notes: Flows w/ also SR5

2327.4

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p>Glass Nozzle Measurements</p> <p>1 _____</p> <p>2 _____</p> <p>3 _____</p> <p style="text-align: right;">.309</p>	<p>Client: BULLSEYE GLASS Facility Location: PORTLAND OR Source: T-7 Sample Location: INLET</p>
<p>Date: 7/26/16</p> <p>Test Method: 5</p> <p>Concurrent Testing: Yes</p> <p>Run #: 1</p>	<p>Operator: GH Support: JL, JF</p> <p>Temperature, Ambient: 50 (Ta)</p> <p>Moisture: - Tdb - Twb -</p> <p>Press., Static (Pstat) - 0.3 Press., Bar (Pb) 29.9</p> <p>Cyclonic Flow Expected? NO If yes, avg. null angle _____ degrees</p>	<p>Probe: 3-5 (C/S) Cp, 8472 Heat Set 250 °F</p> <p>Post-Test Pitot Inspection: (N) no change, (D) damaged</p> <p>Pitot Lk Rate: Pre: Hi 0 @ 3 Post 0 @ 3 in H2O @ in H2O: Lo 0 @ 4 0 @ 8</p> <p>Nozzle: 5-12 Oven: 05-51 Imp. Outlet: G 102</p> <p>Filter: 158756 Heat Set: 250 °F</p> <p>Meter Box: 25 dH @ 1.79729 Y, 99916</p>
<p>ALT-011</p> <p>Std TC (ID/°F): 84 JL</p> <p>Stack TC (ID/°F): 84 3-5</p> <p>Continuity Check: <input checked="" type="checkbox"/> or <input type="checkbox"/></p>		<p>Meter: Prefest: 0.001 cfm 16 inHg</p> <p>Leak Check: Post: 0.007 cfm 9 inHg</p>

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading out (Vol)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dPa)	STACK	PROBE	OVEN Filter °F (To)	IMPINGER Outlet °F (Ti)	METER Inlet/Avg °F (Im-in)	METER Outlet °F (Im-out)	Pump Vacuum inHg (Fv)
							°F (Ts)	°F (Tp)	Amb:	Amb:	Amb:	Amb:	Amb:
1	2	4:20	608.420	.055	4/26 2045	.45	194	258	250	54	90	87	2
2	3	4:30	612.175	.054		.42	182	250	249	54	91	87	3
3	4	4:40	616.386	.062		.53	175	250	250	55	90	87	3
4	5	4:50	620.003	.051		.39	195	250	257	54	91	87	2.5
5	6	4:50:00	623.514	.041		.31	196	250	250	54	90	87	2.5
6	7	5:10	626.996	.044		.36	196	250	250	47	85	87	2.5
7	8	5:20	630.638	.044		.39	100	250	250	45	86	87	2.5
8	9	5:30	634.270	.043		.39	100	250	257	45	86	87	2.5
9	10	5:40	637.946	.049		.41	138	250	249	46	87	85	3
10	11	5:50	641.770	.052		.44	140	250	250	46	87	86	3
11	12	6:00	645.202	.042		.36	145	250	250	44	88	85	3
12	12	6:10	648.556	.047		.39	227	250	250	45	88	85	3
13	11	6:20	651.683	.041		.30	206	250	250	45	87	86	3
14	10	6:30	654.876	.042		.31	210	250	250	46	87	85	3
15	9	6:40	658.077	.0395		.32	163	250	250	47	87	85	3
16	8	6:50	661.506	.044		.35	167	250	251	47	88	85	3.5
17	7	7:00	665.524	.057		.49	155	250	250	46	87	86	3.5
18	6	7:10	668.695	.037		.31	144	250	250	45	88	85	3
19	5	7:20	671.595	.035		.26	209	250	250	49	87	86	3
20	4	7:30	674.753	.042		.31	210	250	250	50	87	85	3.5
21	3	7:40	677.807	.039		.29	211	250	250	51	88	85	3.5
22	2	7:50	681.055	.042		.32	200	250	250	52	87	86	3.5
23	1	8:00	684.549	.046		.37	168	250	250	50	86	65	3.5
24													
25													


Notes: For traverse points 10-12, used stack T from M02

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

Leak check from 684.549 to 684.696

HORIZON ENGINEERING 16-5702

Field Data Sheet

 MONTROSE <small>AIR QUALITY SERVICES</small>			13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505			Client: <u>Bullseye Glass</u> Facility Location: <u>Portland OR</u> Source: <u>T-7</u> Sample Location: <u>Inlet</u>							
Date: <u>4/27/16</u> Test Method: <u>5</u> Concurrent Testing: <u>Yes</u> Run #: <u>1</u>			Glass Nozzle Measurements 1 <u> / </u> 2 <u> / </u> .304 3 <u> / </u>			Probe <u>3-5</u> (S) Cp. <u>8472</u> Heat Set <u>250</u> °F Post-Test Pitot Inspection (NC=no change, D=damaged) Pitot Lk Rate Pre: HI @ <u>3</u> Post <u>0</u> @ <u>3</u> in H2O@in H2O Lo <u>0</u> @ <u>4</u> <u>0</u> @ <u>5</u>							
Operator <u>JM</u> Support <u>BL JF</u> Temperature, Ambient <u>80</u> (Ta) Moisture <u>-</u> Tdb <u>-</u> Twb <u>-</u> Press., Static (Pstat) <u>-0.5</u> Press., Bar (Pb) <u>29.9</u> Cyclonic Flow Expected? <u>N</u> If yes, avg. null angle <u><</u> degrees			ALT-011 Std TC (ID/°F) <u>84</u> <u>5L</u> Stack TC (ID/°F) <u>84</u> <u>3-5</u> Continuity Check <input checked="" type="checkbox"/> or ↓			Nozzle <u>5-12</u> Oven <u>051</u> Imp. Outlet <u>6-12</u> Filter <u>15876</u> Heat Set <u>250</u> °F Meter Box <u>25</u> dH@ <u>1.7429</u> <u>Y.99916</u> Meter Pretest: <u>000</u> cfm <u>16</u> inHg Leak Check Post: <u>007</u> cfm <u>9</u> inHg							
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPv)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK °F (Ts)	PROBE °F. (Tp)	OVEN Filter °F (To)	IMPINGER Outlet °F (Ti)	METER Inlet/Avg. °F (Tin-in)	METER Outlet °F (Tin-out)	Pump Vacuum inHg (Pv)
		<u>3:50</u>	<u>684.696</u>										
1	8:10	<u>3:49.5</u>	<u>687.26</u>	<u>.022</u>	<u>.1913</u>	<u>.14</u>	<u>108</u>	<u>259</u>	<u>245</u>	<u>59</u>	<u>80</u>	<u>80</u>	<u>1</u>
2	8:20	<u>4:11</u>	<u>689.787</u>	<u>.024</u>	<u>.2163</u>	<u>.21</u>	<u>87</u>	<u>250</u>	<u>253</u>	<u>55</u>	<u>79</u>	<u>79</u>	<u>1</u>
3	8:30		<u>692.425</u>	<u>.024</u>	<u>.2185</u>	<u>.22</u>	<u>86</u>	<u>250</u>	<u>250</u>	<u>55</u>	<u>79</u>	<u>79</u>	<u>1</u>
4	8:40		<u>694.859</u>	<u>.022</u>	<u>.199</u>	<u>.20</u>	<u>87</u>	<u>250</u>	<u>250</u>	<u>54</u>	<u>81</u>	<u>81</u>	<u>1</u>
5	8:50		<u>697.660</u>	<u>.027</u>	<u>.2447</u>	<u>.24</u>	<u>86</u>	<u>250</u>	<u>250</u>	<u>54</u>	<u>81</u>	<u>81</u>	<u>1.5</u>
6	9:00		<u>700.4513</u>	<u>.028</u>	<u>.2528</u>	<u>.25</u>	<u>88</u>	<u>250</u>	<u>250</u>	<u>53</u>	<u>81</u>	<u>81</u>	<u>2</u>
7	9:10		<u>703.260</u>	<u>.025</u>	<u>.226</u>	<u>.23</u>	<u>87</u>	<u>250</u>	<u>250</u>	<u>52</u>	<u>82</u>	<u>80</u>	<u>3</u>
8	9:20		<u>705.534</u>	<u>.0186</u>	<u>.1560</u>	<u>.16</u>	<u>130</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>82</u>	<u>80</u>	<u>3</u>
9	9:30		<u>708</u>	<u>.0216</u>	<u>.1799</u>	<u>.18</u>	<u>134</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>82</u>	<u>80</u>	<u>3</u>
10	9:40		<u>710.555</u>	<u>.024</u>	<u>.2013</u>	<u>.20</u>	<u>130</u>	<u>250</u>	<u>250</u>	<u>48</u>	<u>81</u>	<u>81</u>	<u>3</u>
11	9:50		<u>713.065</u>	<u>.025</u>	<u>.1924</u>	<u>.19</u>	<u>183</u>	<u>250</u>	<u>250</u>	<u>49</u>	<u>81</u>	<u>81</u>	<u>3</u>
12	10:00		<u>715.376</u>	<u>.0183</u>	<u>.155</u>	<u>.16</u>	<u>123</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>81</u>	<u>81</u>	<u>3</u>
13	10:10		<u>717.920</u>	<u>.020</u>	<u>.188</u>	<u>.19</u>	<u>117</u>	<u>250</u>	<u>250</u>	<u>50</u>	<u>81</u>	<u>81</u>	<u>3</u>
14	10:20		<u>720.350</u>	<u>.022</u>	<u>.178</u>	<u>.18</u>	<u>149</u>	<u>250</u>	<u>250</u>	<u>50</u>	<u>81</u>	<u>81</u>	<u>3</u>
15	10:30		<u>722.992</u>	<u>.027</u>	<u>.220</u>	<u>.22</u>	<u>146</u>	<u>250</u>	<u>250</u>	<u>49</u>	<u>80</u>	<u>80</u>	<u>3</u>
16	10:40		<u>725.547</u>	<u>.024</u>	<u>.196</u>	<u>.20</u>	<u>143</u>	<u>250</u>	<u>250</u>	<u>49</u>	<u>80</u>	<u>80</u>	<u>4</u>
17	10:50		<u>728.023</u>	<u>.023</u>	<u>.180</u>	<u>.18</u>	<u>168</u>	<u>250</u>	<u>250</u>	<u>49</u>	<u>79</u>	<u>79</u>	<u>4</u>
18	11:00		<u>730.680</u>	<u>.026</u>	<u>.210</u>	<u>.21</u>	<u>148</u>	<u>250</u>	<u>250</u>	<u>46</u>	<u>79</u>	<u>79</u>	<u>4</u>
19	11:10		<u>733.190</u>	<u>.023</u>	<u>.200</u>	<u>.20</u>	<u>106</u>	<u>250</u>	<u>250</u>	<u>47</u>	<u>79</u>	<u>79</u>	<u>4</u>
20	11:20		<u>735.676</u>	<u>.0228</u>	<u>.199</u>	<u>.20</u>	<u>102</u>	<u>250</u>	<u>250</u>	<u>47</u>	<u>79</u>	<u>79</u>	<u>4</u>
21	11:30		<u>737.911</u>	<u>.0184</u>	<u>.161</u>	<u>.16</u>	<u>103</u>	<u>250</u>	<u>260</u>	<u>49</u>	<u>80</u>	<u>80</u>	<u>4</u>
22	11:40		<u>740.575</u>	<u>.0258</u>	<u>.235</u>	<u>.24</u>	<u>81</u>	<u>250</u>	<u>250</u>	<u>50</u>	<u>79</u>	<u>79</u>	<u>4</u>
23	11:50		<u>743.130</u>	<u>.0236</u>	<u>.214</u>	<u>.21</u>	<u>84</u>	<u>250</u>	<u>250</u>	<u>51</u>	<u>79</u>	<u>79</u>	<u>4</u>
24	12:00		<u>745.747</u>	<u>.0238</u>	<u>.215</u>	<u>.22</u>	<u>86</u>	<u>250</u>	<u>250</u>	<u>54</u>	<u>80</u>	<u>80</u>	<u>4</u>
25	12:0		<u>748.321</u>	<u>.0226</u>	<u>.205</u>	<u>.21</u>	<u>86</u>	<u>250</u>	<u>250</u>	<u>54</u>	<u>82</u>	<u>80</u>	<u>4</u>

Notes:

Field Data Sheet

MONTROSE
WATER QUALITY SERVICES
 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Glass Nozzle Measurements

1 _____
 2 _____ **309**
 3 _____

Client: Bullseye Glass
 Facility Location: Portland, OR
 Source: F-7
 Sample Location: Inlet

Date: 4/27/16
 Test Method: 5
 Concurrent Testing: Yes
 Run #: 1

Probe 3-5 (g/s) Cp .8172 Heat Set 250 °F
 Post-Test Pitot Inspection (N=no change, D=damaged)

Pitot Lk Rate Pre: Hi 0 @ 3 Post 0 @ 3
 in H2O@in H2O Lo 0 @ 4 0 @ 5

Operator JM Support BL JF
 Temperature, Ambient 80 (Ta)
 Moisture Tdb _____ Twb _____
 Press., Static (Pstat) 29.3 Press., Bar (Pb) 290
 Cyclonic Flow Expected? No If yes, avg. null angle _____ degrees

ALT-011
 Std TC (ID/°F) 84 JL
 Stack TC (ID/°F) 87 3-5
 Continuity Check or

Nozzle 5-12 Oven 05-91 Imp. Outlet 6-12
 Filter 158 76 1.79 29 Heat Set 250 °F


Meter Box 25 dH@ 4446 Y .99416
 Meter Pretest: 0.007 cfm 16 inHg
 Leak Check Post: 0.007 cfm 9 inHg

Traverse Point Number	Sampling Time min (st)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg	METER Outlet	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	
1	2	12.20	750 .942	.0240	.2175	.22	89	250	250	55	82	80	4
2	3	12.30	753 .560	.0228	.2066	.21	86	250	250	56	82	81	4
3	4	12.40	756 .8406	.0271	.2456	.25	86	250	250	54	82	81	4
4	5	12.50	758 .814	.0212	.1787	.18	127	250	250	55	82	81	4
5	6	13.00	761 .074	.0191	.1580	.16	138	250	250	56	82	81	4
6	7	13.10	763 .465	.0204	.1674	.17	143	250	250	58	82	81	4
7	8	13.20	765 .866	.0224	.1797	.18	158	250	250	58	82	81	4
8	9	13.30	768 .201	.0210	.1690	.17	156	250	250	59	82	82	4
9	10	13.40	770 .772	.0245	.1997	.20	148	250	250	59	82	82	4
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													

Notes:

Field Data Sheet

1074 ³⁵


MONTROSE
 THE QUALITY SERVICES
 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Glass Nozzle Measurements

1	—	—	—	—	—
2	—	—	—	—	—
3	—	—	—	1309	—

Client: **POULS EYE GLASS**
 Facility Location: **PORTLAND OR**
 Source: **BLAST FURNACE T-7**
 Sample Location: **INLET**

Date: **4/27**
 Test Method: **5**
 Concurrent Testing: **0061**
 Run #: **L**

Probe: **2-4 @/s Cp .8363 Heat Set 250 °F**
 Post-Test Pitot Inspection: **(N) - no change, D=damaged**
 Pitot Lk Rate: **Pre: Hi 0 @ 5 Post 0 @ 4**
 in H2O @ in H2O: **Lo 0 @ 5 0 @ 5**

Operator: **SAH** Support: _____
 Temperature, Ambient: **83 (Ta)**
 Moisture: **6%** Tdb: — Twb: —
 Press., Static (Pstat): **3** Press., Bar (Pb): **30.1**
 Cyclonic Flow Expected? **√0** If yes, avg. null angle: _____ degrees

ALT-011
 Std TC (ID/°F): **5H 72**
 Stack TC (ID/°F): **24 72**
 Continuity Check: **(f) or ↓**

Nozzle: **5 12** Oven: **05-51 Imp. Outlet 1-30**
 Filter: **158714** Heat Set: **250 °F**
 Meter Box: **25 dH@ 1.74729 Y 99916**
 Meter: **Pretest: .009 cfm 15 inHg**
 Leak Check: **Post: 0.006 cfm 8 inHg**

Transverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (V _m)	Velocity Head in H ₂ O (dPs)	Orifice Pressure in H ₂ O DESIRED	Orifice Pressure H ₂ O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	Filter °F (To)	Outlet °F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)	
							Amb: —	Amb: —	Amb: —	Amb: —	Amb: —	Amb: —	
1	12	10	771.425										
1	12	10	774.335	.032	.262	.26	141	261	227	65	76	77	1
2	11	20	777.453	.038	.303	.30	146	250	257	54	79	77	1
3	10	30	780.547	.039	.287	.29	191	250	251	52	82	78	1
4	9	40	783.406	.034	.255	.26	192	250	250	51	83	78	1
5	8	50	786.176	.033	.248	.25	197	250	250	54	85	81	1
6	7	1:00	788.965	.032	.252	.25	162	250	250	52	86	82	1.5
7	6	1:10	—	.039	.323	.32	131	250	250	54	86	83	1.5
8	5	1:20	795.415	.046	.337	.34	215	251	250	51	87	84	1.5
9	4	1:30	798.427	.035	.256	.26	222	250	250	49	87	84	1.5
10	3	1:40	801.188	.033	.242	.24	225	250	249	51	86	85	1.5
11	2	1:50	804.298	.036	.286	.29	224	250	249	51	85	84	1.5
12	1	2:00	807.167	.035	.256	.26	226	250	251	49	85	84	1.5
13	1	2:10	810.614	.045	.371	.37	139	250	250	48	85	84	2
14	2	2:20	813.564	.038	.275	.28	222	250	250	47	85	83	2
15	3	2:30	816.684	.042	.304	.30	233	250	250	49	84	83	2
16	4	2:40	819.544	.036	.261	.26	235	250	250	48	83	83	2
17	5	2:50	822.289	.034	.240	.24	240	250	250	49	83	83	2
18	6	3:00	824.926	.030	.223	.22	204	250	250	51	85	83	2
19	7	3:10	827.861	.035	.272	.27	177	249	250	53	85	84	2
20	8	3:20	831.082	.039	.319	.32	143	250	250	51	86	84	2.5
21	9	3:30	834.145	.038	.295	.29	200	250	250	49	86	84	2.5
22	10	3:40	837.191	.04	.285	.28	235	250	250	49	85	84	2.5
23	11	3:50	839.559	.025	.178	.18	239	250	250	49	85	84	2.5
24	12	4:00	842.047	.028	.199	.20	232	250	250	52	84	84	2.5
25													

Notes:

B:\Shared files\Fields\Data Sheets\Method 5\Method 5_PDX-v1.pdf

Field Data Sheet

2044

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Glass Nozzle Measurements

1
2 309
3

Client: **BULLSEYE GLASS**
Facility Location: **PORTLAND OR**
Source: **MAST FURNACE T-7**
Sample Location: **INLET**

Date 4/27/1
Test Method 5
Concurrent Testing ODGI
Run # 2

Probe 2-4 (g/s) Cp 8263 Heat Set 250 °F
Post-Test Pitot Inspection (No-no change, D=damaged)
Pitot Lk Rate Pre: Hi 0@5 Post 0@4
in H2O@in H2O Lo 0@5 0@5

Operator SAH Support
Temperature, Ambient 50 (Ta)
Moisture 88 Tdb - Twb -
Press., Static (Pstat) - Press., Bar (Pb) 30.1
Cyclonic Flow Expected? NO If yes, avg. null angle degrees

ALT-011
Std TC (ID/°F) 3H 72
Stack TC (ID/°F) 24 72

Nozzle 512 Oven 05-51 Imp. Outlet 1-30
Filter 158714 Heat Set 250 °F
Meter Box 25 dH@ 1.79729 Y 99916

Meter Pretest: 004 cfm 15 inHg
Leak Check Post: 008 cfm 6 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading out (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tin-in)	°F (Tim-out)	
1	12	4:10	844.920	.034	.259	.26	189	250	250	52	84	84	2.5
2	11	4:20	847.699	.031	.246	.25	163	250	251	50	84	84	2.5
3	10	4:30	850.666	.032	.267	.27	157	250	250	51	84	84	3
4	9	4:40	853.655	.034	.284	.28	151	250	250	50	84	83	3
5	8	4:50	857.060	.040	.355	.36	120	251	250	50	84	83	3.5
6	7	4:60	860.031	.035	.279	.28	186	250	250	48	85	83	3
7	6	5:10	862.660	.029	.220	.22	219	250	250	50	84	83	3
8	5	5:20	865.471	.034	.253	.25	231	250	250	60	80	82	3
9	4	5:30	869.123	.049	.409	.41	156	250	250	51	81	82	4
10	3	5:40	872.755	.048	.401	.40	144	250	250	46	82	82	4
11	2	5:50	876.275	.044	.382	.38	133	250	249	47	82	82	4
12	1	6:00	879.746	.046	.366	.37	187	250	250	46	83	82	4
13	1	6:10	882.862	.039	.299	.30	211	250	249	47	83	81	4
14	2	6:20	885.753	.034	.261	.26	220	250	251	48	83	81	3.5
15	3	6:30	888.371	.029	.217	.22	228	250	250	48	82	81	3.5
16	4	6:40	891.275	.033	.261	.261	191	250	251	50	82	81	3.5
17	5	6:50	894.296	.034	.282	.28	159	250	250	49	82	81	3.5
18	6	7:00	897.594	.041	.34	.34	150	250	251	47	82	81	4
19	7	7:10	900.701	.037	.307	.31	153	251	250	47	82	81	4.5
20	8	7:20	903.841	.035	.304	.30	132	250	251	47	82	81	4.5
21	9	7:30	906.942	.033	.290	.29	123	250	250	47	82	81	4.5
22	10	7:40	909.728	.031	.237	.24	213	250	250	47	81	80	4.5
23	11	7:50	912.447	.031	.232	.23	225	250	250	47	81	80	4.5
24	12	8:00	914.920	.025	.187	.19	226	250	250	48	81	80	4.5
25													


Change

Notes:

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

Leak check from 914.920 to 915.065

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p>Glass Nozzle Measurements</p> <p>1 _____ 2 _____ 3 _____ .309</p>	<p>Client: <u>Ballsege Glass</u> Facility Location: <u>Portland, OR</u> Source: <u>Blast Furnace T-7</u> Sample Location: <u>Inlet</u></p>
<p>Date: <u>4/28/16</u> Test Method: <u>6</u> Concurrent Testing: <u>0061</u> Run #: <u>2</u></p>		<p>Probe <u>2-4</u> (g/s) Cp, <u>8363</u> Heat Set <u>250</u> °F Post-Test Pitot Inspection (N=no change, D=damaged) Pitot Lk Rate Pre: Hi @ <u>5</u> Post @ <u>5</u> in H2O@in H2O Lo @ <u>8</u> @ <u>5</u></p>

<p>Operator <u>JM</u> Support <u>BC JF</u> Temperature, Ambient <u>80</u> (Ta) Moisture <u>6%</u> Tdb _____ Twb _____ Press., Static (Pstat) <u>- .3</u> Press., Bar (Pb) <u>32.1</u> Cyclonic Flow Expected? <u>No</u> If yes, avg. null angle _____ degrees</p>	<p><u>ALT-011</u> Std TC (ID°F) <u>5.7 72</u> Stack TC (ID°F) <u>2.4 72</u> Continuity Check <u>0</u> or <u>↓</u></p>	<p>Nozzle <u>512</u> Oven <u>05-5</u> Imp. Outlet <u>1-30</u> Filter <u>158714</u> Heat Set <u>250</u> °F Meter Box <u>25</u> dH@ <u>1.79729</u> Y, <u>49916</u> Meter Pretest: <u>0.014</u> cfm <u>15</u> inHg Leak Check Post: <u>0.006</u> cfm <u>6</u> inHg</p>
---	---	---

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading		Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
			°F (Ts)	°F (Tp)				°F (To)	°F (Ti)	METER Inlet/Avg. °F (Tm-in)	METER Outlet °F (Tm-out)			
			915	.065										
1	8.10	2.35	918	.541	.0406	.368	.37	105	258	282	54	79	79	4.5
2	8.20		921	.582	.0325	.290	.29	114	248	250	46	80	79	4.5
3	8.30		924	.332	.0265	.235	.24	118	251	250	45	80	79	4.5
4	8.40		927	.047	.0255	.226	.23	116	250	250	47	80	79	4.5
5	8.50		929	.770	.0266	.229	.23	133	250	250	48	80	79	4.5
6	9.00		932	.312	.0244	.211	.21	133	250	250	48	80	79	4.5
7	9.10		934	.701	.022	.180	.18	165	250	250	49	80	79	4.5
8	9.20		937	.191	.023	.189	.19	165	250	250	49	80	79	4.5
9	9.30		939	.595	.020	.182	.18	158	250	250	48	80	79	4.5
10	9.40		941	.939	.021	.174	.17	159	250	250	49	79	79	4.5
11	9.50		944	.356	.021	.175	.18	153	250	250	50	80	79	4.5
12	10.00		946	.898	.023	.190	.19	159	250	250	50	79	79	4.5
13	10.10		949	.228	.020	.167	.17	154	250	250	50	79	78	4.5
14	10.20		951	.555	.021	.174	.17	161	250	250	50	78	78	4.5
15	10.30		953	.879	.021	.174	.17	156	250	250	49	79	78	4.5
16	10.40		956	.158	.019	.157	.16	159	250	250	50	78	78	4.5
17	10.50		958	.425	.019	.157	.16	159	250	250	49	78	78	4.5
18	11.00		960	.650	.018	.149	.15	155	250	250	49	78	78	4.5
19	11.10		962	.821	.019	.158	.16	157	250	250	49	79	78	4.5
20	11.20		965	.175	.023	.214	.21	90	250	250	52	78	78	4.5
21	11.30		967	.999	.027	.293	.25	85	250	250	52	79	78	4.5
22	11.40		970	.400	.018	.17	.17	79	250	250	50	79	78	4.5
23	11.50		972	.694	.017	.161	.16	80	250	250	50	79	78	4.5
24	12.00		975	.039	.018	.170	.17	80	250	250	50	79	78	4.5
25	12.10		977	.552	.021	.148	.20	81	250	244	51	79	78	4.5

Notes:

Field Data Sheet

MONTROSE
THE QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Glass Nozzle Measurements
1 _____
2 _____
3 _____

Client: Bullseye Glass
Facility Location: Portland, OR
Source: Blast Furnace T-7
Sample Location: Inlet

Date: 4/28/16
Test Method: 5
Concurrent Testing: 0061
Run #: 2

Probe 2-4 (g/s) Cp: 8363 Heat Set 250 °F
Post-Test Pitot Inspection (N=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 5 Post 0 @ 5
Lo 0 @ 5 0 @ 5

Operator: SM Support: BC JF
Temperature, Ambient: 80 (Ta)
Moisture: 6% Tdb - Twb -
Press., Static (Pstat): 3 Press., Bar (Pb): 30.1

ALT-011
Std TC (ID/°F): SH 72
Stack TC (ID/°F): 24 72
Continuity Check: 3 or ↓

Nozzle: 512 Oven (S-5) Imp. Outlet: 1-30
Filter: 158714 Heat Set: 250 °F
Meter Box: 25 dH@ 1.79724 X .99716

Cyclonic Flow Expected? NO If yes, avg. null angle _____ degrees


Meter Pretest: 0.004 cfm 15 inHg
Leak Check Post: 0.006 cfm 6 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2O (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter °F (To)	IMPINGER Outlet °F (Ti)	METER Inlet/Avg °F (Tin-in)	METER Outlet °F (Tin-out)	Pump Vacuum inHg (Pv)
							°F (Ts) Amb: -	°F (Tp) Amb: -	Amb: -	Amb: -	Amb: -	Amb: -	
1	2	12.20	979.827	.017	.161	.16	80	250	250	50	78	78	5
2	3	12.30	982.145	.018	.170	.17	80	250	250	52	78	78	5
3	4	12.40	984.775	.023	.228	.22	79	250	250	53	78	78	5
4	5	12.50	987.207	.021	.179	.18	139	250	250	53	78	78	5
5	6	13.00	989.590	.019	.170	.17	139	250	250	54	79	78	5
6	7	13.10	992.036	.0215	.182	.18	144	250	250	57	79	78	5
7	8	13.20	994.422	.0208	.176	.18	144	250	250	57	78	78	5
8	9	13.30	996.623	.0183	.154	.15	148	250	250	56	79	79	5
9	10	13.40	998.998	.0210	.178	.18	144	250	250	56	79	78	5
10	11	13.50	001.201	.0175	.148	.15	143	250	250	55	77	77	5
11	12	14.00	003.325	.0165	.139	.14	143	250	250	56	77	77	5
12	12	14.10	005.380	.0152	.128	.13	146	250	250	56	77	77	5
13	11	14.20	007.652	.0144	.164	.16	144	250	250	57	72	77	5
14	10	14.30	009.954	.0182	.155	.16	139	250	250	58	77	77	5
15	9	14.40	012.266	.0190	.163	.16	135	250	250	58	78	78	5
16	8	14.50	014.555	.0187	.161	.16	134	250	250	60	79	78	5
17	7	14.55	015.756	.0144	.167	.17	136	250	250	61	79	79	5
18													
19													
20													
21													
22													
23													
24													
25													

Notes:

3974


Field Data Sheet

		13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505		Glass Nozzle Measurements 1 — 2 — 3 — 309		Client: WOLFEYEGLASS Facility Location: PORTLAND OR Source: WAST FURNACE T-7 Sample Location: INLET							
Date: 4/28/16 Test Method: 5 Concurrent Testing: 0061 Run #: 5		Operator: SM Support: _____ Temperature, Ambient \leq (Ta): _____ Moisture: 3 Tdb: _____ Twb: _____ Press., Static (Pstat): 0.31 Press., Bar (Pb): 30.1 Cyclonic Flow Expected? N/O If yes, avg. null angle _____ degrees		Std TC (ID/F): 5L 81 Stack TC (ID/F): 24 81 Continuity Check: <input checked="" type="checkbox"/> or <input type="checkbox"/>		Probe: 2-4 (g/s) Cp: 0.6363 Heat Set: 250 °F Post-Test Pitot Inspection: (N/C) no change, D=damaged Pitot Lk Rate: Pre: Hi 0 @ 5 Post: 0 @ 9 in H2O@in H2O: Lo 0 @ 5 0 @ 8 Nozzle: 512 Oven: 05-51 Imp. Outlet: 1-510 Filter: 158-713 Heat Set: 250 °F Meter Box: 25 dH@ 1.79729 Y.99916							
				Meter: Pretest: 0.006 cfm 15 inHg Leak Check: Post: 0.092 cfm 8 inHg									
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vol)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK °F (Ts)	PROBE °F (Tp)	OVEN Filter °F (To)	IMPINGER Outlet °F (Ti)	METER Inlet/Avg. °F (Tm-in)	METER Outlet °F (Tm-out)	Pump Vacuum inHg (Pv)
		1700	0.21 567										
1	10		25.163	.049	.116	.12	151	260	258	66	86	86	2
2	20		28.717	.045	.138	.138	153	257	252	55	88	87	2
3	30		31.847	.039	.130	.131	147	249	250	53	89	87	2
4	40		35.010	.041	.116	.132	212	245	250	55	90	88	2
5	50		38.066	.039	.130	.130	222	249	250	50	91	88	2
6	1:00		40.650	.027	.120	.121	196	250	251	49	92	89	1.5
7	1:10		43.562	.032	.127	.127	222	250	249	57	93	90	2
8	1:20		46.455	.036	.127	.127	223	250	250	50	93	90	2
9	1:30		49.386	.035	.126	.127	205	250	250	51	93	90	2
10	1:40		52.264	.034	.125	.126	207	251	249	50	93	92	2
11	1:50		55.119	.035	.128	.129	173	250	250	50	94	93	2
12	2:00		58.200	.033	.128	.128	142	250	250	53	95	93	2
13	2:10		61.382	.035	.118	.112	118	250	250	53	94	93	2.5
14	2:20		64.493	.037	.111	.131	164	250	250	51	94	93	2.5
15	2:30		67.398	.032	.126	.127	170	250	250	50	93	93	2.5
16	2:40		70.205	.030	.125	.125	180	250	250	52	93	93	2.5
17	2:50		73.184	.033	.127	.128	178	250	250	52	93	93	2.5
18	3:00		76.076	.032	.126	.127	163	250	250	50	92	92	2.5
19	3:10		79.989	.034	.129	.129	158	250	250	50	92	92	2.5
20	3:20		82.566	.046	.133	.139	140	258	257	50	91	91	2.3
21	3:30		85.910	.045	.135	.135	214	250	250	46	92	91	3
22	3:40		89.011	.041	.130	.131	241	250	250	47	91	90	3
23	3:50		91.818	.035	.126	.126	244	250	249	49	91	90	3
24	4:00	2:55/1:14	95.167	.044	.134	.135	206	250	250	54	86	88	3.5
25													

Notes: B:\Shared files\FieldData Sheets\Method 5\Method 5_v2.pdf

Field Data Sheet

2 of 48

	13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505	Glass Nozzle Measurements 1 <u> </u> 2 <u> </u> 3 <u> </u> 309	Client: BULLSEYE GLASS Facility Location: PULLMAN OR Source: WAST FURNACE T-7 Sample Location: INLET
---	---	--	---

Date 4/28/16
 Test Method 5
 Concurrent Testing 0061
 Run # 3

Operator GA Support
 Temperature, Ambient 81 (Ta)
 Moisture 3 Tdb Twb
 Press., Static (Pstat) -3 (Press., Bar (Pb)) 30.1
 Cyclonic Flow Expected? NO If yes, avg. null angle degrees

ALT-011 4/4/18
 Std TC (ID/PF) 5/16 81
 Stack TC (ID/PF) 2-4 81
 Continuity Check U or ↓

Probe 2-4 (g/s) Cp .8363 Heat Set 250 °F
 Post-Test Pitot Inspection NO (no change, D=damaged)
 Pitot Lk Rate Pre: Hi 0 @ 5 Post 0 @ 4
 in H2O@in H2O Lo: 2 @ 5 0 @ 8
 Nozzle 512 Oven 65-51 Imp. Outlet 1-40
 Filter 1/8 7/19 Heat Set 250 °F
 Meter Box 25 dH@ 179279 Y .99916


Meter Pretest: 0.006 cfm 15 inHg
 Leak Check Post: 0.002 cfm 8 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F Inlet/Avg (Tm-in)	°F Outlet (Tm-out)	
1	4:10		97.941	.032	.254	.25	197	250	250	47	87	88	3
2	4:20		101.635	.049	.420	.42	152	250	250	49	87	87	4
3	4:30		104.818	.038	.316	.32	172	250	251	45	89	87	3.5
4	4:40		107.491	.030	.225	.23	238	250	250	48	90	87	3
5	4:50		109.936	.027	.203	.20	248	250	250	52	89	88	3
6	4:00		112.376	.025	.188	.19	256	250	250	54	89	88	3
7	4:10 6:5:10		115.404	.038	.299	.30	207	249	250	53	89	88	4
8	5:20		118.675	.042	.330	.33	182	250	249	51	90	88	4
9	5:30		122.125	.043	.361 .403 .38	.36	165	250	250	49	91	89	4.5
10	5:40		125.655	.045	.378	.38	160	250	250	50	91	89	4.5
11	5:50		129.489	.051	.454	.45	130	249	250	48	91	89	5
12	6:00		133.054	.047	.392	.39	170	250	250	47	91	89	5
13	6:10		136.295	.043	.331	.33	222	250	250	49	91	89	4.5
14	6:20		139.360	.038	.292	.29	232	250	249	50	91	89	4.5
15	6:30		142.296	.035	.262	.26	240	250	250	50	90	89	4
16	6:40		145.249	.038	.301	.3	202	250	250	51	90	89	4.5
17	6:50		148.431	.037	.307	.31	172	250	250	49	89	89	4.5
18	7:00		151.871	.043	.364	.36	160	250	250	47	89	89	5
19	7:10		149.971 158.547	.035	.256	.30	157	250	250	47	89	89	5
20	7:20		158.547	.043	.385	.39	126	250	250	48	90	89	5.5
21	7:30		161.713	.038	.317	.32	170	249	250	45	89	88	6
22	7:40		164.556	.034	.264	.26	214	250	250	44	87	86	5
23	7:50		167.632	.038	.296	.30	220	250	250	46	86	87	5
24	8:00	1:30	170.445	.033	.254	.25	214	250	250	47	87	86	5
25													

Notes: B:\Shared files\FieldData Sheets\Method 5\Method 5_v2.pdf
 Leak check for At pause from 170.445 HORIZON ENGINEERING 16-5702
 Leak check good

40f4
42

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>		Glass Nozzle Measurements				<p>Client: <u>Ballsege Glass</u></p> <p>Facility Location: <u>Portland, OR</u></p> <p>Source: <u>Blast Furnace T-7</u></p> <p>Sample Location: <u>Inlet</u></p>							
		Date <u>4/29/16</u>		1 <u> </u>		Probe <u>2-4</u> (g/s) Cp: <u>8363</u> Heat Set <u>250</u> °F							
		Test Method <u>5</u>		2 <u> </u>		Post-Test Pitot Inspection (NC=no change, D=damaged)							
		Concurrent Testing <u>0061</u>		3 <u> </u>		Pitot Lk Rate Pre: Hi <u>0</u> @ <u>5</u> Post <u>0</u> @ <u>9</u>							
Run # <u>3</u>		<p style="font-size: 2em; margin: 0;">309</p>				in H2O@in H2O Lo <u>0</u> @ <u>5</u> Hi <u>0</u> @ <u>8</u>							
Operator <u>JM</u> Support <u>RC CH</u>						Nozzle <u>512</u> Oven <u>05-51</u> Imp. Outlet <u>1-40</u>							
Temperature, Ambient <u>81</u> (Ta)		ALT-011				Filter <u>158713</u> Heat Set <u>230</u> °F							
Moisture <u>3</u> Tdb <u>-</u> Twb <u>-</u>		Std TC (ID/°F) <u>JL 81</u>				Meter Box <u>25</u> dH@ <u>1.79275</u> Y <u>.99916</u>							
Press., Static (Pstat) <u>31</u> Press., Bar (Pb) <u>30.1</u>		Stack TC (ID/°F) <u>2-4 81</u>				Meter Pretest: <u>0.086</u> cfm <u>15</u> inHg							
Cyclonic Flow Expected? <u>No</u> If yes, avg. null angle <u> </u> degrees		Continuity Check <input checked="" type="radio"/> Or <input type="radio"/>				Leak Check Post: <u>0.002</u> cfm <u>8</u> inHg							
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cfm (Vm)	Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)	
1	2	12.20	224.402	0.146	.121	.12	162	250	250	56	83	83	5
2	3	12.30	226.308	0.144	.119	.12	161	250	250	56	83	83	5
3	4	12.40	228.209	0.146	.121	.12	163	250	250	58	83	83	5
4	5	12.50	230.101	0.147	.122	.12	162	250	250	56	82	83	5
5	6	13.00	232.080	0.153	.127	.13	161	250	250	59	84	83	5
6	7	13.10	233.906	0.127	.105	.11	166	250	250	60	83	83	5
7	8	13.20	235.570	0.121	.104	.10	169	250	250	62	83	84	5
8	9	13.30	237.367	0.126	.144	.14	169	250	250	64	84	84	5
9	10	13.40	239.469	0.149	.123	.12	166	250	250	62	84	84	5
10	11	13.50	241.307	0.134	.111	.11	163	250	250	58	85	85	5
11	12	14.00	243.144	0.136	.1084	.11	189	250	250	57	85	85	5
12	12	14.10	245.066	0.148	.124	.12	158	250	250	58	86	86	5
13	11	14.20	247.172	0.151	.132	.13	134	250	250	58	86	86	5
14	10	14.30	249.019	0.135	.116	.12	143	250	250	58	86	86	5
15	9	14.40	250.886	0.133	.11	.11	166	250	250	59	86	86	5
16	8	14.50	251.070	0.126	.088	.10	203	250	250	59	86	86	5
17	14.40	14.29											
18													
19													
20													
21													
22													
23													
24													
25													

Notes:
B:\Shared files\FieldData Sheets\Method 5\Method 5_v2.pdf

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Glass Nozzle Measurements

Client: **Bullseye**
Facility Location: **Portland**
Source: **outlet #7**
Sample Location: **Roof**

Date: **4/26/14**
Test Method: **OMS**
Concurrent Testing: **VES**
Run #: **1**

1 _____
2 _____
3: **3135**

Probe: **3-6** (g/s) Cp: **8472** Heat Set: **250** °F
Post-Test Pitot Inspection: **8378** (NC=no change, D=damaged)
Pitot Lk Rate: Pre: Hi **0** @ **12** Post: **0** @ **6**
in H2O@in H2O: Lo **0** @ **10** **0** @ **5**

Operator: **100** Support: _____

ALT-011

Nozzle: **F-4065** Oven: **62349** Imp. Outlet: **F-40**

Temperature, Ambient (Ta): _____

Std TC (ID/°F): **62** °F

Filter: **58758** Heat Set: **250** °F

Moisture: **3%** Tdb: **130** Twb: **120**

Stack TC (ID/°F): **61**

Meter Box: **3** dH@: **1.8884** Y: **99156**

Press., Static (Pstat): **✓** Press., Bar (Pb): **29.9**

Continuity Check: **Ⓟ** or ↓

Meter: Pretest: **0.001** cfm **16"** inHg


Cyclonic Flow Expected? _____ If yes, avg. null angle _____ degrees

Leak Check: **SEE REPORT** **4.008** cfm **11"** inHg

Traverse Point Number	Sampling Time (min)	Clock Time (24 hr)	Dry Gas Meter Reading outfl (Vn)	Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK		OVEN Filter (To)	IMPINGER Outlet (Ti)	METER Inlet/Avg. (T)	METER Outlet (Tm-out)	Pump Vacuum inHg (Pv)
							°F (Ta)	°F (Tp)					
		17:31 5:31	950.104	0.08	1.2935	1.3	102	250	263	51	67	67	4
1	10		956.295	0.14	2.2636	2.2	120	251	263	53	72	61	4
2	20		964.440	0.14	2.2636	2.3	123	253	246	60	74	69	4
3	30		972.785	0.11	1.7785	1.8	150	250	256	57	76	74	4
4	40		980.16	0.10	1.6169	1.6	160	254	244	56	70	69	4
5	50		987.235	0.09	1.4552	1.4	166	250	250	56	72	70	3.5
6	60		993.800	0.09	1.4552	1.5	148	253	243	53	68	66	3
7	70		1000.47	0.06	0.9701	0.97	168	249	244	54	64	63	3
8	80		1005.900	0.05	0.8084	0.81	174	250	260	52	64	63	2.5
9	90		1010.97	0.05	0.8084	0.81	179	250	244	56	65	62	2
10	100		1015.875	0.05	0.8084	0.81	172	254	265	54	63	62	2
11	110		1020.805	0.05	0.8084	0.80	152	250	248	56	63	62	2
12	120		1025.63	0.05	0.8084	0.80	164	250	258	53	62	62	2
13	130		1030.475	0.05	0.8084	0.81	175	250	255	52	64	61	2
14	140		1035.310	0.05	0.8084	0.81	184	249	241	54	66	62	2
15	150		1040.200	0.05	0.8084	0.81	186	249	261	54	66	62	2
16	160		1045.095	0.05	0.8084	0.81	181	250	246	54	65	62	2
17	170		1049.985	0.05	0.8084	0.81	169	253	263	52	66	61	2
18	180		1054.915	0.06	0.9701	0.97	159	249	251	51	66	62	3
19	190		1060.380	0.07	1.1318	1.1	144	252	250	51	66	62	3
20	200		1066.100	0.07	1.1318	1.1	111	251	255	53	67	66	3
21	210		1071.740	0.07	1.1318	1.1	173	253	246	52	68	62	3
22	220		1077.365	0.07	1.14	1.1	176	253	246	53	68	65	3
23	230		1082.985	0.10	1.6367	1.6	171	255	245	53	68	64	3
24	240		1089.975	0.10	1.6367	1.6	149	250	258	51	66	62	3
25	250		1096.995	0.10	1.6367	1.6	148	253	251	52	69	64	3

Notes: **Paused @ 69.17 in run RSC 18:50**
B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p><i>SEE PAGE 1</i></p> <p>Glass Nozzle Measurements</p>		Client: <i>Run/leg</i> Facility Location: <i>Portland OR</i> Source: <i>Outlet 5-7</i> Sample Location: <i>Outlet</i>
	Date: <i>4/26/16</i>	1	Probe <i>3-6 (g/s) Cp. 8378 Heat Set 250 °F</i>
	Test Method: <i>ODEQ 5</i>	2	Post-Test Pitot Inspection: <i>NC</i> (NC=no change, D=damaged)
	Concurrent Testing: <i>Yes</i>	3	Pitot Lk Rate: <i>Pre: Hi 0 @ 12 Post 2 @ 6</i> <i>in H2O @ in H2O Lo 0 @ 10 @ 0 @ 7</i>

Operator: <i>PS</i>	Support: <i>-</i>	ALT-011	Nozzle: <i>5-635 Oven 621349 Imp. Outlet I-40</i>
Temperature, Ambient (Ta): <i>-</i>	Std TC (ID/°F): <i>62 POT</i>	Stack TC (ID/°F): <i>61</i>	Filter: <i>158758 Heat Set 250 °F</i>
Moisture: <i>3% Tdb 130 Twb 120</i>	Press., Static (Pstat): <i>1</i>	Press., Bar (Pb): <i>29.9</i>	Meter Box: <i>dH @ 1.8884 Y. 99150</i>
Cyclonic Flow Expected? <i>Yes</i> If yes, avg. null angle <i>✓</i> degrees	Continuity Check: <i>1</i> or <i>↓</i>		Meter Pretest: <i>0.001 cfm 16" inHg</i> Leak Check Post: <i>0.082 cfm 14" inHg</i>

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vin)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	Outlet °F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)	
			1104.00				Amb: -	Amb: -	Amb: -	Amb: -	Amb: -	Amb: -	
2	260	22:00	1083.00	0.11	1.7938	1.8	138	254	256	53	67	63	3.5
3	270		1111.350	0.12	1.9568	1.9	136	255	244	52	69	64	4
4	280		1118.945	0.11	1.7938	1.8	137	249	252	48	76	64	4
5	290		1126.370	0.10	1.6367	1.6	158	257	250	47	77	66	4
6	300	*	1133.405	0.08	1.3046	1.3	170	251	251	44	91	65	3
7	310		1139.780	0.02	0.3261	0.33	159	254	254	50	69	66	1
8	320		1142.830	0.07	1.1415	1.1	170	253	248	50	67	65	3
9	330		1148.400	0.06	0.9784	0.98	168	248	261	49	69	66	3
10	340		1153.885	0.06	0.9784	0.98	155	247	254	48	69	65	3
11	350		1159.345	0.07	1.1415	1.1	147	254	260	47	68	65	3
12	360		1165.070	0.06	0.9784	0.98	143	252	248	47	68	65	3
13	370		1170.780	0.06	0.9784	0.98	152	251	250	47	68	65	3
14	380		1176.235	0.05	0.8154	0.81	173	252	258	49	68	64	3
15	390		1181.190	0.05	0.8154	0.81	179	252	241	50	68	64	3
16	400	00:24	1186.100	0.06	0.9784	0.98	182	252	264	50	68	64	3
17	410		1191.530	0.06	0.9784	0.98	173	250	244	49	69	65	3
18	420		1196.985	0.09	1.4676	1.4	154	251	263	49	72	66	4
19	430		1203.570	0.09	1.4676	1.4	148	250	243	49	73	66	3
20	440		1210.180	0.09	1.4676	1.4	136	257	262	49	73	68	3
21	450		1216.79	0.06	0.9784	0.98	120	242	249	49	74	68	3
22	460		1222.855	0.05	0.8154	0.81	115	256	264	50	74	69	3
23	470		1227.790	0.04	0.6523	0.65	114	253	243	50	73	69	3
24	480		1232.113	0.09	1.477	1.5	177	245	250	50	72	71	3
25	490		1232.155										
26	500		1238.7	0.08	1.30	1.3	164	249	249	49	76	74	3
27	500		1245.21	0.07	1.14	1.1	151	253	254	49	75	74	3

5
6
1/27
7
orange
start
20158

no HazMat

Notes: * 22:42 Paused NO Flow Restart @ 22:44 Flow @ 0.02 when came back Cont. to Run @ 1.3 with HORIZON ENGINEERING 16-5702
300617 Job Revs
315 into Run 20 of 71

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

SEE PAGE 1
Glass Nozzle Measurements
1 _____
2 _____
3 .3235

Client: Bullseye
Facility Location: Portland OR
Source: outlet T-7
Sample Location: outlet

Date: 4/27/16
Test Method: ORDER 5
Concurrent Testing: Bags
Run #: R-1

Probe: 3-6 (g/s) Cp 8378 Heat Set: 250 °F
Post-Test Pitof Inspection: NC (NC=no change, D=damaged)
Pitot Lk Rate: Pre: Hi 0 @ R Post 0 @ 6
in H2O@in H2O: Lo 0 @ 10 0 @ 7

Operator: BS Support: DH
Temperature, Ambient (Ta): _____
Moisture: 3% Tdb: 130 Twb: 120
Press., Static (Pstat): 1 Press., Bar (Pb): 30.1
Cyclonic Flow Expected? N If yes, avg. null angle: _____ degrees

ALT-011
Std TC (ID/°F): 65 P8
Stack TC (ID/°F): 65
Continuity Check: ↑ or ↓

Nozzle: S-635 Oven: 621347 Imp. Outlet: 250 I 41 PC
Filter: 158757 Heat Set: 250 °F
Meter Box: 3 dh @ 1.8884 Y.9750
Meter: Pretest: 0.002 cfm 20 inHg
Leak Check: PT Post: 0.002 cfm 11.7 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dl)	STACK °F (Ts)	PROBE °F (Tp)	OVEN Filter °F (To)	IMPINGER Outlet °F (Ti)	METER		Pump Vacuum inHg (Pv)
											Inlet/Avg °F (Tn-in)	Outlet °F (Tn-out)	
			<u>1251.216</u>										
1	510	<u>1251.011</u>	<u>1251.216</u>	<u>.07</u>	<u>1.19</u>	<u>1.2</u>	<u>146</u>	<u>254</u>	<u>251</u>	<u>49</u>	<u>75</u>	<u>73</u>	<u>3</u>
2	520	<u>5</u>	<u>1262.601</u>	<u>.06</u>	<u>1.02</u>	<u>1.0</u>	<u>143</u>	<u>256</u>	<u>259</u>	<u>49</u>	<u>75</u>	<u>72</u>	<u>3</u>
3	530	<u>6</u>	<u>1268.034</u>	<u>.05</u>	<u>.86</u>	<u>.86</u>	<u>138</u>	<u>254</u>	<u>250</u>	<u>49</u>	<u>74</u>	<u>69</u>	<u>3</u>
4	540	<u>7</u>	<u>1272.988</u>	<u>.05</u>	<u>.86</u>	<u>.86</u>	<u>137</u>	<u>254</u>	<u>256</u>	<u>50</u>	<u>74</u>	<u>71</u>	<u>3</u>
5	550	<u>8</u>	<u>1277.991</u>	<u>.05</u>	<u>.86</u>	<u>.86</u>	<u>125</u>	<u>252</u>	<u>255</u>	<u>51</u>	<u>73</u>	<u>71</u>	<u>3</u>
6	560	<u>9</u>	<u>1283.816</u>	<u>.06</u>	<u>1.02</u>	<u>1.0</u>	<u>119</u>	<u>250</u>	<u>243</u>	<u>48</u>	<u>73</u>	<u>69</u>	<u>3</u>
7	570	<u>10</u>	<u>1288.324</u>	<u>.06</u>	<u>1.02</u>	<u>1.0</u>	<u>115</u>	<u>253</u>	<u>251</u>	<u>49</u>	<u>74</u>	<u>69</u>	<u>3</u>
8	580	<u>11</u>	<u>1294.320</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>143</u>	<u>251</u>	<u>244</u>	<u>49</u>	<u>73</u>	<u>72</u>	<u>2</u>
9	590	<u>12</u>	<u>1299.557</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>136</u>	<u>255</u>	<u>251</u>	<u>48</u>	<u>73</u>	<u>69</u>	<u>2</u>
10	600		<u>1304.167</u>	<u>.04</u>	<u>.71</u>	<u>.71</u>	<u>135</u>	<u>252</u>	<u>246</u>	<u>49</u>	<u>72</u>	<u>68</u>	<u>2</u>
11	610	<u>11</u>	<u>1309.342</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>114</u>	<u>250</u>	<u>247</u>	<u>49</u>	<u>73</u>	<u>72</u>	<u>2</u>
12	620	<u>10</u>	<u>1314.602</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>126</u>	<u>251</u>	<u>251</u>	<u>49</u>	<u>72</u>	<u>71</u>	<u>2</u>
13	630	<u>9</u>	<u>1314.602</u>	<u>.04</u>	<u>.71</u>	<u>.71</u>	<u>123</u>	<u>253</u>	<u>251</u>	<u>49</u>	<u>72</u>	<u>71</u>	<u>2</u>
14	640	<u>8</u>	<u>1319.198</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>124</u>	<u>250</u>	<u>254</u>	<u>49</u>	<u>71</u>	<u>69</u>	<u>2</u>
15	650	<u>9</u>	<u>1324.612</u>	<u>.05</u>	<u>.88</u>	<u>.88</u>	<u>124</u>	<u>253</u>	<u>258</u>	<u>49</u>	<u>71</u>	<u>67</u>	<u>2</u>
16	660	<u>6</u>	<u>1330.618</u>	<u>.07</u>	<u>1.24</u>	<u>1.2</u>	<u>140</u>	<u>255</u>	<u>260</u>	<u>49</u>	<u>71</u>	<u>70</u>	<u>2</u>
17	670	<u>5</u>	<u>1336.752</u>	<u>.07</u>	<u>1.24</u>	<u>1.2</u>	<u>143</u>	<u>252</u>	<u>251</u>	<u>49</u>	<u>72</u>	<u>71</u>	<u>2</u>
18	680	<u>4</u>	<u>1343.246</u>	<u>.08</u>	<u>1.41</u>	<u>1.4</u>	<u>135</u>	<u>251</u>	<u>255</u>	<u>49</u>	<u>72</u>	<u>71</u>	<u>2</u>
19	690	<u>3</u>	<u>1349.143</u>	<u>.07</u>	<u>1.24</u>	<u>1.2</u>	<u>133</u>	<u>251</u>	<u>247</u>	<u>51</u>	<u>72</u>	<u>71</u>	<u>2</u>
20	700	<u>2</u>	_____	<u>.08</u>	<u>1.41</u>	<u>1.4</u>	<u>132</u>	<u>255</u>	<u>255</u>	<u>49</u>	<u>72</u>	<u>71</u>	<u>3</u>
21	710	<u>1</u>	<u>1361.732</u>	<u>.07</u>	<u>1.24</u>	<u>1.2</u>	<u>140</u>	<u>252</u>	<u>244</u>	<u>49</u>	<u>73</u>	<u>72</u>	<u>3</u>
22	720		<u>1367.990</u>	<u>.08</u>	<u>1.41</u>	<u>1.4</u>	<u>136</u>	<u>253</u>	<u>256</u>	<u>49</u>	<u>72</u>	<u>68</u>	<u>3</u>
23	730	<u>2</u>	<u>1374.517</u>	<u>.08</u>	<u>1.41</u>	<u>1.4</u>	<u>132</u>	<u>254</u>	<u>251</u>	<u>49</u>	<u>71</u>	<u>66</u>	<u>3</u>
24	740	<u>3</u>	<u>1380.499</u>	<u>.07</u>	<u>1.24</u>	<u>1.2</u>	<u>131</u>	<u>252</u>	<u>252</u>	<u>49</u>	<u>73</u>	<u>72</u>	<u>3</u>
25	750	<u>4</u>	<u>1386.166</u>	<u>.06</u>	<u>1.06</u>	<u>1.1</u>	<u>130</u>	<u>251</u>	<u>254</u>	<u>49</u>	<u>71</u>	<u>67</u>	<u>3</u>

Notes:

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

SEE PAGE 1
Glass Nozzle Measurements

Client: *Bullseye*
Facility Location: *Portland OR*
Source: *T2*
Sample Location: *outlet T07*

Date: *4/27/16*
Test Method: *ODEQ 5*
Concurrent Testing: *Rags*
Run #: *R-1*

1 *-*
2 *-*
3 *.3735*

Probe: *3-6* (g/s) Cp *.8378* Heat Set *250* °F
Post-Test Pitot Inspection: *AC* (NC=no change, D=damaged)
Pitot Lk Rate: Pre: Hi *0* @ *12* Post: *0* @ *6*
in H2O @ in H2O: Lo *0* @ *10* *0* @ *7*

Operator: *BS* Support: *JH*
Temperature, Ambient (Ta): *-*
Moisture: *3%* Tdb: *130* Twb: *120*
Press., Static (Pstat): *2* Press., Bar (PB): *30.1*
Cyclonic Flow Expected? *AC* If yes, avg. null angle: *-* degrees

ALT-011
Std TC (ID/°F): *6.5* *PT*
Stack TC (ID/°F): *6.5*
Continuity Check: *(1)* or *↓*

Nozzle: *S-635* Oven: *21349* Imp. Outlet: *I-41*
Filter: *158737* Heat Set: *250* °F
Meter Box: *3* dH@: *1.8884* Y: *.945* Pr: *.99150*
Meter: Pretest: *.001* cfm (6" inHg)
Leak Check: Post: *.008* cfm (11" inHg)

13

14

15

nd
1930

16

38
min.
test

Transverse Point Number	Sampling Time min (d)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)	
1	760	5	1391.851	.06	1.06	1.1	132	251	255	50	71	70	3
2	770	6	1391.261	.05	.88	.88	133	253	258	51	72	71	3
3	780	7	1402.671	.06	1.06	1.1	132	251	243	53	72	68	3
4	790	8	1407.282	.05	.88	.88	130	249	257	53	73	71	3
5	800	9	1413.001	.05	.88	.88	121	253	243	54	72	67	3
6	810	10	1417.834	.04	.71	.71	117	254	257	50	72	67	3
7	820	11	1423.141	.05	.88	.88	115	251	244	48	71	68	3
8	830	12	1428.444	.05	.88	.88	119	255	260	51	73	70	2
9	840		1433.038	.04	.71	.71	117	248	249	51	74	71	2
10	850	11	1438.667	.05	.88	.88	120	252	257	51	73	71	2
11	860	10	1443.781	.05	.88	.88	130	252	252	49	74	73	3
12	870	9	1449.469	.06	1.06	1.1	131	252	249	49	74	73	3
13	880	8	1455.301	.06	1.06	1.1	129	253	253	50	74	73	3
14	890	7	1461.174	.06	1.06	1.1	128	251	247	50	75	69	3
15	900	6	1466.412	.05	.88	.88	128	250	256	50	75	74	3
16	910	5	1472.571	.07	1.24	1.2	128	249	246	50	76	75	3
17	920	4	1478.555	.07	1.24	1.2	133	250	255	50	77	74	3
18	930	3	1484.313	.06	.88 <i>1.02</i>	.88 <i>1.02</i>	142	252	247	51	76	75	3
19	940	2	1489.350	.08	1.39	1.4	133	253	258	51	77	76	3
20	950	1											
21	960												
22	970												
23	980												
24	990												
25													

Notes:

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Date 4/27/16
Test Method ODAQ 5
Concurrent Testing YES
Run # 2

Glass Nozzle Measurements

1	-
2	-
3	<u>2735</u>

Client: Bulkley
Facility Location: Portland
Source: Outlet T-7
Sample Location: Roof

Probe 3-6 (g/s) Cp 8378 Heat Set 250 °F
Post-Test Pitot Inspection NC (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 5 Post 0 @ 33 °F
in H2O@in H2O Lo 0 @ 7 0 @ 55

Operator PS Support JH
Temperature, Ambient (Ta) ALT-011
Moisture 3% Tdb - Twb -
Press., Static (Pstat) Press., Bar (Pb) 30.1
Cyclonic Flow Expected? N If yes, avg. null angle - degrees

Std TC (ID/°F) 65 °F
Stack TC (ID/°F) 45

Nozzle 5635 Oven 62134 Imp. Outlet I-41
Filter 158757 Heat Set 250 °F
Meter Box 3 dH@ 1.8884 Y 99150

Meter Pretest: 0.00 cfm 20 inHg
Leak Check SEE PAGE 1 1.00 cfm 9 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tin-in)	°F (Tin-out)	inHg (Pv)
		<u>17:30</u>	<u>489.715</u>	<u>.03</u>	<u>.5247</u>	<u>.53</u>	<u>111</u>	<u>252</u>	<u>242</u>	<u>57</u>	<u>71</u>	<u>70</u>	<u>1</u>
1	10		<u>493.605</u>	<u>.03</u>	<u>.5247</u>	<u>.52</u>	<u>133</u>	<u>255</u>	<u>228</u>	<u>55</u>	<u>73</u>	<u>71</u>	<u>1</u>
2	20		<u>497.465</u>	<u>.03</u>	<u>.5247</u>	<u>.52</u>	<u>142</u>	<u>250</u>	<u>269</u>	<u>58</u>	<u>75</u>	<u>71</u>	<u>1</u>
3	30		<u>501.345</u>	<u>.03</u>	<u>.5247</u>	<u>.53</u>	<u>156</u>	<u>252</u>	<u>244</u>	<u>59</u>	<u>79</u>	<u>73</u>	<u>1</u>
4	40		<u>505.280</u>	<u>.04</u>	<u>.6996</u>	<u>.70</u>	<u>164</u>	<u>252</u>	<u>261</u>	<u>59</u>	<u>80</u>	<u>75</u>	<u>2</u>
5	50		<u>509.865</u>	<u>.03</u>	<u>.5247</u>	<u>.52</u>	<u>165</u>	<u>257</u>	<u>251</u>	<u>60</u>	<u>86</u>	<u>76</u>	<u>2</u>
6	60		<u>513.825</u>	<u>.04</u>	<u>.6996</u>	<u>.70</u>	<u>143</u>	<u>253</u>	<u>246</u>	<u>59</u>	<u>78</u>	<u>76</u>	<u>2</u>
7	70		<u>518.430</u>	<u>.06</u>	<u>1.0494</u>	<u>1.0</u>	<u>151</u>	<u>252</u>	<u>258</u>	<u>59</u>	<u>79</u>	<u>76</u>	<u>2</u>
8	80		<u>523.980</u>	<u>.06</u>	<u>1.0494</u>	<u>1.0</u>	<u>168</u>	<u>257</u>	<u>243</u>	<u>58</u>	<u>79</u>	<u>75</u>	<u>2</u>
9	90		<u>529.580</u>	<u>.08</u>	<u>1.3992</u>	<u>1.4</u>	<u>177</u>	<u>253</u>	<u>257</u>	<u>57</u>	<u>80</u>	<u>79</u>	<u>3</u>
10	100		<u>536.200</u>	<u>.08</u>	<u>1.3992</u>	<u>1.4</u>	<u>181</u>	<u>248</u>	<u>247</u>	<u>57</u>	<u>80</u>	<u>75</u>	<u>3</u>
11	110		<u>542.795</u>	<u>.09</u>	<u>1.5741</u>	<u>1.5</u>	<u>178</u>	<u>258</u>	<u>258</u>	<u>56</u>	<u>79</u>	<u>75</u>	<u>3</u>
12	120		<u>549.640</u>	<u>.09</u>	<u>1.5741</u>	<u>1.5</u>	<u>155</u>	<u>247</u>	<u>242</u>	<u>55</u>	<u>78</u>	<u>75</u>	<u>3</u>
13	130		<u>556.470</u>	<u>.09</u>	<u>1.5741</u>	<u>1.5</u>	<u>160</u>	<u>255</u>	<u>259</u>	<u>55</u>	<u>79</u>	<u>76</u>	<u>3</u>
14	140		<u>563.505</u>	<u>.08</u>	<u>1.3992</u>	<u>1.4</u>	<u>177</u>	<u>253</u>	<u>242</u>	<u>53</u>	<u>79</u>	<u>74</u>	<u>3</u>
15	150		<u>570.205</u>	<u>.08</u>	<u>1.3992</u>	<u>1.4</u>	<u>185</u>	<u>256</u>	<u>258</u>	<u>52</u>	<u>78</u>	<u>75</u>	<u>3</u>
16	160		<u>576.880</u>	<u>.07</u>	<u>1.2243</u>	<u>1.2</u>	<u>171</u>	<u>251</u>	<u>242</u>	<u>53</u>	<u>78</u>	<u>73</u>	<u>3</u>
17	170		<u>582.900</u>	<u>.06</u>	<u>1.0082</u>	<u>1.0</u>	<u>189</u>	<u>256</u>	<u>260</u>	<u>53</u>	<u>77</u>	<u>73</u>	<u>3</u>
18	180		<u>588.485</u>	<u>.05</u>	<u>.8402</u>	<u>.84</u>	<u>171</u>	<u>249</u>	<u>240</u>	<u>53</u>	<u>77</u>	<u>72</u>	<u>2</u>
19	190		<u>593.610</u>	<u>.04</u>	<u>.6722</u>	<u>.67</u>	<u>159</u>	<u>251</u>	<u>264</u>	<u>53</u>	<u>76</u>	<u>73</u>	<u>2</u>
20	200		<u>598.165</u>	<u>.03</u>	<u>.5300</u>	<u>.53</u>	<u>144</u>	<u>256</u>	<u>243</u>	<u>53</u>	<u>75</u>	<u>71</u>	<u>2</u>
21	210		<u>602.095</u>	<u>.03</u>	<u>.5163</u>	<u>.52</u>	<u>162</u>	<u>250</u>	<u>265</u>	<u>54</u>	<u>74</u>	<u>73</u>	<u>2</u>
22	220		<u>605.950</u>	<u>.02</u>	<u>.3329</u>	<u>.33</u>	<u>175</u>	<u>255</u>	<u>246</u>	<u>54</u>	<u>73</u>	<u>70</u>	<u>1</u>
23	230		<u>608.935</u>	<u>.02</u>	<u>.3329</u>	<u>.33</u>	<u>181</u>	<u>248</u>	<u>258</u>	<u>54</u>	<u>71</u>	<u>70</u>	<u>1</u>
24	240		<u>611.890</u>	<u>.03</u>	<u>.4994</u>	<u>.50</u>	<u>181</u>	<u>255</u>	<u>256</u>	<u>53</u>	<u>70</u>	<u>70</u>	<u>1</u>
25	250		<u>615.730</u>	<u>.04</u>	<u>.6765</u>	<u>.68</u>	<u>165</u>	<u>252</u>	<u>241</u>	<u>52</u>	<u>72</u>	<u>69</u>	<u>1</u>

Notes:

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Date: 4/27/16
Test Method: 012ED 5
Concurrent Testing: RASS
Run #: 2

SEE PAGE 1

Glass Nozzle Measurements

1 ---
2 ---
3 3735

Client: Bullseye
Facility Location: Portland OR
Source: Outlet T-7
Sample Location: Outlet

Probe 3-6 (g/s) Cp, 8378 Heat Set 250 °F
Post-Test Pitot Inspection: AC (NC=no change, D=damaged)
Pitot Lk Rate: Pre: Hi 0 @ 5 Post 0 @ 5 3 PT
in H2O@in H2O: Lo 0 @ 7 0 @ 5

Operator: PT Support: DH
Temperature, Ambient (Ta): --- ALT-011
Moisture: 3% Tdb - Twb 30.1 PT
Std TC (ID/°F): 65 PT
Stack TC (ID/°F): 65
Press., Static (Pstat): --- Press., Bar (Pb): 30.1 Continuity Check Or
Cyclonic Flow Expected? If yes, avg. null angle --- degrees

Nozzle: S-635 Oven: 621379 Imp. Outlet: I-41
Filter: 158757 Heat Set: 250 °F
Meter Box: 3 dH@ 18884 x 99150

Meter: Pretest: 0.2 cfm 20 inHg
Leak Check: Post: 0.2 cfm 9 inHg

Traverse Point Number	Sampling Time min (d)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg	METER Outlet	Pump Vacuum
							°F (Ts)	°F (Tp)	°F (To)	°F (Tb)	°F (Tm-in)	°F (Tm-out)	inHg (Pv)
1 2	260		620.265	.03	.5182	.52	152	253	260	51	71	69	1
2 3	270		624.195	.03	.5566	.56	144	252	244	52	70	68	1
3 4	280		628.230	.03	.5566	.56	140	255	265	52	71	68	1
4 5	290		632.270	.04	.7636	.76	127	253	241	51	71	68	2
5 6	300		637.040	.06	1.0915	1.0	156	253	261	51	71	68	2
6 7	310		642.585	.08	1.4287	1.4	171	249	242	51	73	68	3
7 8	320		649.170	.05	.8837	.88	173	253	253	51	71	68	2
8 9	330		654.380	.05	.8837	.88	172	252	240	51	71	69	2
9 10	340		659.575	.09	1.6479	1.6	152	252	263	51	72	68	3
10 11	350		666.620	.09	1.6479	1.6	150	253	244	51	72	68	3
6 11 12	360		673.725	.08	1.4692	1.4	142	247	259	51	72	68	3
12	370		680.350	.09	1.6922	1.7	136	256	241	51	72	68	4
13 11	380		687.635	.09	1.7094	1.7	130	251	259	51	72	68	3
14 10	390		694.930	.09	1.6399	1.6	155	258	245	51	73	67	3
15 9	400		702.000	.08	1.4275	1.4	168	256	260	51	71	67	3
16 8	410		708.645	.06	1.0555	1.1	177	253	243	52	71	66	2
7 17 7	420		714.470	.06	1.0555	1.1	177	258	259	51	71	67	2
18 6	430		720.170	.03	.5402	.54	160	252	246	52	71	66	1
19 5	440		724.145	.03	.5536	.55	145	257	261	52	69	66	1
20 4	450		728.180	.02	.3772	.37	132	256	254	52	69	66	1
21 3	460		731.385	.02	.3952	.39	105	251	250	53	68	66	1
22 2	470		734.730	.02	.3952	.39	103	251	264	51	67	66	1
23 1	480		737.974 738.027	.08	1.58 1.4	1.4 1.4	168	251	259	50	67	66	1
24 1	490		744.970	.08	1.42	1.4	177	256	260	51	69	64	1
25 2	500		761.485	.07	1.24	1.2	174	251	258	51	70	64	1

Notes: *Timer 316 Parger. Flow drop to .02 +ttt Keep Running @ 1.4
BACK up @ 319 - 334 Flow jump up to 1.8
Cont. to Run @ .88

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

HORIZON ENGINEERING 16-5702
2 of 4

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

SEE PAGE 1
Glass Nozzle Measurements
1 -
2 -
3 - 3735

Client: Bullseye Glass
Facility Location: Portland OR
Source: outlet
Sample Location: outlet T7

Date: 4/28/16
Test Method: ORDER 5
Concurrent Testing: 13095
Run # 2

Probe 3-6 (g/s) Cp. 8378 Heat Set 250 °F
Post-Test Pitot Inspection NC (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0@5 Post 0@33 ft
in H2O@in H2O Lo 0@7 0@5

Operator BS Support JH
Temperature, Ambient (Ta) ALT-011
Moisture 3% Tdb - Twb -
Press., Static (Pstat) ↓ Press., Bar (Pb) 30.1
Cyclonic Flow Expected? ✓ If yes, avg. null angle _____ degrees

Std TC (ID/°F) 65PT
Stack TC (ID/°F) 65
Continuity Check Ⓢ or ↓

Nozzle S-635 Oven 21349 Imp. Outlet I-41
Filter 158757 Heat Set 250 °F
Meter Box 3 dH@ 1.8884 Y. 99150
Meter Pretest: .01 cfm 20 inHg
Leak Check Post: .02 cfm 9 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Fv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	
1	3	510	758.066	.06	1.06	1.1	157	249	252	52	71	70	2
2	4	520	764.634	.06	1.06	1.1	134	251	260	53	71	66	2
3	5	530	770.371	.05	.94	.94	138	252	255	53	70	69	1
4	6	540	775.580	.06	1.06	1.1	141	253	259	53	70	69	2
5	7	550	781.355	.05	.94	.94	141	249	246	54	72	71	2
6	8	560	786.731	.04	.76	.76	139	253	249	54	68	66	1
7	9	570	791.577	.05	.94	.94	138	253	244	53	69	65	2
8	10	580	797.241	.04	.75	.75	133	252	248	55	70	68	1
9	11	590	802.011	.04	.75	.75	118	250	243	51	69	66	1
10	12	600	806.781	.03	.59	.59	105	250	251	50	69	65	1
11		610	810.954	.03	.58	.58	105	248	247	49	69	65	1
12	11	620	815.188	.03	.58	.58	113	250	256	49	67	65	1
13	10	630	819.343	.04	.75	.75	113	248	250	49	67	66	1
14	9	640	824.295	.03	.58	.58	111	255	260	48	68	67	1
15	8	650	828.422	.03	.58	.58	112	253	248	49	67	64	1
16	7	660	832.614	.04	.76	.76	129	252	255	48	66	65	1
17	6	670	836.851	.04	.76	.76	131	253	248	49	67	64	1
18	5	680	842.066	.05	.94	.94	131	253	258	49	68	66	2
19	4	690	847.511	.05	.94	.94	131	255	250	47	68	64	2
20	3	700	852.992	.06	1.14	1.1	130	249	254	49	68	63	2
21	2	710	858.934	.06	1.14	1.1	131	250	249	48	68	63	2
22	1	720	864.621	.07	1.32	1.3	132	254	257	49	68	63	2
23		730	870.954	.08	1.51	1.5	131	250	249	49	69	67	3
24	2	740	876.677	.07	1.32	1.3	132	254	258	49	69	68	2
25	3	750	883.902	.06	1.14	1.1	130	251	249	50	68	64	2

Notes:

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

SEE PAGE 1
Glass Nozzle Measurements

Client: **Bullseye Glass**
Facility Location: **Portland OR**
Source: **OUTLET**
Sample Location: **+Z outlet**

Date: **4/26/16**
Test Method: **ODEQ 5**
Concurrent Testing: **RASP**
Run #: **2**

1 **-**
2 **-**
3 **.3735**

Probe: **3-6 (g/s) Cp. 8378** Heat Set: **250 °F**
Post-Test Pitot Inspection: **NC** (NC=no change, D=damaged)
Pitot Lk Rate: Pre: **Hi 0 @ 5** Post: **D @ 3**
in H2O@in H2O: Lo **0 @ 7** **0 @ 5**

Operator: **BS** Support: **JH**
Temperature, Ambient (Ta): **-**
Moisture: **3% Tdb** ~ **Twb** -
Press., Static (Pstat): **1** Press., Bar (Pb): **30.1**
Cyclonic Flow Expected? **✓** If yes, avg. null angle = **-** degrees

ALT-011
Std TC (ID/°F): **65.08**
Stack TC (ID/°F): **65**
Continuity Check: **0** or **↓**

Nozzle: **5635** Oven: **62349** Imp. Outlet: **I-41**
Filter: **158757** Heat Set: **250 °F**
Meter Box: **3 dH @ 1.8884** **V. 99150**
Meter: Pretest: **.002** cfm **20"** inHg
Leak Check: Post: **.007** cfm **9"** inHg

Transverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cfm (Vm)	Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	inHg (Pv)
			889.631										
1	760	4	889.631	.06	1.13	1.1	178	254	259	50	68	67	2
2	770	5	895.321	.05	.94	.94	127	249	247	50	68	67	2
3	780	6	900.628	.05	.94	.94	125	254	249	50	68	67	2
4	790	7	906.06	.04	.77	.77	115	250	251	51	68	67	2
5	800	8	911.542	.04	.77	.77	114	250	260	51	67	63	1
6	810	9	916.441	.03	.58	.58	108	250	247	52	67	66	1
7	820	10	920.704	.04	.77	.77	111	252	257	52	67	66	1
8	830	11	925.641	.03	.58	.58	113	256	249	52	67	65	1
9	840	12	929.847	.03	.58	.58	106	249	260	53	69	64	1
10	850		933.561	.03	.58	.58	107	252	250	53	66	63	1
11	860	11	937.712	.02	.39	.39	108	254	259	53	67	65	1
12	870	10	941.198	.03	.58	.58	105	251	251	53	67	66	1
13	880	9	945.412	.03	.58	.58	121	254	251	55	68	67	1
14	890	8	949.608	.03	.58	.58	115	249	257	55	68	67	1
15	900	7	953.762	.03	.58	.58	113	252	249	56	68	67	1
16	910	6	957.941	.04	.77	.77	120	258	252	55	69	62	1
17	920	5	962.718	.05	.96	.96	121	255	246	56	68	67	1
18	930	4	967.788	.06	1.15	1.2	119	253	256	56	68	67	2
19	940	3	973.824	.06	1.15	1.2	118	251	248	57	71	70	2
20	950	2	979.782	-	-	-	-	-	-	-	-	-	-
21	960	1											
22													
23													
24													
25													

13

14

15


16

Notes:

B:\Shared files\FieldsData Sheets\Method 5\Method 5_PDX-v1.pdf

End @ 0930, 950 min. test

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p>Glass Nozzle Measurements</p> <p>1 <u> </u> 2 <u> </u> 3 <u>23735</u></p>	<p>Client: <u>Bullseye</u> Facility Location: <u>Portland</u> Source: <u>T-7 outlet</u> Sample Location: <u>Roof</u></p>
<p>Date: <u>7/28/16</u> Test Method: <u>ODEQ 5</u> Concurrent Testing: <u>YES</u> Run #: <u>3</u></p>	<p>Probe: <u>3-6</u> (g/s) Cp. <u>8378</u> Heat Set <u>250</u> °F Post-Test Pitot Inspection: <u>NC</u> (NC=no change, D=damaged) Pitot Lk Rate: Pre: Hi <u>0 @ 6</u> Post <u>0 @ 6</u> in H2O @ in H2O: Lo <u>0 @ 5</u> <u>0 @ 6</u></p>	<p>Nozzle: <u>635</u> Oven: <u>234</u> Imp. Outlet: <u>1405N-2</u> Filter: <u>1.58764</u> Heat Set: <u>250</u> °F Meter Box: <u>3</u> dH@: <u>1.8884</u> Y: <u>59150</u></p>

<p>Operator: <u>186</u> Support: <u>14 MV</u> Temperature, Ambient (Ta): <u>63</u> Moisture: <u>3%</u> Tdb: <u>-</u> Twb: <u>-</u> Press., Static (Pstat): <u>1</u> Press., Bar (Pb): <u>30.1</u> Cyclonic Flow Expected? <u>N</u> If yes, avg. null angle: <u>-</u> degrees</p>	<p>ALT-011 Std TC (ID/°F): <u>1863</u> Stack TC (ID/°F): <u>63</u> Continuity Check: <u>1</u> or <u>↓</u></p>	<p>Meter: <u>.002</u> Pretest: <u>0.004</u> fpm <u>15</u> inHg Leak Check: <u>SEC</u> <u>Page 4</u> cfm <u>6</u> inHg</p>
--	---	---

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump
							°F (Ts)	°F (Tp)	°F (To)	°F (Tl)	Inlet/Avg °F (Tm-in)	Outlet °F (Tm-out)	Vacuum inHg (Pv)
1	10	15:08	980.136	.07	1.3431	1.3	116	257	241	60	71	71	2
2	20	17:08	986.350	.07	1.3431	1.3	134	249	261	65	71	71	1
3	30	17:05	992.540	.04	.7469	.75	136	256	244	64	71	71	1
4	40	5/6/16	997.325	.04	.7469	.75	131	252	259	58	74	72	1
5	50		1002.050	.04	.7238	.72	153	250	252	57	75	71	1
6	60		1006.686	.06	1.0735	1.1	162	254	247	55	77	72	2
7	70		1012.370	.04	.7156	.71	158	254	257	58	80	74	1
8	80		1017.065	.04	.7074	.70	174	248	244	59	81	75	1
9	90		1021.500	.04	.7074	.70	188	255	262	60	80	75	1
10	100		1026.230	.05	.8611	.86	191	250	242	60	82	76	1
11	110		1031.390	.05	.8643	.86	187	256	263	58	82	77	1
12	120		1036.605	.06	1.0718	1.1	170	255	242	59	78	76	2
13	130		1042.390	.06	1.0718	1.1	161	254	265	58	77	75	2
14	140		1048.200	.07	1.2309	1.2	180	255	244	57	77	75	2
15	150		1054.225	.06	1.0436	1.0	187	256	261	58	76	73	2
16	160		1059.805	.06	1.0309	1.0	195	250	246	59	76	72	2
17	170		1065.360	.05	.8950	.89	197	251	265	59	75	71	2
18	180		1070.685	.05	.8670	.86	189	250	248	59	75	71	2
19	190		1076.125	.05	.8670	.86	165	250	268	59	74	71	2
20	200		1081.045	.07	1.2812	1.3	149	253	256	59	74	72	3
21	210		1087.350	.03	.5463	.55	158	253	250	58	76	72	1
22	220		1091.350	.02	.3778	.37	137	249	263	59	73	71	1
23	230		1094.550	.02	.3777	.37	127	254	246	59	73	70	1
24	240		1097.755	.01	.1895	.19	125	256	253	59	73	71	1
25	250		1099.851	.01	.1980	.20	100	250	253	62	71	71	1
26	250		1101.980	.08	.9348	.93	133	250	243	61	73	72	1

Notes:

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

FAW Kicked Down @ 229 into Run Kick Back up @ 245 into Run
 .05 m VFA Nozzle
 HORIZON ENGINEERING 16-5702

2
3
K4
H

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

SEE PAGE 1

Glass Nozzle Measurements

1	---
2	---
3	<u>3.725</u>

Client: BULLSEYE
Facility Location: Portland OR
Source: T-7 outlet
Sample Location: Outlet

Date 4/28/16
Test Method ODEQ 5
Concurrent Testing BAAS
Run # 3

Probe 3-6 (g/s) Cp .8378 Heat Set 250 °F
Post-Test Pitot Inspection NC (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0@6 Post 0@6
in H2O@in H2O Lo 0@5 0@6

Operator PT Support JH MV
Temperature, Ambient (Ta) 63
Moisture 3.7 Tdb - Twb
Press., Static (Pstat), ± Press., Bar (Pb) 30.1
Cyclonic Flow Expected? N If yes, avg. null angle _____ degrees


ALT-011
Std TC (ID/°F) 10.63
Stack TC (ID/°F) 63
Continuity Check 1 or 1

Nozzle 635 Oven 621349 Imp. Outlet GN-2
Filter 158764 Heat Set 250 °F
Meter Box 3 dH@ 18884 X.99150
Meter Pretest: 0.004 cfm 15" inHg
Leak Check Post: .002 cfm 6" inHg

Traverse Point Number	Sampling Time min (st)	Clock Time (24 hr)	Dry Gas Meter Reading: cfm (Vn)	Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)	
							°F (Ts)	°F (Tp)	Filter °F (Te)	Outlet °F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)		
							Amb:	Amb:	Amb:	Amb:	Amb:	Amb:		
2	260	21:28	1107.270	.03	.5609	.56	122	253	266	58	77	71	1	
3	270		1171.330	.03	.5609	.56	126	248	248	59	75	71	1	
4	280		1115.370	.04	.7478	.75	120	251	259	58	76	75	1	
5	290		1120.130	.03	.5609	.56	116	254	261	60	76	75	1	
6	300		1124.145	.03	.5525	.55	142	257	241	60	75	74	1	
7	310		1128.135	.04	.6929	.69	180	258	268	60	75	72	1	
8	320		1132.760	.05	.8515	.85	191	255	245	57	75	72	2	
9	330		1137.830	.06	1.0410	1.0	179	249	261	54	75	71	2	
10	340		1143.435	.06	1.0410	1.0	160	249	242	55	75	71	2	
11	350		1149.020	.07	1.266	1.3	153	250	261	55	76	73	3	
12	360		1155.370	.07	1.2806	1.3	146	249	245	54	75	71	3	
12	370		1166.755	.07	1.3183	1.3	132	249	258	55	74	70	3	
13	380		1168.125	.06	1.0885	1.1	154	250	248	57	73	70	3	
14	390		1173.815	.06	1.0652	1.1	168	253	257	57	73	70	3	
15	400		1179.460	.05	.8724	.87	179	252	253	57	74	70	2	
16	410		1184.575	.05	.8669	.86	183	254	252	57	74	69	2	
17	420		1189.700	.05	.8877	.88	168	253	254	57	75	70	2	
18	430		1194.915	.05	.9035	.90	157	253	241	57	75	70	2	
19	440		1200.195	.04	.7371	.74	145	251	262	58	75	70	2	
20	450		1204.910	.04	.7470	.74	137	254	241	57	75	70	2	
21	460		1209.610	.03	.5747	.57	122	255	268	58	73	70	1	
22	470		1213.685	.02	.3831	.38	127	252	246	58	74	70	1	
23	480		1216.946 1217.064	.11	2.11	2.1	122	254	241	60	70	68	3	
24	490		1225.284	.10	1.91	1.9	156	253	247	57	71	70	3	
25	500		1233.068	.05	.76	.76	145	247	255	57	73	72	3	

Notes: Port change LEAKV 0.004 @ 10"

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>		<p style="font-size: 2em; color: red;">SEE PAGE 1</p> <p>Glass Nozzle Measurements</p> <p>1 <u> </u> 2 <u> </u> 3 <u>3735</u></p>		<p>Client: <u>JustSave</u> Facility Location: <u>PonHnd OR</u> Source: <u>T7 outlet</u> Sample Location: <u>Outlet</u></p>									
<p>Date: <u>4/28/16</u> Test Method: <u>ODEQ5</u> Concurrent Testing: <u>Bags</u> Run # <u>3</u></p>		<p>Operator: <u>135 Support JH MV</u> Temperature, Ambient (Ta): <u>63</u> Moisture: <u>3%</u> Tdb <u> </u> Twb <u> </u> Press., Static (Pstat): <u>1</u> Press., Bar (Pb): <u>30.1</u> Cyclonic Flow Expected? <u>N</u> If yes, avg. null angle <u> </u> degrees</p>		<p>Probe: <u>3-6 (g/s) Cp. 8378</u> Heat Set <u>250</u> °F Post-Test Pitot Inspection: <u>NC</u> (NC=no change, D=damaged) Pitot Lk Rate: Pre: Hi <u>0 @ 6</u> Post <u>0 @ 6</u> in H2O@in H2O: Lo <u>0 @ 5</u> <u>0 @ 6</u> Nozzle: <u>S-635 Ovens 2347 Imp. Outlet N-2</u> Filter: <u>158764</u> Heat Set <u>250</u> °F Meter Box: dH@ <u>1.8884</u> X. <u>9150</u></p>									
<p>Std TC (ID/°F): <u>63</u> Stack TC (ID/°F): <u>63</u> Continuity Check: <u>1</u> or <u>↓</u></p>		<p>Meter: Pretest: <u>0.4</u> cfm <u>15"</u> inHg Leak Check: Post: <u>0.02</u> cfm <u>6"</u> inHg</p>											
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum
							°F (Ts)	°F (Tp)	°F (To)	°F (Td)	°F (Tn-in)	°F (Tn-out)	inHg (Pv)
1	2	510	1238.731	.06	1.14	1.1	137	249	252	58	73	77	2
2	3	520	1244.504	.10	1.84	1.8	146	249	256	58	73	70	3
3	4	530	1251.729	.10	1.84	1.8	144	247	250	60	74	73	3
4	5	540	1259.260	.08	1.47	1.5	142	252	256	59	73	68	2
5	6	550	1265.921	.07	1.29	1.3	142	236	249	59	75	68	2
6	7	560	1272.107	.06	1.10	1.1	140	255	254	59	75	70	2
7	8	570	1278.449	.05	.92	.92	145	257	245	59	75	74	2
8	9	580	1283.698	.05	.92	.92	147	250	254	59	74	73	2
9	10	590	1289.039	.06	1.10	1.1	146	252	248	59	77	74	2
10	11	600	1294.987	.04	.74	.74	144	249	255	59	76	72	2
11	12	610	1300.545	.04	.74	.74	143	251	259	60	74	73	1
12	13	620	1304.912	.04	.74	.74	143	250	248	54	74	71	1
13	14	630	1309.652	.04	.74	.74	147	254	255	55	74	73	1
14	15	640	1314.554	.05	.92	.92	145	251	250	55	75	74	1
15	16	650		.05	.92	.92	145	254	256	54	75	70	1
16	17	660	1324.910	.05	.92	.92	144	252	247	54	74	73	1
17	18	670	1330.475	.04	.74	.74	144	251	256	53	76	70	1
18	19	680	1335.877	.05	.92	.92	145	250	251	53	74	70	2
19	20	690		.05	.92	.92	147	251	258	53	74	72	2
20	21	700	1346.039	.06	1.10	1.1	144	255	249	54	75	74	3
21	22	710	1352.045	.07	1.29	1.3	141	255	257	55	74	72	3
22	23	720	1358.061	.07	1.29	1.3	140	249	253	55	74	69	3
23	24	730	1364.487	.08	1.47	1.5	139	250	250	55	74	69	3
24	25	740	1371.824	.08	1.47	1.5	132	255	249	56	73	72	3
25	26	750	1378.274	.07	1.29	1.3	139	251	253	56	72	71	2

Notes:

Field Data Sheet

HORIZON ENGINEERING
 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Glass Nozzle Measurements

1
 2
 3 .3735

Client: Bullseye
 Facility Location: Portland OR
 Source: TZ
 Sample Location: outlet

Date: 4/29/16
 Test Method: ODER 5
 Concurrent Testing: Buss
 Run # 3

Probe 3-6 (g/s) Cp 8378 Heat Set 250 °F
 Post-Test Pitot Inspection NC (NC=no change, D=damaged)
 Pitot Lk Rate Pre: Hi 0 @ 17 Post 0 @ 6
 in H2O @ in H2O Lo 0 @ 5 0 @ 6

Operator BS Support JH MV
 Temperature, Ambient (Ta) 63
 Moisture 22 Tdb Twb
 Press., Static (Pstaf) Press., Bar (Pb) 30.1
 Cyclonic Flow Expected? If yes, avg. null angle degrees

ALT-011
 Std TC (ID/°F) P0 63
 Stack TC (ID/°F) 63

Nozzle S-635 Oven 621349 Imp. Outlet CV-2
 Filter 158764 Heat Set 250 °F
 Meter Box 3 dH@ 1.8004 899150

Meter Pretest: 004 cfm 15 inHg
 Leak Check Post: .002 cfm 0 inHg

Transverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg	METER Outlet	Pump Vacuum
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	inHg (Pv)
13 3	760		1384.100	.07	1.29	1.3	139	251	253	56	71	70	2
2 4	770		1390.466	.06	1.14	1.1	135	253	249	56	74	70	2
3 5	780			.06	1.14	1.1	134	250	247	55	73	69	2
4 6	790		1401.864	.05	.94	.94	134	250	246	56	74	69	2
5 7	800		1407.664	.06	1.14	1.1	133	256	259	57	73	69	2
6 8	810		1413.412	.05	.94	.94	134	253	248	56	74	70	2
13 7 9	820		1418.761	.05	.94	.94	135	251	259	56	74	69	2
8 10	830		1423.971	.04	.74	.74	136	248	250	55	73	69	2
9 11	840		1433.415	.04	.74	.74	136	247	251	55	74	71	1
10 12	850		1438.138	.04	.74	.74	136	248	253	56	74	73	1
14 11	860		1442.909	.04	.74	.74	136	251	248	56	75	74	1
12 11	870		1442.909	.04	.74	.74	136	253	254	57	75	74	1
13 10	880		1447.654	.03	.56	.56	133	250	246	58	76	74	1
14 9	890		1451.762	.04	.74	.74	131	254	250	59	76	75	1
15 8	900			.05	.94	.94	127	255	257	59	77	74	2
16 7	910		1460.342	.04	.74	.74	127	253	249	59	76	75	1
15 17	920		1465.718	.04	.74	.74	130	253	257	59	78	77	1
18 5	930	0900	1466.846										
19 4	940	*											
20 3	950												
21 2	960												
22 1	970												
16 23	980												
24													
25													

Notes: B:\Shared files\Field Data Sheets\Method 5\Method 5_v2.pdf

Sample Recovery / Moisture Catch

BULLSEYE
GLASS FURNACE T7-INLET
PORTLAND OR
ODEQ5

26-Apr-16
SH,JL,JF,BC,JM,CH,JH

Definitions	Symbol	Units	Run 1	Run 2	Run 3	mew
Impinger Contents						
	Impinger, Contents, Condensate & Rinse	g	1,039.20	1,080.00	778.13	
	Impinger, Contents & Condensate	g	866.10	900.00	651.00	
	spg (g/ml) Impinger	g	557.10	555.00	279.00	
	0.99823 H2O	ml	200.00	200.00	200.00	
	Condensate	g	109.35	145.35	172.35	
	Sample Correction Volume	ml	373.41	380.32	327.36	
	Sample sent to lab	ml	482.95	525.93	500.02	
	Sample received by lab	ml	472.00	554.00	500.00	
	Diff		-2.3%	5.3%	0.0%	
Silica Gel Impinger						
	Final weight	g	546.00	553.00	882.00	
	Initial weight	g	520.00	520.00	843.00	
	Gain	g	26.00	33.00	39.00	
Total Moisture Gain						
	Condensate + Silica Gel gain	g	135.35	178.35	211.35	
Vlc						
	Net Moisture Gain	ml	135.60	178.68	211.74	
General Remarks						
	Sample Appearance		clr	clr	clr	
	Container Marked		yes	yes	yes	
Filter ID & Remarks						
	Front		15-8-756	15-8-714	15-8-713	
	Appearance		green	green	green	



MONTROSE
AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505
www.montrose-env.com

ODEQ⁵⁶

Sample Recovery Worksheet

Client: Bullseye Date: 4/26-4/27/16
Facility Location: Portland, OR Source: Glass Furnace T7
Operator: JF JH Sample Location: Inlet

Balance Calibration (1000, 500, 200 g)
Need one per each 3-run test

Tolerance must be within $\pm 1.0\%$
998 1 499 1 200

IMPINGER CONTENTS

Container, condensate & rinse, grams
Container & condensate, grams
Empty container, grams
Initial volume, ml
Initial contents
Initial concentration
Net water gain, ml
Condensate appearance
Level marked on container
pH of condensate
Rinsed with
Solvent Name and Lot No.
Solvent Name and Lot No.

	<u>31</u> RUN 1	<u>31</u> RUN 2	RUN 3
Container, condensate & rinse, grams	<u>677.2/362</u>	<u>622/458</u>	
Container & condensate, grams	<u>591/278.1</u>	<u>622/278</u>	<u>651</u>
Empty container, grams	<u>279/278.1</u>	<u>277/278</u>	<u>279/278</u>
Initial volume, ml	<u>200</u>	<u>200</u>	<u>200</u>
Initial contents	<u>DI H₂O</u>	<u>DI H₂O</u>	<u>DI H₂O</u>
Initial concentration	<u>100%</u>	<u>100%</u>	<u>100%</u>
Net water gain, ml			
Condensate appearance	<u>clear</u>	<u>clear</u>	<u>clear</u>
Level marked on container	<u>yes</u>	<u>yes</u>	<u>yes</u>
pH of condensate			
Rinsed with	<u>DI H₂O/Acetone</u> →		
Solvent Name and Lot No.	<u>DI H₂O: 2122</u> →		
Solvent Name and Lot No.	<u>Acetone: 15070138</u>		

SILICA GEL (w/impinger, top off)

Final weight, grams
Initial weight, grams
Net gain, grams

Final weight, grams	<u>546</u>	<u>553</u>	<u>882</u>
Initial weight, grams	<u>520</u>	<u>520</u>	<u>520 843</u>
Net gain, grams			

TOTAL MOISTURE GAIN

Impingers and silica gel, grams

Impingers and silica gel, grams			
---------------------------------	--	--	--

FILTERS

Front filter number
Front filter appearance
Back filter number

Front filter number	<u>158756</u>	<u>158714</u>	<u>158713</u>
Front filter appearance	<u>green, moisture spot, what looks like a water drop.</u>	<u>green</u>	<u>green</u>
Back filter number		<u>NA</u>	<u>NA</u>

Sample Recovery / Moisture Catch

BULLSEYE
GLASS FURNACE T7-OUTLET
PORTLAND OR

26-Apr-16
PT,BS,JH,MV,JF

Definitions	Symbol	Units	Run 1	Run 2	Run 3	mew
Impinger Contents						
	Impinger, Contents, Condensate & Rinse	g	1167.00	1205.20	1153.99	
	Impinger, Contents & Condensate	g	1024.00	1040.00	1032.30	
	spg (g/ml) Impinger	g	557.00	557.00	555.00	
	0.99823 H2O	ml	200.00	200.00	200.00	
	Condensate	g	267.35	283.35	277.65	
	Sample Correction Volume	ml	343.25	365.49	321.90	
	Sample sent to lab	ml	611.08	649.35	600.05	
	Sample received by lab	ml	619.00	670.00	600.00	
	Diff		1.3%	3.2%	0.0%	
Silica Gel Impinger						
	Final weight	g	870.00	570.00	565.00	
	Initial weight	g	832.00	520.00	520.00	
	Gain	g	38.00	50.00	45.00	
Total Moisture Gain						
	Condensate + Silica Gel gain	g	305.35	333.35	322.65	
Vlc						
	Net Moisture Gain	ml	305.90	333.96	323.24	
Filter ID & Remarks						
	Front Appearance		15-8-758 white	15-8-757 white	15-8-764 white	



MONTROSE

AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505
www.montrose-env.com

ODREQ 58

Sample Recovery Worksheet

Client: Bullseye Date: 4/26-4/27/16
 Facility Location: Portland, OR Source: Glass Furnace T7
 Operator: JF JH Sample Location: Outlet

Balance Calibration (1000, 500, 200 g)
Need one per each 3-run test

Tolerance must be within $\pm 1.0\%$
998 1 499 1 200

IMPINGER CONTENTS

Container, condensate & rinse, grams
 Container & condensate, grams
 Empty container, grams
 Initial volume, ml
 Initial contents
 Initial concentration
 Net water gain, ml
 Condensate appearance
 Level marked on container
 pH of condensate
 Rinsed with
 Solvent Name and Lot No.
 Solvent Name and Lot No.

	RUN 1	RUN 2	RUN 3
Container, condensate & rinse, grams	<u>645/522</u>	<u>628/522.2</u>	<u>600.3/432</u>
Container & condensate, grams	<u>629/395</u>	<u>625/395.4</u>	<u>600.3/432</u>
Empty container, grams	<u>279/278</u>	<u>279/278</u>	<u>277/278</u>
Initial volume, ml	<u>200</u>	<u>200</u>	<u>200</u>
Initial contents	<u>DI H₂O</u>	<u>DI H₂O</u>	<u>DI H₂O</u>
Initial concentration	<u>100%</u>	<u>100%</u>	<u>100%</u>
Net water gain, ml			
Condensate appearance			
Level marked on container			
pH of condensate			
Rinsed with	<u>DI H₂O / Acetone</u> →		
Solvent Name and Lot No.	<u>DI H₂O: 4122</u>		
Solvent Name and Lot No.	<u>Acetone:</u>		

SILICA GEL (w/impinger, top off)

Final weight, grams
 Initial weight, grams
 Net gain, grams

Final weight, grams	<u>JF 427 6 870</u>	<u>570</u>	<u>565</u>
Initial weight, grams	<u>520 832</u>	<u>520</u>	<u>520</u>
Net gain, grams			

TOTAL MOISTURE GAIN

Impingers and silica gel, grams

Impingers and silica gel, grams			
---------------------------------	--	--	--

FILTERS

Front filter number
 Front filter appearance
 Back filter number

Front filter number	<u>158756</u>	<u>158757</u>	<u>15-8-764</u>
Front filter appearance	<u>white</u>	<u>white</u>	<u>* White</u>
Back filter number			

* Filter blown

through 1259
 HORIZON ENGINEERING 16-5702A 50
 1258

Blank Correction

BULLSEYE
GLASS FURNACE T7-INLET
PORTLAND OR

26-Apr-16
SH,JL,JF,BC,JM,CH,JH

mew

BLANKS				Run 1	Run 2	Run 3
Acetone	120 ml		0.0000 gm			0.00 mg/100ml
Acetone	Acceptable Limit					0.80 mg/100ml
	Applicable Correction					0.00 mg/100ml
H2O, Residue	100 ml		0.0000 gm			0.00
H2O, DCM	100 ml		0.0000 gm			0.00
H2O, Combined	100 ml		0.0000 gm			0.00
H2O, Combined	Acceptable Limit					1.00
H2O, Residue	Applicable Correction					0.00
H2O, DCM	Applicable Correction					0.00
Filter-Front	15-8-765 ID		0.0002 gm			
RUNS				Run 1	Run 2	Run 3
ACETONE-Front	Volume	ml	96	46	116	
	Weight	mg	8.7	10.3	10.7	
	Blank	mg/100ml	0.00	0.00	0.00	
	Correction	mg	0.00	0.00	0.00	
	Net	mg	8.70	10.30	10.70	
ACETONE-Back	Volume	ml	132	154	100	
	Weight	mg	2.8	1.9	2.6	
	Blank	mg/100ml	0.00	0.00	0.00	
	Correction	mg	0.00	0.00	0.00	
	Net	mg	2.80	1.90	2.60	
IMP WATER-Residue	Volume	ml	373.4	380.3	327.4	
	Weight	mg	4.2	3.6	5.7	
	Blank	mg/100ml	0.00	0.00	0.00	
	Correction	mg	0.00	0.00	0.00	
	Net	mg	4.20	3.60	5.70	
IMP WATER-Extract (DCM)	Volume	ml	373.4	380.3	327.4	
	Weight	mg	0.1	0.2	0.0	
	Blank	mg/100ml	0.00	0.00	0.00	
	Correction	mg	0.00	0.00	0.00	
	Net	mg	0.10	0.20	0.00	
FILTER-Front	ID		15-8-756	15-8-714	15-8-713	
	Weight	mg	1183.4	1278.6	1357.9	
FRONT HALF TOTAL		mg	1192.10	1288.90	1368.60	
BACK HALF TOTAL		mg	7.10	5.70	8.30	
TOTAL		mn mg	1199.20	1294.60	1376.90	
PERCENT BACK HALF		%	0.6%	0.4%	0.6%	

Blank Correction

BULLSEYE
GLASS FURNACE T7-OUTLET
PORTLAND OR

26-Apr-16
PT,BS,JH,MV,JF

mew

BLANKS				Run 1	Run 2	Run 3
Acetone	120 ml		0.0000 gm			0.00 mg/100ml
Acetone	Acceptable Limit					0.80 mg/100ml
	Applicable Correction					0.00 mg/100ml
H2O, Residue	100 ml		0.0000 gm			0.00
H2O, DCM	100 ml		0.0000 gm			0.00
H2O, Combined	100 ml		0.0000 gm			0.00
H2O, Combined	Acceptable Limit					1.00
H2O, Residue	Applicable Correction					0.00
H2O, DCM	Applicable Correction					0.00
Filter-Front	15-8-765 ID		0.0002 gm			
RUNS				Run 1	Run 2	Run 3
ACETONE-Front	Volume ml		76	54	62	
	Weight mg		1.2	0.3	1.4	
	Blank mg/100ml		0.00	0.00	0.00	
	Correction mg		0.00	0.00	0.00	
	Net mg		1.20	0.30	1.40	
ACETONE-Back	Volume ml		108	155	22	
	Weight mg		1.7	2.0	0.0	
	Blank mg/100ml		0.00	0.00	0.00	
	Correction mg		0.00	0.00	0.00	
	Net mg		1.70	2.00	0.00	
IMP WATER-Residue	Volume ml		343.3	365.5	321.9	
	Weight mg		10.0	5.9	4.3	
	Blank mg/100ml		0.00	0.00	0.00	
	Correction mg		0.00	0.00	0.00	
	Net mg		10.00	5.90	4.30	
IMP WATER-Extract (DCM)	Volume ml		343.3	365.5	321.9	
	Weight mg		0.0	0.1	0.3	
	Blank mg/100ml		0.00	0.00	0.00	
	Correction mg		0.00	0.00	0.00	
	Net mg		0.00	0.10	0.30	
FILTER-Front	ID		15-8-758	15-8-757	15-8-764	
	Weight mg		0.3	0.0	2.5	
FRONT HALF TOTAL	mg		1.50	0.30	3.90	
BACK HALF TOTAL	mg		11.70	8.00	4.60	
TOTAL	mn mg		13.20	8.30	8.50	
PERCENT BACK HALF	%		88.6%	96.4%	54.1%	

ANTECH

Analysis/Technology

Mr. David Bagwell
 MONTROSE ENVIRONMENTAL
 13585 NE Whitaker
 Portland OR 97230

page 1 of 2

May 13, 2016 Identification : Bullseye Glass #5702
Job# 1612400-06 Received: 5/3/16
Method: ODEQ 5

<u>Sample #</u>	12400	12401	12402	12403	12404	12405
<u>Identification</u>	GFT7 In Run 1	GFT7 In Run 2	GFT7 In Run 3	GFT7 Out Run 1	GFT7 Out Run 2	GFT7Out Run 3
<u>Front Water:</u>						
<u>Volume (mls)</u>	96	46	116	76	54	62
<u>Residue (g)</u>	0.0087	0.0103	0.0107	0.0012	0.0003	0.0014
<u>Back Acetone</u>						
<u>Volume (mls)</u>	132	154	100	108	155	22
<u>Residue (g)</u>	0.0028	0.0019	0.0026	0.0017	0.0020	0.0000
<u>Impinger water:</u>						
<u>Volume (mls)</u>	472	554	500	619	670	600
<u>Residue (g)</u>	0.0042	0.0036	0.0057	0.0100	0.0059	0.0043
<u>Dichloromethane:</u>						
<u>Volume (mls)</u>	150	150	150	150	150	150
<u>Residue (g)</u>	0.0001	0.0002	-0.0004	-0.0001	0.0001	0.0003
<u>Filters:</u>						
<u>Number:</u>	15-8-756	15-8-714	15-8-713	15-8-75 ^{ME617} 88	15-8-757	15-8-764
<u>Residue(g):</u>	1.1834	1.2786	1.3579	0.0003	-0.0002	0.0025

Respectfully submitted:
 ANTECH

Diana Tracy
 Diana Tracy, president

ANTECH

Analysis/Technology

MONTROSE ENVIRONMENTAL
13585 NE Whitaker
Portland OR 97230

page 2 of 2

May 13, 2016
Job# 1612400-06
Method: ODEQ 5

Identification: Bullseye Glass #5702
Received: 5/3/16

Sample # 12406
Identification Blanks


Acetone:
Volume (mls): 120
Residue (g): -0.0001

Water:
Volume (mls): 100
Residue (g): -0.0001

DCM:
Volume (mls): 150
Residue (g): -0.0001

Filters:
Number: 15-8-765
Residue: 0.0002

Respectfully submitted:
ANTECH


Diana Tracy
president

501 N.E. THOMPSON MILL ROAD
CORBETT, OREGON 97019
503/695-2135
FAX: 503/695-2139
E-mail: antech@cascadeaccess.com

HORIZON ENGINEERING 16-5702

ANTECH

SAMPLE DATA: EPA RESIDUES

Analyst: h2 reviewer: _____
Job# 1612400-06 Identification: Bullseye Glass

Montrose
5702

FRONT ACETONE:

Sample #	Sample ID	vol mark	Date/time	Into dessicator	Vol(mls)	date/time weighed	GWt1(g)	GWt2(g)	GWt3(g)	GWt4(g)	GWt5(g)	GWt6(g)	Average	*Tare (g)	Net (g)
12403	GFT70R1	✓	5-4 11A		76	5-5 10A	127.7761	127.7753	127.7758				127.7756	127.7744	0.0012
12404	GFT70R2	✓	5-4 11A		54	5-5 10A	105.1312	105.1303	105.1308				105.1306	105.1303	0.0003
12405	GFT70R3	none	5-4 11A		62	5-5 10A	107.0150	107.0142	107.0147				107.0145	107.0131	0.0014

BACK ACETONE:

Sample #	Sample ID	vol mark	Date/time	Into dessicator	Vol(mls)	date/time weighed	GWt1(g)	GWt2(g)	GWt3(g)	GWt4(g)	GWt5(g)	GWt6(g)	Average	*Tare (g)	Net (g)
12403	GFT70R1	✓	5-5 7A		108	5-5 10A	111.5457	111.5448	111.5462	111.5459			111.5461	111.5444	0.0017
12404	GFT70R2	✓	5-5 7A		155	5-5 10A	104.0353	104.0344	104.0354	104.0358			104.0356	104.0336	0.0020
12405	GFT70R3	none	5-4 11A		22	5-5 10A	109.7738	109.7727	109.7732				109.7730	109.7730	0.0000

COPY

ANTECH ID 1612400-06
SAMPLE DATA: EPA RESIDUE

IMPINGER WATER:

Sample #	Sample ID	vol mark	Date/time	Into dessicator	Vol(mls)	date/time Weighed	GWt1(g)	GWt2(g)	GWt3(g)	GWt4(g)	GWt5(g)	GWt6(g)	Average	*Tare (g)	Net (g)
12403	GFT70R1	✓	5-5 7A		619	5-5 10A	164.4956	164.4945	164.4950				164.4948	5-3 1P	0.0100
12404	GFT70R2	✓	5-5 7A		670	5-5 10A	170.0870	170.0862	170.0865				170.0864	5-3 1P	0.0059
12405	GFT70R3	✓	5-5 7A		600	5-5 10A	142.7271	142.7262	142.7266				142.7264	5-3 1P	0.0043

DICHLOROMETHANE:

Sample #	Sample ID	vol mark	Date/time	Into dessicator	Vol(mls)	date/time Weighed	GWt1(g)	GWt2(g)	GWt3(g)	GWt4(g)	GWt5(g)	GWt6(g)	Average	*Tare (g)	Net (g)
12403			5-5 7A		(150)	5-5 10A	98.9021	98.9019					98.9020	5-3 1P	-0.0001
12404			5-5 7A		(150)	5-5 10A	120.9662	120.9663					120.9663	5-3 1P	0.0001
12405			5-5 7A		(150)	5-5 10A	100.5051	100.5052					100.5052	5-3 1P	0.0003

COPY

Monroe
5702

ANTECH

ID 1612400-06

SAMPLE DATA: EPA RESIDUES

FILTERS:

Sample # 12400
Sample ID GFT7LR1
Filter # 15-8-756
Date/time 5-3 11A
In dessicator

12401
GFT7LR2
15-8-714
5-3 11A

12402
GFT7LR3
15-8-713
5-3 11A

	Date/time		Date/time		Date/time
GWt1(g)	1.4770	5-5 10A	1.6312	5-5 10A	1.6171
GWt2(g)	1.4790	5-6 7A	1.6319	5-6 7A	1.6253
GWt3(g)	1.0368	5-8 9A			1.7134
GWt4(g)	1.5355	5-9 7A			1.7139
Average	1.5362		1.6316		1.7137
Tare (g)	.3528	12-4-15	.3530	12-4-15	.3558
Net (g)	1.1834		1.2786		1.3579

FILTERS:

Sample # 12403
Sample ID GFT7OR1
Filter # 15-8-758
Date/time 5-3 11A
In dessicator

12404
GFT7OR2
15-8-757
5-3 11A

12405
GFT7OR3
15-8-764
5-3 11A

	Date/time		Date/time		Date/time
GWt1(g)	.3563	5-5 10A	.3565	5-5 10A	.3574
GWt2(g)	.3562	5-6 7A	.3565	5-6 7A	.3554
GWt3(g)					.3564
GWt4(g)					.3566
Average	.3563		.3565		.3565
Tare (g)	.3560	12-4-15	.3567	12-4-15	.3540
Net (g)	0.0003		-0.0002		0.0025

COPY

ANTECH

SAMPLE DATA: EPA RESIDUES

Analyst: [Signature] reviewer: [Signature]
Job# 1612400-06 Identification: Bullseye Glass Montrose 5702

HOUSE BLANKS:

ACETONE:

Sample # 124
Sample ID lab blank
vol mark _____
Date/time 5-4 11A 16B442
Into dessicator _____
Vol(mls) (100) date/time weighed _____
GWt1(g) 104.2690 5-5 10A
GWt2(g) 104.2693 5-6 7A
GWt3(g) _____
GWt4(g) _____
GWt5(g) _____
GWt6(g) _____
Average 104.2692 _____

IMPINGER WATER:

Sample # 124
Sample ID lab blank
vol mark _____
Date/time 5-4 11A 16B443
Into dessicator _____
Vol(mls) (100) date/time weighed _____
GWt1(g) 162.0684 5-5 10A
GWt2(g) 162.0684 5-6 7A
GWt3(g) _____
GWt4(g) _____
GWt5(g) _____
GWt6(g) _____
Average 162.0684 _____

DCM:

Sample # 124 lab blank
Sample ID _____
vol mark _____
Date/time 5-4 11A 16B444
Into dessicator _____
Vol(mls) (150) date/time weighed _____
GWt1(g) 118.7342 5-5 10A
GWt2(g) 118.7339 5-6 7A
GWt3(g) _____
GWt4(g) _____
GWt5(g) _____
GWt6(g) _____
Average 118.7341 _____

*Tare (g) 104.2690 5-3 1P

162.0685 5-3 1P

118.7341 5-3 1P

Net (g) 0.0002

-0.0001

0.0000

COPY

FILTER:

Sample # _____
Sample ID _____
Filter # _____
Date/time _____
Into dessicator _____
Vol(mls) _____ date/time weighed _____
GWt1(g) _____
GWt2(g) _____
GWt3(g) _____
GWt4(g) _____
GWt5(g) _____
GWt6(g) _____
Average _____
*Tare (g) _____
Net (g) _____

FILTER:

Sample # _____
Sample ID _____
Filter # _____
Date/time _____
Into dessicator _____
Vol(mls) _____ date/time weighed _____
GWt1(g) _____
GWt2(g) _____
GWt3(g) _____
GWt4(g) _____
GWt5(g) _____
GWt6(g) _____
Average _____
*Tare (g) _____
Net (g) _____

EMPTY:

Sample # 124
Sample ID lab blank
Filter # _____
Date/time 5-4 11A
Into dessicator _____
Vol(mls) empty date/time weighed _____
GWt1(g) 105.3494 5-5 9A
GWt2(g) 105.3493 5-6 7A
GWt3(g) 105.3498 5-8 8A
GWt4(g) 105.3495 5-9 7A
GWt5(g) _____
GWt6(g) _____
Average 105.3497 _____
*Tare (g) 105.3496 5-3 1P
Net (g) 0.0001

ANTECH
SAMPLE DATA:

RESIDUES

Analyst: W
Job# 1612400-06

reviewer: _____
Identification: Bullseye Glass

montrose
5702

QC DATA:

	5-3	5-5	5-6	5-8	5-9
Date/time	<u>5-3</u>	<u>5-5</u>	<u>5-6</u>	<u>5-8</u>	<u>5-9</u>
Balance calibrated	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
(NTIS cert wts)	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Date/time	<u>1P</u>	<u>8A</u>	<u>7A</u>	<u>7A</u>	<u>7A</u>
Temp/temp	<u>70</u>	<u>70</u>	<u>68</u>	<u>70</u>	<u>68</u>
Relative humidity (%)	<u>32</u>	<u>32</u>	<u>31</u>	<u>34</u>	<u>32</u>

Date/time	_____	_____	_____	_____	_____
Balance calibrated	_____	_____	_____	_____	_____
(NTIS cert wts)	_____	_____	_____	_____	_____
Date/time	_____	_____	_____	_____	_____
Temp/temp	_____	_____	_____	_____	_____
Relative humidity (%)	_____	_____	_____	_____	_____

Reagent Tracking:

Reagent:	Brand:	Lot #	Expiration Date:
<u>DCM</u>	<u>CP</u>	<u>DN388</u>	_____
<u>acetone</u>	<u>CP</u>	<u>DPO50</u>	_____
<u>DI H₂O</u>	<u>Picca</u>	<u>1501A48</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____

COPY

balance # 50505744

ANALYTICAL BALANCE CALIBRATION FORM

1612400-06

Page 9 of 12

Balance name Sartorius

Number 50505744

Classification of standard weights

Date	0.500 g	1.0000 g	10.0000 g	50.0000 g	100.0000 g	Analyst
3-18-16	0.0999	1.0001g			100.0000	W
3-20-16	0.1000g	1.0001g			100.0000g	W
3-21-16	0.1000g	1.0001g			100.0001g	W
3-22-16	0.1000g	1.0001g			100.0001g	W
3-23-16	0.1000g	1.0000g			100.0000g	W
3-24-16	0.0999g	1.0001g			100.0000g	W
3-27-16	0.1000g	1.0000g			100.0000g	W
3-28-16	0.1000g	1.0000g			100.0000g	W
4-1-16	0.1000g	1.0001g			100.0000g	W
4-3-16	0.1000g	1.0001g			100.0000g	W
4-4-16	0.1001g	1.0000g			100.0001g	W
4-7-16	0.1000g	1.0001g			100.0000g	W
4-8-16	0.1000g	1.0001g			100.0001g	W
4-11-16	0.1001g	1.0001g			100.0001g	W
4-12-16	0.1001g	1.0001g			100.0000g	W
4-13-16	0.1000g	1.0001g			100.0000g	W
4-14-16	0.1001g	1.0001g			100.0001g	W
4-15-16	0.1000g	1.0001g			100.0001g	W
4-16-16	0.1000g	1.0000g			100.0000g	W
4-25-16	0.1000g	1.0001g			100.0000g	W
4-26-16	0.0999g	1.0000g			100.0000g	W
4-27-16	0.1000g	1.0001g			100.0000g	W
4-28-16	0.1000g	1.0001g			100.0000g	W
4-29-16	0.1000g	1.0001g			100.0000g	W
5-1-16	0.1001g	1.0000g			100.0001g	W
5-2-16	0.1000g	1.0000g			100.0001g	W
5-3-16	0.1000g	1.0000g			100.0001g	W
5-4-16	0.0999g	1.0000g			100.0001g	W
5-5-16	0.1000g	1.0000g			100.0000g	W
5-6-16	0.1000g	1.0001g			100.0001g	W
5-8-16	0.1001g	1.0001g			100.0000g	W
5-9-16	0.1000g	1.0001g			100.0000g	W

calibrated

COPY

COPY

		RH 23	RH 25	RH 30	Ave
		11-30	12-3	12-4	
<u>UG</u>					
1090	15-8-701	.3533	.3533	.3534	.3533
1095	702	.3558	.3558	.3558	.3558
1083	703	.3519	.3520	.3521	.3520
1104	704	.3558	.3558	.3558	.3558
	705	.3539	.3539	.3540	.3539
<u>Ave</u>					
.3515	15-8-706	.3532	.3533	.3533	.3533
.3569	707	.3596	.3595	.3596	.3596
.3534	708	.3558	.3557	.3558	.3558
.3557	709	.3581	.3582	.3581	.3581
.3598	710	.3565	.3565	.3566	.3565
.3570	15-8-711	.3558	.3560	.3559	.3559
.3578	712	.3568	.3568	.3568	.3568
.3563	713	.3558	.3558	.3558	.3558
.3537	714	.3530	.3530	.3531	.3530
.3546	715	.3522	.3521	.3522	.3522
.3547	15-8-716	.3534	.3534	.3534	.3534
.3527	717	.3541	.3542	.3542	.3542
.3541	718	.3513	.3514	.3515	.3514
.3533	719	.3526	.3526	.3527	.3526
.3530	720	.3529	.3529	.3529	.3529
.3525	15-8-721	.3525	.3525	.3525	.3525
.3539	722	.3542	.3543	.3543	.3543
.3517	723	.3520	.3520	.3519	.3520
.3512	724	.3539	.3539	.3537	.3539
.3541	725	.3560	.3560	.3560	.3560
.3525					

COPY

AVE	RH 23		RH 25		RH 30	
	4-30	12-3	12-4	AVE		
.3525	15-8-751 .3515	.3516	.3517	.3516		
.3540	752 .3528	.3528	.3528	.3528		
.3534	753 .3539	.3539	.3540	.3539		
.3530	754 .3525	.3525	.3525	.3525		
.3580	755 .3558	.3559	.3559	.3559		
.3545	15-8-756 .3528	.3529	.3528	.3528		
.3580	757 .3567	.3567	.3567	.3567		
.3564	758 .3560	.3561	.3560	.3560		
.3556	759 .3573	.3573	.3578	.3573		
.3583	760 .3577	.3578	.3578	.3578		
.3575	15-8-761 .3582	.3582	.3582	.3582		
.3548	762 .3569	.3570	.3570	.3570		
.3558	763 .3560	.3560	.3561	.3560		
.3526	764 .3539	.3541	.3541	.3540		
.3509	765 .3529	.3529	.3530	.3529		
.3515	15-8-766 .3540	.3541	.3542	.3541		
.3512	767 .3527	.3527	.3527	.3527		
.3525	768 .3528	.3528	.3528	.3528		
.3506	769 .3517	.3518	.3518	.3518		
.3506	770 .3506	.3506	.3506	.3506		
.3543	15-8-771 .3539	.3539	.3539	.3539		
.3551	772 .3558	.3559	.3559	.3558		
.3542	773 .3562	.3563	.3563	.3563		
.3541	774 .3555	.3555	.3555	.3555		
.3491	775 .3515	.3516	.3516	.3516		

COPY

4-25
RH30

16B 401 123.6717
 402 105.5274
 403 109.9200
 404 120.4775
 405 107.3002

16B 426 109.7730
 427 141.5820
 428 125.5117
 429 159.9157
 430 144.4848

4-29
RH33

16B 406 103.9335
 407 97.2730
 408 103.6724
 409 116.7660
 410 103.9369

16B 431 170.0805
 432 143.7221
 433 88.9212
 434 99.3000
 435 88.8498

6-3
RH32

16B 411 87.1556
 412 105.6080
 413 111.5222
 414 103.3506
 415 124.8392

16B 436 98.9021
 437 120.9662
 438 100.5049
 439 117.6592
 440 132.3452

16B 416 109.9086
 417 115.5414
 418 127.7744
 419 105.1303
 420 107.0131

16B 441 118.9348
 442 104.2690
 443 162.0685
 444 118.7341
 445 105.3496

16B 421 114.4252
 422 107.1594
 423 116.4975
 424 111.5444
 425 104.0336

5-4
RH34

16B 446 113.1254
 447 67.7602
 448 72.7309
 449 66.0372
 450 65.5801



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
 2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
 (503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Antech Lab
 501 N.E. Thompson Mill Rd.
 Corbett, OR 97019

Report Number: ANTL0150505744160322

A2LA ACCREDITED
CERTIFICATE OF CALIBRATION WITH DATA

COPY

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location
Balance	Sartorius	BP210S	50505744	N/A	Lab
Units	Readability	SOP	Cal Date	Last Cal Date	Cal Due Date
g	0.0001	QC012	3/22/16	3/24/15	3/2017

FUNCTIONAL CHECKS

ECCENTRICITY		LINEARITY		STANDARD DEVIATION			ENVIRONMENTAL CONDITIONS
Test Wt:	Tol:	Test Wt:	Tol:	Test Wt:	Tol:		
100	0.0003	50x4	0.0002	100	0.0001		<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>
As-Found:		As-Found:		1.100.0003	5.100.0004	9.100.0003	Good Fair Poor
Pass: <input checked="" type="checkbox"/>	Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/>	Fail: <input type="checkbox"/>	2.100.0005	6.100.0002	10.100.0002	
As-Left:		As-Left:		3.100.0004	7.100.0003	Result	Temperature: 21.1°C
Pass: <input checked="" type="checkbox"/>	Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/>	Fail: <input type="checkbox"/>	4.100.0003	8.100.0002	0.00009	

A2LA ACCREDITED SECTION OF REPORT

Standard	As-Found	As-Left	Expanded Uncertainty
200	200.0009	200.0006	0.00023
100	100.0006	100.0003	0.00023
50	50.0003	50.0002	0.00023
10	10.0002	10.0000	0.00022
1	1.0000	1.0000	0.00022
0.1	0.1000	0.1000	0.00022

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Cal Date	Cal Due Date	NIST ID
Weight Set	Rice Lake	20 kg to 1mg	2831W	12/8/15	12/2016	20152429

Permanent Information Concerning this Equipment:
 Unit needs software repair for linearity and repeatability.

Comments/Info Concerning this Calibration:

Report prepared/reviewed by: J. Colacchio Date: 3/22/16

Technician: J. Colacchio
 Signature:

THIS CERTIFICATE SHALL NOT BE REPRODUCED WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation and readability of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy. Calibrations comply with ISO/IEC 17025 and ANSI/Z540-1-1994 quality standards.

Particulate Matter Chain of Custody

1612400-04



Page: 1 of 1

Client: Bullseye Glass
 Laboratory: Antech
 501 N.E. Thompson Mill Road
 Corbett, Oregon 97019

Montrose Job No. 5702
~~5702~~
 Antech Job No. _____

Field Personnel JF/JH/CN
 Office Personnel _____

METHOD: specify>>			Front <u>Acetone</u> Rinse	Back <u>Acetone</u> Rinse	Impinger H2O	Filter - Front	CPM Cont. 1 EPA 202	CPM Cont. 2 EPA 202	CPM Cont. 3 EPA 202
Source	Run #	Test Date							
T7 Inlet	1	4/27	1	1	2	1	—	—	—
"	2	4/28	"	"	"	"			
"	3	4/29	"	"	"	"			
T7 Outlet	1	4/27	"	"	"	"			
"	2	4/28	"	"	"	"			
"	3	4/29	"	"	"	"			
Blanks		4/28	1	—	1	1			
Field Train Recovery									
Field Train Proof									

Return Samples to Montrose ASAP for Further Analysis? _____ RUSH Normal _____

Notes: 33 total samples. Please Rush!

Relinquished by: [Signature] Date/Time 5/2/16 1123

Relinquished by: _____ Date/Time _____

Received by: [Signature] Date/Time 5/3 9:30

Received by: _____ Date/Time _____

HORIZON ENGINEERING 1665702

Bill To: Horizon Engineering, LLC
 13585 NE Whitaker Way
 Portland, OR 97230

AmTest Air Quality
 4150 'B' Place NW, Suite 106
 Auburn, WA 98001
 Phone: 253.480.3800

The Avogadro Group
 2825 Verne Roberts Circle
 Antioch, CA 94509

The Avogadro Group
 13585 NE Whitaker Way
 Portland, OR 97230

Montrose Air Quality Services
 11327 E. Montgomery Bay #1
 Spokane Valley, WA 99206

Montrose Air Quality Services
 2285 Deerfield Lane
 Helena, MT 89601

Other _____

LABORATORY REPORT

May 18, 2016

Jason French
Horizon Engineering, LLC
4150 'B' Place Northwest, Suite 106
Auburn, WA 98001

RE: Bullseye Glass / 5702

Dear Jason:

Enclosed are the results of the samples submitted to our laboratory on May 4, 2016. For your reference, these analyses have been assigned our service request number P1602318.

All analyses were performed according to our laboratory's NELAP and DoD-ELAP-approved quality assurance program. The test results meet requirements of the current NELAP and DoD-ELAP standards, where applicable, and except as noted in the laboratory case narrative provided. For a specific list of NELAP and DoD-ELAP-accredited analytes, refer to the certifications section at www.alsglobal.com. Results are intended to be considered in their entirety and apply only to the samples analyzed and reported herein.

If you have any questions, please call me at (805) 526-7161.

Respectfully submitted,

ALS | Environmental



By Kate Aguilera at 10:31 am, May 18, 2016

Kate Aguilera
Project Manager

Client: Horizon Engineering, LLC
Project: Bullseye Glass / 5702

Service Request No: P1602318

CASE NARRATIVE

The samples were received intact under chain of custody on May 4, 2016 and were stored in accordance with the analytical method requirements. The samples were received past the recommended holding time for all of the analyses. The analyses were performed as soon as possible after receipt by the laboratory. The data is flagged to indicate the holding time exceedance. Please refer to the sample acceptance check form for additional information. The results reported herein are applicable only to the condition of the samples at the time of sample receipt.

Ethane and Propane Analysis

The samples were analyzed per modified EPA Method TO-3 for ethane and propane using a gas chromatograph equipped with a flame ionization detector (FID). This procedure is described in laboratory SOP VOA-TO3C1C6. This method is included on the laboratory's DoD-ELAP scope of accreditation, however it is not part of the NELAP or AIHA-LAP accreditation.

Fixed Gases Analysis

The samples were also analyzed for fixed gases (oxygen, nitrogen, carbon monoxide, methane and carbon dioxide) according to modified EPA Method 3C (single injection) using a gas chromatograph equipped with a thermal conductivity detector (TCD). This procedure is described in laboratory SOP VOA-EPA3C. This method is included on the laboratory's DoD-ELAP scope of accreditation, however it is not part of the NELAP or AIHA-LAP accreditation.

The results of analyses are given in the attached laboratory report. All results are intended to be considered in their entirety, and ALS Environmental (ALS) is not responsible for utilization of less than the complete report.

Use of ALS Environmental (ALS)'s Name. Client shall not use ALS's name or trademark in any marketing or reporting materials, press releases or in any other manner ("Materials") whatsoever and shall not attribute to ALS any test result, tolerance or specification derived from ALS's data ("Attribution") without ALS's prior written consent, which may be withheld by ALS for any reason in its sole discretion. To request ALS's consent, Client shall provide copies of the proposed Materials or Attribution and describe in writing Client's proposed use of such Materials or Attribution. If ALS has not provided written approval of the Materials or Attribution within ten (10) days of receipt from Client, Client's request to use ALS's name or trademark in any Materials or Attribution shall be deemed denied. ALS may, in its discretion, reasonably charge Client for its time in reviewing Materials or Attribution requests. Client acknowledges and agrees that the unauthorized use of ALS's name or trademark may cause ALS to incur irreparable harm for which the recovery of money damages will be inadequate. Accordingly, Client acknowledges and agrees that a violation shall justify preliminary injunctive relief. For questions contact the laboratory.

ALS Environmental - Simi Valley
CERTIFICATIONS, ACCREDITATIONS, AND REGISTRATIONS

Agency	Web Site	Number
AIHA	http://www.aihaaccreditedlabs.org	101661
Arizona DHS	http://www.azdhs.gov/lab/license/env.htm	AZ0694
DoD ELAP	http://www.pjlab.com/search-accredited-labs	L15-398
Florida DOH (NELAP)	http://www.doh.state.fl.us/lab/EnvLabCert/WaterCert.htm	E871020
Maine DHHS	http://www.maine.gov/dhhs/mecdc/environmental-health/water/dwp-services/labcert/labcert.htm	2014025
Minnesota DOH (NELAP)	http://www.health.state.mn.us/accreditation	977273
New Jersey DEP (NELAP)	http://www.nj.gov/dep/oqa/	CA009
New York DOH (NELAP)	http://www.wadsworth.org/labcert/elap/elap.html	11221
Oregon PHD (NELAP)	http://public.health.oregon.gov/LaboratoryServices/EnvironmentalLaboratoryAccreditation/Pages/index.aspx	4068-003
Pennsylvania DEP	http://www.depweb.state.pa.us/labs	68-03307 (Registration)
Texas CEQ (NELAP)	http://www.tceq.texas.gov/field/qa/env_lab_accreditation.html	T104704413-15-6
Utah DOH (NELAP)	http://www.health.utah.gov/lab/labimp/certification/index.html	CA01627201 5-5
Washington DOE	http://www.ecy.wa.gov/programs/eap/labs/lab-accreditation.html	C946

Analyses were performed according to our laboratory's NELAP and DoD-ELAP approved quality assurance program. A complete listing of specific NELAP and DoD-ELAP certified analytes can be found in the certifications section at www.alsglobal.com, or at the accreditation body's website.

Each of the certifications listed above have an explicit Scope of Accreditation that applies to specific matrices/methods/analytes; therefore, please contact the laboratory for information corresponding to a particular certification.

ALS ENVIRONMENTAL

DETAIL SUMMARY REPORT

Client: Horizon Engineering, LLC
 Project ID: Bullseye Glass / 5702

Service Request: P1602318

Date Received: 5/4/2016
 Time Received: 09:35

Client Sample ID	Lab Code	Matrix	Date Collected	Time Collected	TO-3 Modified - C1C6+ Bag	
					TO-3 Modified - C1C6+ Bag	3C Modified - Fxd Gases Bag
1-A	P1602318-001	Air	4/27/2016	00:00	X	X
1-B	P1602318-002	Air	4/27/2016	00:00	X	X
1-C	P1602318-003	Air	4/27/2016	00:00	X	X
1-D	P1602318-004	Air	4/27/2016	00:00	X	X
1-E	P1602318-005	Air	4/27/2016	00:00	X	X
1-F	P1602318-006	Air	4/27/2016	00:00	X	X
1-G	P1602318-007	Air	4/27/2016	00:00	X	X
2-A	P1602318-008	Air	4/28/2016	00:00	X	X
2-B	P1602318-009	Air	4/28/2016	00:00	X	X
2-C	P1602318-010	Air	4/28/2016	00:00	X	X
2-D	P1602318-011	Air	4/28/2016	00:00	X	X
2-E	P1602318-012	Air	4/28/2016	00:00	X	X
2-F	P1602318-013	Air	4/28/2016	00:00	X	X
3-A	P1602318-014	Air	4/29/2016	00:00	X	X
3-B	P1602318-015	Air	4/29/2016	00:00	X	X
3-C	P1602318-016	Air	4/29/2016	00:00	X	X
3-D	P1602318-017	Air	4/29/2016	00:00	X	X
3-E	P1602318-018	Air	4/29/2016	00:00	X	X



Air - Chain of Custody Record & Analytical Service Request

2655 Park Center Drive, Suite A
 Simi Valley, California 93065
 Phone (805) 526-7161
 Fax (805) 526-7270

Requested Turnaround Time in Business Days (Surcharges) please circle: 1 Day (100%) 2 Day (75%) 3 Day (50%) 4 Day (35%) 5 Day (25%) 10 Day-Standard

ALS Project No. P1602318

Company Name & Address (Reporting Information) Thomas Rhodes / Horizon Engineering (Same as Billing Address)				Project Name Bullseye Glass				ALS Contact:		Comments e.g. Actual Preservative or specific instructions
				Project Number 5702				Analysis Method		
Project Manager Jason French				P.O. # / Billing Information 13585 NE Whittier Way Portland OR 97230						
Phone 503-255-3050		Fax 503-255-0505		Sampler (Print & Sign) <i>[Signature]</i> Chris Hineson				3C		
Email Address for Result Reporting t.rhodes@montrose-env.com										
Client Sample ID	Laboratory ID Number	Date Collected	Time Collected	Canister ID (Bar code # - AC, SC, etc.)	Flow Controller ID (Bar code # - FC #)	Canister Start Pressure "Hg	Canister End Pressure "Hg/psig	Sample Volume		
1A-G		4/27	Various						All Bags analyzed for N ₂ /O ₂ /CO ₂ /CO/CH ₄ /C ₂ H ₆ /C ₃ H ₈ only	
2A-F		4/28	u							
3A-E		4/29	u							
Report Tier Levels - please select										
Tier I - Results (Default if not specified) _____				Tier III (Results + QC & Calibration Summaries) _____				EDD required: Yes / No		Chain of Custody Seal: (Circle) INTACT BROKEN ABSENT
Tier II (Results + QC Summaries) <input checked="" type="checkbox"/> _____				Tier IV (Data Validation Package) 10% Surcharge _____				Type: _____ Units: _____		
Relinquished by: (Signature) <i>[Signature]</i>				Date: 5/2/16		Time: 1200		Received by: (Signature) <i>[Signature]</i>		Date: 5/4/16
Relinquished by: (Signature) _____				Date: _____		Time: _____		Received by: (Signature) _____		Date: _____ Time: _____
									Cooler / Blank Temperature °C	

HORIZON ENGINEERING 16-5702

**ALS Environmental
Sample Acceptance Check Form**

Client: Horizon Engineering, LLC Work order: P1602318
 Project: Bullseye Glass / 5702
 Sample(s) received on: 5/4/16 Date opened: 5/4/16 by: KKELPE

Note: This form is used for all samples received by ALS. The use of this form for custody seals is strictly meant to indicate presence/absence and not as an indication of compliance or nonconformity. Thermal preservation and pH will only be evaluated either at the request of the client and/or as required by the method/SOP.

- | | Yes | No | N/A |
|---|-------------------------------------|-------------------------------------|-------------------------------------|
| 1 Were sample containers properly marked with client sample ID? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2 Did sample containers arrive in good condition? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3 Were chain-of-custody papers used and filled out? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4 Did sample container labels and/or tags agree with custody papers? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 5 Was sample volume received adequate for analysis? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6 Are samples within specified holding times? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 7 Was proper temperature (thermal preservation) of cooler at receipt adhered to? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 8 Were custody seals on outside of cooler/Box/Container? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Location of seal(s)? _____ Sealing Lid? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Were signature and date included? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Were seals intact? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 9 Do containers have appropriate preservation , according to method/SOP or Client specified information? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Is there a client indication that the submitted samples are pH preserved? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Were VOA vials checked for presence/absence of air bubbles? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Does the client/method/SOP require that the analyst check the sample pH and <u>if necessary</u> alter it? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 10 Tubes: Are the tubes capped and intact? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 11 Badges: Are the badges properly capped and intact? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Are dual bed badges separated and individually capped and intact? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Lab Sample ID	Container Description	Required pH *	Received pH	Adjusted pH	VOA Headspace (Presence/Absence)	Receipt / Preservation Comments
P1602318-001.01	5.0 L Tedlar Bag					
P1602318-002.01	5.0 L Tedlar Bag					
P1602318-003.01	5.0 L Tedlar Bag					
P1602318-004.01	5.0 L Tedlar Bag					
P1602318-005.01	5.0 L Tedlar Bag					
P1602318-006.01	5.0 L Tedlar Bag					
P1602318-007.01	5.0 L Tedlar Bag					
P1602318-008.01	5.0 L Tedlar Bag					
P1602318-009.01	5.0 L Tedlar Bag					
P1602318-010.01	5.0 L Tedlar Bag					
P1602318-011.01	5.0 L Tedlar Bag					
P1602318-012.01	5.0 L Tedlar Bag					
P1602318-013.01	5.0 L Tedlar Bag					
P1602318-014.01	5.0 L Tedlar Bag					
P1602318-015.01	5.0 L Tedlar Bag					

Explain any discrepancies: (include lab sample ID numbers): _____
 Chain of Custody is missing time collected _____

ALL SAM

RSK - MEEPP, HCL (pH<2); RSK - CO2, (pH 5-8); Sulfur (pH>4)

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-A
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-001

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.7	0.10	
7727-37-9	Nitrogen	77.2	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.16	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-B
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-002

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Wade Henton
 Sample Type: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.5	0.10	
7727-37-9	Nitrogen	76.9	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.56	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-003

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.3	0.10	
7727-37-9	Nitrogen	76.7	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	2.01	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-D
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-004

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.4	0.10	
7727-37-9	Nitrogen	76.8	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.81	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-E
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-005

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS#	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.6	0.10	
7727-37-9	Nitrogen	77.3	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.12	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-F
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-006

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.6	0.10	
7727-37-9	Nitrogen	77.3	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.11	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-G
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-007

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS#	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.7	0.10	
7727-37-9	Nitrogen	77.4	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	0.874	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-A
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-008

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Wade Henton
 Sample Type: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.3	0.10	
7727-37-9	Nitrogen	76.5	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbou Dioxide	2.11	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-B
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-009

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GCI/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS#	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.5	0.10	
7727-37-9	Nitrogen	77.0	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.55	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-010

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.4	0.10	
7727-37-9	Nitrogen	76.7	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.80	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-D
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-011

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.6	0.10	
7727-37-9	Nitrogen	77.2	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.23	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-E
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-012

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.6	0.10	
7727-37-9	Nitrogen	77.2	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.18	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-F
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-013

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS#	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.7	0.10	
7727-37-9	Nitrogen	77.4	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	0.900	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-A
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-014

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Wade Henton
 Sample Type: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.4	0.10	
7727-37-9	Nitrogen	76.7	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.88	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-B
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-015

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	22.0	0.10	
7727-37-9	Nitrogen	77.9	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	ND	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-016

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	22.0	0.10	
7727-37-9	Nitrogen	77.7	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	0.331	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-D
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-017

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.4	0.10	
7727-37-9	Nitrogen	77.0	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.50	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-E
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-018

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Wade Henton
 Sample Type: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 0.10 ml(s)

CAS #	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	21.5	0.10	
7727-37-9	Nitrogen	77.1	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	1.35	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Method Blank
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160504-MB

Test Code: EPA Method 3C Modified
Instrument ID: HP5890 II/GC1/TCD
Analyst: Wade Henton
Sample Type: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
Date Received: NA
Date Analyzed: 5/04/16
Volume(s) Analyzed: 0.10 ml(s)

CAS#	Compound	Result %, v/v	MRL %, v/v	Data Qualifier
7782-44-7	Oxygen*	ND	0.10	
7727-37-9	Nitrogen	ND	0.10	
630-08-0	Carbon Monoxide	ND	0.10	
124-38-9	Carbon Dioxide	ND	0.10	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Lab Control Sample
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160504-LCS

Test Code: EPA Method 3C Modified
 Instrument ID: HP5890 II/GC1/TCD
 Analyst: Wade Henton
 Sample Type: 5.0 L Tedlar Bag
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/04/16
 Volume(s) Analyzed: NA ml(s)

CAS #	Compound	Spike Amount ppmV	Result ppmV	% Recovery	ALS	Data Qualifier
					Acceptance Limits	
7782-44-7	Oxygen*	25,000	26,500	106	84-121	
7727-37-9	Nitrogen	50,000	52,200	104	88-122	
630-08-0	Carbon Monoxide	50,000	53,000	106	87-118	
124-38-9	Carbon Dioxide	50,000	51,600	103	84-117	

* = The oxygen result may include argon due to coelution. Ambient air includes 0.93% argon.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-A
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-001

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	3.8	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **1-B**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-002

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: **H3**

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	5.3	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-003

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	5.5	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **1-D**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-004

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: **H3**

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	6.0	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-E
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-005

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/27/16
Date Received: 5/4/16
Date Analyzed: 5/4/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	6.6	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **1-F**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-006

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: **H3**

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/4/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.6	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 1-G
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-007

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/27/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	3.7	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.
 MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.
 H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-A
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-008

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.2	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-B
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-009

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
Date Received: 5/4/16
Date Analyzed: 5/5/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.6	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-010

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	5.7	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-D
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-011

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.7	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 2-E
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-012

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.2	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **2-F**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-013

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: **H3**

Date Collected: 4/28/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.0	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **3-A**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-014

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: **H3**

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.3	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-B
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-015

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	2.7	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-C
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P1602318-016

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
Date Received: 5/4/16
Date Analyzed: 5/5/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	3.0	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: 3-D
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
ALS Sample ID: P1602318-017

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes: H3

Date Collected: 4/29/16
Date Received: 5/4/16
Date Analyzed: 5/5/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	4.0	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: **Horizon Engineering, LLC**
 Client Sample ID: **3-E**
 Client Project ID: **Bullseye Glass / 5702**

ALS Project ID: P1602318
 ALS Sample ID: P1602318-018

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes: H3

Date Collected: 4/29/16
 Date Received: 5/4/16
 Date Analyzed: 5/5/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	3.8	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

H3 = Sample was received and analyzed past holding time.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Method Blank
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160504-MB

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/04/16
 Volume(s) Analyzed: 1.0 ml(s)

Componud	Result ppmV	MRL ppmV	Data Qualifier
Methane	ND	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Method Blank
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
ALS Sample ID: P160505-MB

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
Date Received: NA
Date Analyzed: 5/05/16
Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	ND	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

RESULTS OF ANALYSIS

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Method Blank
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160505-MB

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/05/16
 Volume(s) Analyzed: 1.0 ml(s)

Compound	Result ppmV	MRL ppmV	Data Qualifier
Methane	ND	0.50	
Ethane	ND	0.50	
Propane	ND	0.50	

ND = Compound was analyzed for, but not detected above the laboratory reporting limit.

MRL = Method Reporting Limit - The minimum quantity of a target analyte that can be confidently determined by the referenced method.

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Lab Control Sample
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160504-LCS

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/04/16
 Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount ppmV	Result ppmV	% Recovery	ALS	Data Qualifier
				Acceptance Limits	
Methane	1,020	1,010	99	83-107	
Ethane	1,010	1,040	103	77-111	
Propane	1,010	1,100	109	78-110	

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Lab Control Sample
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160505-LCS

Test Code: EPA TO-3 Modified
Instrument ID: HP5890 II/GC8/FID
Analyst: Adam McAfee
Sampling Media: 5.0 L Tedlar Bag
Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/05/16
 Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount ppmV	Result ppmV	% Recovery	ALS	Data Qualifier
				Acceptance Limits	
Methane	1,020	945	93	83-107	
Ethane	1,010	974	96	77-111	
Propane	1,010	1,020	101	78-110	

ALS ENVIRONMENTAL

LABORATORY CONTROL SAMPLE SUMMARY

Page 1 of 1

Client: Horizon Engineering, LLC
Client Sample ID: Lab Control Sample
Client Project ID: Bullseye Glass / 5702

ALS Project ID: P1602318
 ALS Sample ID: P160505-LCS

Test Code: EPA TO-3 Modified
 Instrument ID: HP5890 II/GC8/FID
 Analyst: Adam McAfee
 Sampling Media: 5.0 L Tedlar Bag
 Test Notes:

Date Collected: NA
 Date Received: NA
 Date Analyzed: 5/05/16
 Volume(s) Analyzed: NA ml(s)

Compound	Spike Amount ppmV	Result ppmV	% Recovery	ALS	Data Qualifier
				Acceptance Limits	
Methane	1,020	1,010	99	83-107	
Ethane	1,010	1,040	103	77-111	
Propane	1,010	1,090	108	78-110	

Traverse Point Locations


BULLSEYE
GLASS FURNACE T7-OUTLET
PORTLAND OR

4/26 - 4/29 2016
PT,BS,JH,MV,JF

mew

EAST

Outer Circumference	Co	in	
Wall thickness	t	in	
INSIDE of FAR WALL to OUTSIDE of Nipple	F	in	14.13
INSIDE of NEAR WALL to OUTSIDE of Nipple	N	in	1.625
STACK WALL to DOWNstream Disturb	N-t	in	
UPstream Disturb	A	in	57.0
Inner Diameter	B	in	39.5
Area	Ds	in	12.5
DOWNstream Ratio	As	sqin	122.7
UPstream Ratio	A/Ds		4.56
	B/Ds		3.16
Minimum #Pts (Particulate)			24
Minimum #Pts/Diameter			12
Minimum #Pts (NON-Particulate)			16
Minimum #Pts/Diameter			8
Actual Points per Diameter			12
Actual Points Used			



Trav Pt #No	Fract Stk ID (f)	Stack ID (Ds)	Actual Points (Dsxf)	Nearest 8ths (TP)	Adjusted Points (TP)	Traverse Points (TP + N)	Traverse Points (TP + N)
1	2.13%	12.5	0.3	0.25	0.5	2.125	2 1 / 8
2	6.70%	12.5	0.8	0.875	0.875	2.5	2 1 / 2
3	11.81%	12.5	1.5	1.5	1.5	3.125	3 1 / 8
4	17.73%	12.5	2.2	2.25	2.25	3.875	3 7 / 8
5	25.00%	12.5	3.1	3.125	3.125	4.75	4 3 / 4
6	35.57%	12.5	4.4	4.5	4.5	6.125	6 1 / 8
7	64.43%	12.5	8.1	8	8	9.625	9 5 / 8
8	75.00%	12.5	9.4	9.375	9.375	11	11
9	82.27%	12.5	10.3	10.25	10.25	11.875	11 7 / 8
10	88.19%	12.5	11.0	11	11	12.625	12 5 / 8
11	93.30%	12.5	11.7	11.625	11.625	13.25	13 1 / 4
12	97.87%	12.5	12.2	12.25	12	13.625	13 5 / 8

Traverse Point Locations


BULLSEYE
GLASS FURNACE T7-OUTLET
PORTLAND OR

4/26 - 4/29 2016
PT,BS,JH,MV,JF

mew

WEST

Outer Circumference	Co	in	
Wall thickness	t	in	
INSIDE of FAR WALL to OUTSIDE of Nipple	F	in	13.88
INSIDE of NEAR WALL to OUTSIDE of Nipple	N	in	1.625
STACK WALL to OUTSIDE of Nipple	N-t	in	
DOWNstream Disturb	A	in	57.0
UPstream Disturb	B	in	39.5
Inner Diameter	Ds	in	12.25
Area	As	sqin	117.9
DOWNstream Ratio	A/Ds		4.65
UPstream Ratio	B/Ds		3.22
Minimum #Pts (Particulate)			24
Minimum #Pts/Diameter			12
Minimum #Pts (NON-Particulate)			16
Minimum #Pts/Diameter			8
Actual Points per Diameter			12
Actual Points Used			



Trav Pt #No	Fract Stk ID (t)	Stack ID (Ds)	Actual Points (Dsxf)	Nearest 8ths (TP)	Adjusted Points (TP)	Traverse Points (TP + N)	Traverse Points (TP + N)
1	2.13%	12.3	0.3	0.25	0.5	2.125	2 1 / 8
2	6.70%	12.3	0.8	0.875	0.875	2.5	2 1 / 2
3	11.81%	12.3	1.4	1.5	1.5	3.125	3 1 / 8
4	17.73%	12.3	2.2	2.125	2.125	3.75	3 3 / 4
5	25.00%	12.3	3.1	3.125	3.125	4.75	4 3 / 4
6	35.57%	12.3	4.4	4.375	4.375	6	6
7	64.43%	12.3	7.9	7.875	7.875	9.5	9 1 / 2
8	75.00%	12.3	9.2	9.25	9.25	10.875	10 7 / 8
9	82.27%	12.3	10.1	10.125	10.125	11.75	11 3 / 4
10	88.19%	12.3	10.8	10.75	10.75	12.375	12 3 / 8
11	93.30%	12.3	11.4	11.375	11.375	13	13
12	97.87%	12.3	12.0	12	11.75	13.375	13 3 / 8



EPA METHOD 1

TRAVERSE POINT LOCATIONS

Client: Bullseye Glass
Source: T-7 Baghouse outlet
Date: 6/6/16

Facility Location: Portland OR
Sample Location: ROOF
Initials: PR

Bottom Ports

Traverse Point Number	Traverse Point Location (inches)
1	2 1/8
2	2 1/2
3	3 1/8
4	3 3/4
5	4 3/4
6	6
7	9 1/2
8	10 7/8
9	11 3/4
10	12 3/8
11	13
12	13 3/8

Duct Dimensions and Port Locations

	E	W
Inside of far wall to outside of nipple, F	14 1/8	13 3/8
Inside of near wall to outside of nipple, N	15 1/8	15 1/8
Nearest downstream disturbance, A	57	
Nearest upstream disturbance, B	39 1/2	
Circular: Inside Diameter, F-N	12 1/2	12 1/4
Rectangular: Width _____" Depth _____"		
Rectangular Equiv. Diameter: (2*W*D)/(W+D) _____"		
Number of Ports:	2	

Duct characteristics:

Construction: Steel PVC Fiberglass Other _____

Shape: Circular Rectangular Elliptical

Orientation: Vertical Horizontal Diagonal (~ angle: _____°)

Flow straighteners: Yes No

Stack Extension: Yes No

Cyclonic Flow Expected: Yes No

Cyclonic Flow Measured & Documented: Yes No

Average Null Angle <20°: Yes No N/A

Meets EPA M-1 Criteria: Yes No (If "No", explain why)

Test port sketch or comments



MONTROSE

AIR QUALITY SERVICES

13505 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505
 www.montrose-env.com

Cyclonic Flow Measurement

Run(s): NA
 Time: 1457

Client: Bulleger Glass
 Source: JFB
 Sample Location: JFB JFB outlet
 Pitot: 3-6


Date: 4/26/16
 Facility Location: Portland, OR
 Operator: BS
 Magnehelic: 97

BS 5/3/16
BS 5/3/16

Null angles measured from horizontal


Port	Traverse Point	Null Angle ($\Delta p = 0$)	Direction of Rotation (CW or CCW)	90° from Null Angle	Direction of Rotation (CW or CCW)	Δp
<u>NW</u>	1	0				
	2	0				
	3	0				
	4	0				
	5	0				
	6	0				
	7	0				
	8	0				
	9	0				
	10	0				
	11	0				
	12	0				
<u>NE</u>	1	0				
	2	0				
	3	0				
	4	0				
	5	0				
	6	0				
	7	0				
	8	0				
	9	0				
	10	0				
	11	0				
	12	0				
	Average	0				

EXAMPLES:



Near side of stack

Null Angle ($\Delta p = 0$)	Direction of Rotation (CW or CCW)
72	CCW
90° from Null Angle	Direction of Rotation (CW or CCW)
18	CW



Far side of stack

Null Angle ($\Delta p = 0$)	Direction of Rotation (CW or CCW)
76	CW
90° from Null Angle	Direction of Rotation (CW or CCW)
14	CCW

HORIZON ENGINEERING 16-5702

Production/Process Data



Raw Material Information

Amount of total chromium in the batch (lbs)

Type and quantity of material being processed


Weight of finished product (lbs)

Weight of charges during each batch (lbs)

Batch tickets providing this information was provided to DEQ prior to testing and no changes to the approved formulations were made. Glass formulation information is Confidential Business information.

Bag House purging cycle - Note: All Purging cycles to be done in low fire

Date	Time	Oxy%	Gas %	BH DP inWC Magnehelic pre - purge	Hz Pre - purge	Close Pm and close slide gate (note location) and clamp damper door	Hz @ purge cycle	Cycles cycle = 4 pulses)	(1 Open Pm and Open slide gate (set to last location) and clamp damper door	Reset Hz to original set point	BH DP inWC Magnehelic	Notes
4/24/2016	8:55	980	515	5.5/4.8	45	open PM/close DD	60	5min	Close PM/open	45	5.1/4.5	
4/24/2016	9:40	707	670	5.5/4.7	45	open PM/close DD	60	10min	Close PM/open	45	5.2/4.5	
	11:15p			5.5/4.8	45	open PM/close DD	60	10min	Close PM/open	45	5.2/4.5	
4/25/2016	230a	920	488	6.8/6.1	50	open PM/close DD	60	10min	Close PM/open	50	6.4/5.6	
4/25/2016	500a	535	280	7/6.3	50	open PM/close DD	60	10min	Close PM/open	50	6.5/5.6	
4/25/2016	110p	433	227	5.9/5.4	45	open PM/close DD	60	10min	Close PM/open	45	5.5/4.7	
4/25/2016	140p	422	230	5.7/4.9	45	open PM/close DD	60	15min	Close PM/open	45	5.5/4.8	
4/25/2016	515p	522	275	5.9/5.	45	open PM/close DD	60	15min	Close PM/open	45	5.5/4.9	
4/25/2016	905p	977	514	6.7/6.1	50	open PM/close DD	60	15min	Close PM/open	50	6.5/5.7	
4/26/2016	215a	807	426	5.8/5.3	45	open PM/close DD	60	10min	Close PM/open	45	5.5/4.9	
4/26/2016	600a	526	274	5.9/5.4	45	open PM/close DD	60	10min	Close PM/open	45	5.7/5.0	
4/26/2016	130p	296	157	6.0/5.5	45	open PM/close DD	45	10min	Close PM/open	45	5.4/4.8	
4/26/2016	315p	598	314	5.5/5.	45	open PM/close DD	45	15min	Close PM/open	45	5.4/4.9	
4/26/2016	430p	498	262	5.5/4.9	45	open PM/close DD	25	15min	Close PM/open	45	5.1/4.7	
4/26/2016	1040p	978	515	6.6/6.2	50	open PM/close DD	25	15min	Close PM/open	50	6/5.4	lowered to 45 hz. Mag 5.1/4.8
4/27/2016	250a	295	154	4.8/4.3	40	open PM/close DD	25	5min	Close PM/open	40	4.5/4.1	
4/27/2016	1130a	297	154	4.8/4.4	45	open PM/close DD	60	10min	close PM/open	40	4.6/4.1	
4/27/2016	1215p	297	158	4.7/4.1	40	open PM/close DD	60	10min	Close PM/open	40	4.6/4.1	
4/27	335p	578	309	4.9/4.3	40	open PM/close DD	30	15min	Close PM/open	40	4.5/4.	
4/27	435p	294	155	4.5/4.1	40	open PM/close DD	30	10min	Close PM/open	40	4.4/4	
4/27	10:40p	294	155	6.5/6.	47.5	open PM/close DD	30	15min	Close PM/open	47.5	5.6/5.2	lowered to 45 hz. Mag 5.1/4.8
4/28	215a	294	155	4.8/4.4	40	open PM/close DD	40/50/60	5min	Close PM/open	40	4.7/4.3	
4/28	1145am	293	155	6.0/5.8	45	open PM/close DD	60	10min	Close PM/open	40	4.8/4.4	
4/28	1215pm	296	156	4.8/4.4	40	open PM/close DD	60	10min	Close PM/open	40	4.8/4.4	
4/28	4:00p	574	292	5.5/4.9	40	open PM/close DD	30	15min	Close PM/open	40	4.5/4.2	
4/28	9:50p	291	153	7.1/6.6	50	open PM/close DD	30	15min	Close PM/open	50	6.5/6	
4/29	155	291	153	7.1/6.7	50	open PM/close DD	30	10	Close PM/open	50	6.7/6.2	
5/1	845p	288	145	8.1/7.6	55	open PM/close DD	30	12	Close PM/open		7.6/6.7	
5/2	1200p	288	148	4.9/4.6	40	open PM/close DD	30	15	Close PM/open	40	4.5/4	
5/2	2:30	561	288	5.5/5.2	45	open PM/close DD	30	15	Close PM/open	45	4.5/4.6	
5/2	830p	535	429	7/6.4	50	open PM/close DD	30	15	Close PM/open	45	5.5/5	



MELT SHACK T-7°F

2650
2500
2350
2200
2050
1900

2016 Tue Apr 26


2016 Wed Apr 27

hour


135


HORIZON ENGINEERING 16-5702





137





Conditions:	Date	Time	Oxy CFH	Gas CFH	Furn. Temp	Ambient Temp	Diverter valve Temp	12" inlet Temp	Bag H. temp	VFD Hertz	Damper set %	Stack damper door position	Air dump position - O/C	PM damper Position - O/C	Furnace door - O/C	Magnahell c
Setup	4/26															
At temp	4/26	5:25pm	478	258	2499	71	107	121	123	45	18	open	closed	closed	closed	5.5/4.9
Charge	4/26	5:30pm	292	154	2417	71	164	201	161	45	25/12.5	open	closed	open	open	5.5/5
Recover	4/26	5:50pm	977	516	2344	72	192	197	159	45	17	open	closed	closed	closed	5.5/5
At temp	4/26	6:10pm	973	516	2460	73	214	216	186	45	19	open	closed	closed	closed	5.5/4.9
Charge	4/26	6:15pm	238	154	2385	72	234	261	210	45	25/12.5	open	closed	open	open	5.4/4.9
Recover	4/26	6:30pm	989	518	2324	72	200	202	179	45	14	open	closed	closed	closed	5.5/4.9
At temp	4/26	7:10pm	983	515	2487	74	205	N/A	204	45	28	open	closed	closed	closed	5.4/4.9
Charge	4/26	7:15pm	294	155	2403	74	207	N/A	203	45	25/12.5	open	closed	open	open	5.4/5
Recover	4/26	7:25pm	982	514	2353	73	189	N/A	184	45	23	open	closed	closed	closed	5.5/5.1
At temp	4/26	8:25pm	715	372	2498	72	169	N/A	188	45	27	open	closed	closed	closed	5.4/5
Charge	4/26	8:30pm	297	156	2418	72	209	N/A	201	45	25/12.5	open	closed	open	open	5.5/5.1
Recover	4/26	8:50pm	981	517	2351	72	198	N/A	187	45	30	open	closed	closed	closed	5.6/5.2
		9:05p							216	47.5						
		9:17pm							210	50						
At temp	4/26	9:55pm	509	269	2500	72	112	N/A	144	50	16	open	closed	closed	closed	6.8/6.3
Charge	4/26	10:00pm	296	156	2411	72	182	N/A	177	50	25/12.5	open	closed	open	open	6.9/6.4
Recover	4/26	10:20pm	971	513	2358	73	156	N/A	167	50	30	open	closed	closed	closed	6.9/6.4
		11:40pm			2487					45						5.1/4.8
At temp	4/26	11:25 PM	531	284	2500	71	120	N/A	152	45	16.8	open	closed	closed	closed	5.5/4.9
Charge	4/26	11:30pm	296	155	2402	71	320	N/A	235	45	25/12.5	open	closed	open	open	5.5/4.9
Recover	4/26	11:50pm	980	515	2377	71	183	N/A	178	45	24	open	closed	closed	closed	5.5/5
Setup																
At temp	4/27	12:55am	535	284	2498	70	164	N/A	160	45	17	open	closed	closed	closed	5.5/5.1
Charge	4/27	1:00am	292	194	2339	69	170	N/A	170	48/45	25/12.5	open	closed	open	open	6.2/5.8
Recover	4/27	1:20am	980	514	2326	69	189	N/A	184	45	25.8	open	closed	closed	closed	5.7/5.2
	4/27	205am	750	395	(estimated flow rates)											
	4/27	245a	484	248	(estimated flow rates)											
	4/27	300am	508	267	(estimated flow rates)											
	4/27	400am	465	241	(estimated flow rates)											
	4/27	500am	566	301	(estimated flow rates)											
	4/27	600am	689	364	(estimated flow rates)											
	4/27	700am	463	235	(estimated flow rates)											
	4/27	800am	448	238	(estimated flow rates)											
	4/27	900am	290	152	(estimated flow rates)											

Notes:
The duration of each charge period is 5 minutes (0.083 hours)
The duration of each refining period is 8 hours.

HORIZON ENGINEERING-16-5702

Conditions:	Date	Time	Oxy CFH	Gas CFH	Furn. Temp	Ambient Temp	Diather valve Temp	12" inlet Temp	Bag H. temp	VRD Hertz	Damper set %	Stack damper door position	Air dump position - O/C	PM damper Position - O/C	Furnace door - O/C	Magnahelic
Setup	4/27									45						
At temp	4/27	5:25pm	524	373	2501	71.5	155	n/a	140	45	8	open	closed	closed	closed	5.4/4.9
Charge	4/27	5:30pm	292	154	2405	71	224	n/a	183	45	25/12.5	open	closed	open	open	5.5/5.
Recover	4/27	5:50pm	982	514	2372	72	190	n/a	173	45	16.6	open	closed	closed	closed	5.5/5
		5:55pm				193			190							
At temp	4/27	6:10pm	978	517	2481	73	177	n/a	188	45		open	closed	closed	closed	
Charge	4/27	6:15pm	294	154	2341	72.3	227.4	n/a	209	45	25/12.5	open	closed	open	open	5.5/5
Recover	4/27	6:36pm	980	515	2356	73	171	n/a	176	45	25	open	closed	closed	closed	5.6/5.1
At temp	4/27	7:10pm	987	515	2497	71	211	n/a	209	45	24.5	open	closed	closed	closed	5.5/5.
Charge	4/27	7:15pm	297	157	2406	71	226	n/a	214	45	25/12.5	open	closed	open	open	5.5/5.1
Recover	4/27	7:35pm	984	517	2405	70.6	211.6	n/a	204.7	45	24.3	open	closed	closed	closed	5.5/5.2
At temp	4/27	8:25pm	590	313	2501	70.9	156	n/a	182	45	24.5	open	closed	closed	closed	5.5/5.2
Charge	4/27	8:30pm	299	158	2392	71.6	195	n/a	190	45	25/12.5	open	closed	open	open	5.6/5.2
Recover	4/27	8:50pm	987	517	2402	70.2	214.2	n/a	199.6	45	26.4	open	closed	closed	closed	5.5/5.1
		9:10p			2346		242		223	47.5						6/5.6
		9:22pm					221		215	50						6.5/6.1
		9:40pm					145		168	47.5						6.2/5.8
At temp	4/27	9:55pm	528	277	2501	68.9	134.5	n/a	155.4	47.5	16.4	open	closed	closed	closed	6.5/6.0
Charge	4/27	10:00pm	297	158	2382	68.9	179.2	n/a	169	47.5	25/12.5	open	closed	open	open	6.5/6
Recover	4/27	10:20pm	975	510	2355	69	163	n/a	165	47.5	27	open	closed	closed	closed	6.5/6
		11:00 AM			2422				45							5.1/4.8
At temp	4/27	11:25 PM	516	273	2500	68	125	n/a	146	45	25	open	closed	closed	closed	5.5/5
Charge	4/27	11:30pm	295	156	2318	68	160	n/a	163	45	25/12.5	open	closed	open	open	5.6/5.2
Recover	4/27	11:50pm	976	518	2370	67	168	n/a	171	45	22	open	closed	closed	closed	5.6/5.2
At temp	4/28	12:55am	505	262	2501	67	122	n/a	151	45		open	closed	closed	closed	5.7/5.2
Charge	4/28	1:00am	294	155	2375	67	165	n/a	171	45	25/12.5	open	closed	open	open	5.8/5.3
Recover	4/28	1:20am	982	513	2308	67	135	n/a	149	45	22	open	closed	closed	closed	5.8/5.3
	4/28	3am	508	267	(estimated flow rates)	65	165		155	40						4.9/4.3
	4/28	4am	465	241	(estimated flow rates)	65	160		152	40						5/4.5
	4/28	5am	566	301	(estimated flow rates)	64.6	154.3		150.4	40						4.9/4.5
	4/28	6am	689	364	(estimated flow rates)	64.5	164		149	40						4.9/4.5
	4/28	7am	463	235	(estimated flow rates)	64	149		138	40						5/4.6
	4/28	8am	448	238	(estimated flow rates)	63	150		139	40						5/4.6
	4/28	9am	290	152	(estimated flow rates)	65	146		138	40						5/4.6
	4/28	10am				66	202		162	45						6/5.6
	4/28	11am				67	195		175	45						6/5.8
	4/28	12pm				74	122		128	40						4.8/4.4
	4/28	1pm				74	120		128	40						5/4.5
	4/28	2pm				77	178		166	40						5/4.5
	4/28	3pm				77.7	164.4		170.6	40						5/4.3
	4/28	4pm				77.1	152.7		161.9	40						5/4.3

Notes:
 The duration of each charge period is 5 minutes (0.083 hours)
 The duration of each refining period is 8 hours.

Conditions:	Date	Time	Qty CFH	Gas CFH	Furn. Temp	Ambient Temp	Diverter valve Temp	12" inlet Temp	Bag H. temp	VFD Hertz	Damper set %	Stack damper door position	Air dump position - O/C	PM damper Position - O/C	Furnace door - O/C	Magnahefic
Setup	4/28									45						
At temp	4/28	4:55pm	537	288	2500	78.8	154	n/a	154	45	12	open	closed	closed	closed	5.6/5.1
Charge	4/28	5:00pm	291	154	2377	77	210	n/a	183	45	25/12.5	open	closed	open	open	5.6/5.1
Recover	4/28	5:20pm	980	515	2352	78.4	194	n/a	177.1	45	19.9	open	closed	closed	closed	5.6/5.2
		5:00pm														
At temp	4/28	5:40pm	978	514	2492	79.9	205.2	n/a	205.8	45	18.1	open	closed	closed	closed	5.5/5.2
Charge	4/28	5:45pm	286	151	2342	79.3	215.7	n/a	209.5	45	25/12.5	open	closed	open	open	5.5/5.2
Recover	4/28	6:05pm	977	516	2345	79.5	197.9	n/a	193.6	45	25.5	open	closed	closed	closed	5.6/5.3
		6:40 AM								47.5						
At temp	4/28	6:40pm	977	510	2501	80.4	236.4	n/a	223.9	47.5	23.4	open	closed	closed	closed	6/5.7
Charge	4/28	6:45pm	293	154	2383	81.9	222.2	n/a	223.9	47.5	25/12.5	open	closed	open	open	6/5.7
Recover	4/28	7:05pm	298	515	2380	79.8	218	n/a	208	47.5	27.1	open	closed	closed	closed	6.2/5.9
		7:40pm								50						6.7/6.3
At temp	4/28	7:55pm	688	361	2509	77.6	177.4	n/a	205.6	50	17	open	closed	closed	closed	6.75/6.3
Charge	4/28	8:00pm	293	155	2384	76.5	197.5	n/a	202.7	50	25/12.5	open	closed	open	open	6.9/6.4
Recover	4/28	8:20pm	974	514	2380	75.3	195.9	n/a	194.9	50	28	open	closed	closed	closed	
		8:45pm	292	154					236	50						7.1/6.6
		9:00pm								45						5.5/5
At temp	4/28	9:25pm	607	322	2509	73.8	161.2	n/a	184.6	45	21.9	open	closed	closed	closed	5.5/5
Charge	4/28	9:30pm	292	154	2356	74.1	212.1	n/a	196.2	45	25/12.5	open	closed	open	open	5.6/5.2
Recover	4/28	9:50pm	981	519	2371	74	219.7	n/a	194.2	45	25	open	closed	closed	closed	6.1/5.2
		10:30pm					262		236	50						6.7/6.5
At temp	4/28	10:55pm	554	591	2500	74	135	n/a	157	50	19.9	open	closed	closed	closed	7/6.6
Charge	4/28	11:00pm	291	152	2442	74	184	n/a	171	50	25/12.5	open	closed	open	open	7/6.6
Recover	4/28	11:20pm	981	513	2391	75	174	n/a	162	50	19.5	open	closed	closed	closed	7.1/6.7
At temp	4/29	12:25am	538	282	2500	72	136	n/a	156	50	20.4	open	closed	closed	closed	7/6.7
Charge	4/29	12:30am	291	152	2366	73	201	n/a	174	50	25/12.5	open	closed	open	open	7.1/6.7
Recover	4/29	12:50am	980	515	2471	72.5	207	n/a	199.6	50	21	open	closed	closed	closed	6.9/6.6
		205am	750	395	2516	70.6	154		163	45	20	t54/b31.5	closed	closed	closed	5.8/5.3
		245a	484	248	2502	71	176		158	40	21	t54/b31.5	closed	closed	closed	4.8/4.4
		300am	508	267	2505	71	187.9		169	40	18.5	t54/b31.5	closed	closed	closed	4.9/4.5
		400am	465	241	2500	71	164		170	40		t54/b31.5	closed	closed	closed	4.9/4.6
		500am	566	301	2498	70	205		179	40	18	t54/b31.5	closed	closed	closed	4.9/4.5
		600am	689	364	2483	70	174		159	40	17	t54/b31.5	closed	closed	closed	4.9/4.6
		700am	463	235	2498	69	165		153	40	25	t54/b31.5	closed	closed	closed	4.9/4.6
		800am	448	238	2500	71.6	177		160	40	17	t54/b31.5	closed	closed	closed	5/4.7
		900am	290	152	2428	75	184		161	40	26	t54/b31.5	closed	closed	closed	5/4.7
		10am														

PHIZON ENGINEERING 16-5702

Notes:
The duration of each charge period is 5 minutes (0.083 hours)
The duration of each refining period is 8 hours.

Calibration Information

Meter Box

Calibration Critical Orifices

Standard Meter

Pitots

Shortridge Micromanometer

Magnehelic Gauge

Thermocouples and Indicators

Nozzle Diameters

Barometer



Biannual Meterbox Calibration

Method EPA M-5 #7.2
 Location Horizon Shop
 Meter Box ID 3
 Meter ID 6077419

Date 3/24/2016
 Pb= 30.35 (in Hg)
 Ta= 58 (°F)
 Tamb 517.67 (°R)

	Old	New	Change	
0.97<Y<1.03	6/30/15	3/24/16	(+/-)	
Y=	1.02452	0.99150	-3.2%	PASS
dH@=	2.07640	1.88884	-9.0%	

calibrated by JM
 Orifice Set IZ

Leak checks
 Negative 0 in/min @ 25 inches Hg
 Positive 0 in/min @ 5 inches H2O

	VAC (in Hg)	Critical Orifice ID	K	dH (inH ₂ O)	Meter (ft ³)	Net (ft ³)	Field T _{di} (°F)	Meter T _{do} (°F)	T _o (°R)	T _m (°R)	Time t (min)	Y	dH@	Y	dH@	Allow. Tolerance
Initial	21.5	IZ48	0.34956	0.71	928.512	5.3930	61.0	62.0	522.7	522.4	12.00	1.01070	1.89402	0.019	0.01	
Final					933.905		64.0	64.0		pass						
Initial	20	IZ55	0.45656	1.3	933.905	6.0160	64.0	64.0	523.2	523.4	10.00	0.98662	1.93347	0.005	0.04	
Final					939.921		64.0	63.0		pass						
Initial	18.5	IZ63	0.58764	2.1	939.921	7.0460	64.0	63.0	524.7	525.2	9.00	0.97720	1.83902	0.014	0.05	
Final					946.967		68.0	67.0		pass						
												0.99150	1.88884			

STDEV 0.0141
 STDEV/AVG 1.42%

Meterbox	Channel	Ambient			Arb.	Heated			Heated
		Standard, °F	Measured, °F	Difference %		Standard, °F	Measured, °F	Difference %	
3	In	61.3	60.4	0.17%	pass	197.7	199.2	-0.23%	pass
	Out	61.3	62.7	-0.27%	pass	197.9	199.2	-0.20%	pass
FLUKE 688									
Calibrated by JM									

Thermocouple Indicator	Channel	Ambient			200 +/-			400 +/-					
		Standard, °F	Measured, °F	Difference %	Standard, °F	Measured, °F	Difference %	Standard, °F	Measured, °F	Difference %			
24-Mar-16	3 Stack	59	61	-0.39%	pass	200	201	-0.15%	pass	400	401	-0.12%	pass
	Probe	59	58	0.19%	pass	200	201	-0.15%	pass	400	399	0.12%	pass
	Oven	59	58	0.19%	pass	200	202	-0.30%	pass	400	400	0.00%	pass
	Impinger	59	61	-0.39%	pass	200	201	-0.15%	pass	400	401	-0.12%	pass
	Aux	59	61	-0.39%	pass	200	201	-0.15%	pass	400	401	-0.12%	pass
	Meter In	59	61	-0.39%	pass	200	201	-0.15%	pass	400	401	-0.12%	pass
	Meter Out	59	61	-0.39%	pass	200	201	-0.15%	pass	400	401	-0.12%	pass
	Signal Tester 647												
Calibrated by JM													

Biannual Meterbox Calibration

Method EPA M-5 #7.2
 Location Horizon Shop
 Meter Box ID 25
 Meter ID 15131835
 HE ID
 calibrated by PLB
 Orifice Set ND

Date 3/24/2016
 Pb= 30.35 (in Hg)
 Ta= 58 (°F)
 Tamb 517.67 (°R)
 Leak checks
 Negative 0 in/min @ 25 inches Hg
 Positive 0 in/min @ 6 inches H₂O

	Old	New	Change	
0.97<Y<1.03	8/25/15	3/24/16	(+/-)	
Y=	1.01267	0.99916	-1.4%	PASS
dH@=	1.79831	1.79729	-0.1%	

	VAC (in Hg)	Critical Orifice ID	K	dH (inH ₂ O)	Meter (ft ³)	Net (ft ³)	Field T _{di} (°F)	Meter T _{do} (°F)	T _o (°R)	T _m (°R)	Time t (min)	Y	dH@	Y 0.020	dH@ 0.20	Allow. Tolerance
Initial	19.5	ND48	0.3353	0.68	167.251	5.1660	64.0	63.0	522.7	523.4	12.00	1.01408	1.97691	0.015	0.18	
Final					172.417		65.0	63.0						pass	pass	
Initial	17.5	ND55	0.44909	1.1	172.417	5.2750	65.0	63.0	523.2	524.4	9.00	0.99851	1.72363	0.001	0.07	
Final					177.692		67.0	64.0						pass	pass	
Initial	15	ND63	0.58688	1.9	177.692	6.2180	67.0	64.0	523.7	525.9	8.00	0.98489	1.69133	0.014	0.11	
Final					183.91		70.0	64.0						pass	pass	
												0.99916	1.79729			

Meterbox	Ambient				Amb.	Heated			Heated
	Standard, °F	Measured, °F	Difference %			Standard, °F	Measured, °F	Difference %	
25 In	58.0	59.0				197.6	199.2		
3/24/16 Out	58.0	58.0	0.00%	pass		197.6	198.8	-0.18%	pass
Fluke	688								
Calibrated by	PLB								

Thermocouple Indicator	Channel	Ambient				200 +/-				400 +/-			
		Standard, °F	Measured, °F	Difference %		Standard, °F	Measured, °F	Difference %		Standard, °F	Measured, °F	Difference %	
25 24-Mar-16	Stack	59	62	-0.58%	pass	200	200	0.00%	pass	400	399	0.12%	pass
	Probe	59	61	-0.39%	pass	200	201	-0.15%	pass	400	398	0.23%	pass
	Oven	59	62	-0.58%	pass	200	198	0.30%	pass	400	398	0.23%	pass
	Impinger	59	62	-0.58%	pass	200	200	0.00%	pass	400	401	-0.12%	pass
	Aux	59	62	-0.58%	pass	200	199	0.15%	pass	400	400	0.00%	pass
	Meter	59	64	-0.96%	pass	200	202	-0.30%	pass	400	401	-0.12%	pass
		59	63	-0.77%	pass	200	202	-0.30%	pass	400	402	-0.23%	pass
Signal tester	647												
Calibrated by	PLB												

Post Test Meterbox Calibration

Method EPA M-5 #7.2
 Location Horizon Shop
 Meter Box ID 3
 Meter ID 6077419
 calibrated by PB

Date 5/25/2016
 Pb= 30.23 (in Hg)
 Ta= 66 (oF)
 Tamb 525.7 (oR)

	Biannual 3/24/2016	Post-Test 5/25/16	Change (+/-)
Y=	0.99150	0.98308	-0.9%
dH@=	1.88864	1.86822	-1.1%

pass

	VAC (in Hg)	Critical Orifice ID IZ	K	dH (inH2O)	Meter (ft3)	Net (ft3)	Field Tdi (oF)	Meter Tdo (oF)	To (oR)	Tm (oR)	Time t (min)	Y ₁	dH@	Y 0.020	dH@ 0.20
Initial	20.5	55	0.44994	1.2	489.867	7.183	67	67	527.0	527.0	12.0	0.9786	1.8530	0.006	0.02
Final					497.050		67	67						pass	pass
Initial	20.5	55	0.44994	1.2	497.050	6.546	67	67	527.5	528.0	11.0	0.9842	1.8730	0.001	0.00
Final					503.596		70	68						pass	pass
Initial	20.5	55	0.44994	1.2	503.596	5.939	70	68	528.0	529.3	10.0	0.9885	1.8787	0.005	0.01
Final					509.535		71	68						pass	pass
												0.98308	1.8682		

Allow. Tolerance

Post Test Meterbox Calibration

Method EPA M-5 #7.2
 Location Horizon Shop
 Meter Box ID 25
 Meter ID 15131835
 calibrated by PT

Date 5/31/2016
 Pb= 30.11 (in Hg)
 Ta= 65 (oF)
 Tamb 524.7 (oR)

	Biannual 3/24/2016	Post-Test 5/31/16	Change (+/-)
Y=	0.99916	0.97912	-2.0%
dH@=	1.79729	1.71253	-4.9%

pass

	VAC (in Hg)	Critical Orifice ID Shop #3	K	dH (inH2O)	Meter (ft3)	Net (ft3)	Field Tdi (oF)	Meter Tdo (oF)	To (oR)	Tm (oR)	Time t (min)	Y	dH@	Y	dH@
Initial	21	55	0.44771	1.1	16.656	5.074	67	66	526.5	527.0	8.5	0.9756	1.7098	0.020	0.20
Final					21.730		68	67						0.004	0.00
Initial	21	55	0.44771	1.1	21.730	6.270	68	67	527.0	528.3	10.5	0.9775	1.7070	0.002	0.01
Final					28.000		71	67						pass	pass
Initial	21	55	0.44771	1.1	28.000	6.242	71	67	527.5	529.5	10.5	0.9843	1.7208	0.005	0.01
Final					34.242		72	68						pass	pass
												0.97912	1.7125		

Allow. Tolerance

Critical Orifice Calibrations

Client HORIZON
 Set ID "YD" Shop #3
 DGM (Y) = 1.00310
 DGM ID # 2299046

Fluke ID 455
 Std Manometer 537

12/2/15 Date
 in house Job
 DP Calibrated
 new QA/QC

Dry Gas Meter			Orifice ID # 40	Orifice ID # 48	Orifice ID # 55	Orifice ID # 63	Orifice ID # 73				
K' Critical Orifice Coefficient			0.23426	0.34072	0.44994	0.59086	0.80743				
Symbol	Units	Run 1	Run 2	Run 1	Run 2	Run 1	Run 2	Run 1	Run 2		
Initial volume	V _i ft ³	498.995	504.431	509.896	515.660	521.449	531.500	537.697	545.494	553.284	563.225
Final Volume	V _f ft ³	504.431	509.896	515.660	521.449	531.500	537.697	545.494	553.284	563.225	580.024
Difference	V _m ft ³	5.436	5.465	5.764	5.789	10.051	6.197	7.797	7.790	9.941	16.799
Temperatures											
Ambient	T _a °F	55.0	58.5	58.5	58.5	59.0	59.5	59.5	59.5	60.0	60.0
Absolute ambient	T _a °R	514.67	518.17	518.17	518.17	518.67	519.17	519.17	519.17	519.67	519.67
Initial Inlet	T _i °F	56.2	65.9	68.7	75.7	76.7	82.9	83.1	88.9	89.5	93.3
Outlet	T _f °F	55.3	56.5	57.5	58.6	59.3	60.7	61.2	62.1	63.0	64.0
Final Inlet	T _i °F	65.9	68.7	75.7	76.7	82.9	83.1	88.9	89.5	93.3	94.5
Outlet	T _f °F	56.5	57.5	58.6	59.3	60.7	61.2	62.1	63.0	64.0	65.7
Avg. Temp	T _m °R	518.145	521.82	524.795	527.245	529.57	531.645	533.495	535.545	537.12	539.045
Time	min sec	18 0	18 0	13 0	13 0	17 0	10 30	10 0	10 0	9 20	15 44
SAMPLE RATE	ACFM	0.3020	0.3036	0.4434	0.4453	0.5912	0.5902	0.7797	0.7790	1.0651	1.0677
Orifice man. rdg	dH@ in H ₂ O	0.28	0.28	0.67	0.67	1.20	1.20	2.20	2.20	4.20	4.20
Barometric. Pressure	Pbar inHg	30.08	30.11	30.11	30.08	30.11	30.08	30.05	30.05	30.08	30.08
Pump vacuum	inHg	21.0	21.0	19.6	19.6	18.0	18.0	16.0	16.0	12.8	12.8
K' factor		0.2341	0.2345	0.3408	0.3407	0.4511	0.4488	0.5923	0.5895	0.8079	0.8070
K' factor Average			0.2343		0.3407		0.4499		0.5909		0.8074
% Error (+/- 0.5)	%	PASS	0.082%	PASS	0.016%	PASS	0.260%	PASS	0.237%	PASS	0.056%

HORIZON ENGINEERING 16-5702

Critical Orifice Calibrations

Client HORIZON
 Set ID "NR" Shop #2
 DGM (Y) = 1.00310 Fluke ID 455
 DGM ID # 2299046 Std Manometer 537

12/2/15 Date
 in house Job
 YY Calibrated
 mew QA/QC

Dry Gas Meter	K' Critical Orifice Coefficient	Symbol	Units	Orifice ID # 40		Orifice ID # 48		Orifice ID # 55		Orifice ID # 63		Orifice ID # 73	
				Run 1	Run 2	Run 1	Run 2	Run 1	Run 2	Run 1	Run 2	Run 1	Run 2
				0.23609		0.34106		0.44771		0.57050		0.77954	
Initial volume	V _i		ft ³	580.170	587.015	595.181	600.520	605.860	612.315	618.785	625.170	631.564	637.752
Final Volume	V _f		ft ³	587.015	595.181	600.520	605.860	612.315	618.785	625.170	631.564	637.752	643.920
Difference	V _m		ft ³	6.845	8.166	5.339	5.340	6.455	6.470	6.385	6.394	6.188	6.168
Temperatures													
Ambient	T _a		°F	59.5	58.0	58.0	58.5	58.5	59.0	59.0	59.5	59.5	59.5
Absolute ambient	T _a		°R	519.17	517.67	517.67	518.17	518.17	518.67	518.67	519.17	519.17	519.17
Initial Inlet	T _i		°F	73.1	67.6	68.6	75.2	76.2	81.9	82.5	87.2	88.0	93.7
Outlet	T _f		°F	64.3	60.1	58.5	59.0	59.5	60.3	60.8	61.6	62.3	63.1
Final Inlet	T _i		°F	67.6	68.6	75.2	76.2	81.9	82.5	87.2	88.0	93.7	94.7
Outlet	T _f		°F	60.1	58.5	59.0	59.5	60.3	60.8	61.6	62.3	63.1	64.0
Avg. Temp	T _m		°R	525.945	523.37	524.995	527.145	529.145	531.045	532.695	534.445	536.445	538.545
Time			min	22	26	12	12	11	11	8	8	6	6
				10	42	0	0	0	0	30	30	0	0
				22.17	26.70	12.00	12.00	11.00	11.00	8.50	8.50	6.00	6.00
SAMPLE RATE			ACFM	0.3088	0.3058	0.4449	0.4450	0.5868	0.5882	0.7512	0.7522	1.0313	1.0280
Orifice man. rdg	dH@		in H ₂ O	0.28	0.28	0.66	0.66	1.20	1.20	2.00	2.00	3.90	3.90
Barometric. Pressure	Pbar		inHg	30.08	30.08	30.05	30.02	30.02	29.99	30.02	30.02	29.99	29.99
Pump vacuum			inHg	21.2	21.2	19.6	19.6	18.0	18.0	16.2	16.2	13.0	13.0
K' factor				0.2368	0.2354	0.3416	0.3405	0.4479	0.4475	0.5709	0.5701	0.7823	0.7768
K' factor Average					0.2361		0.3411		0.4477		0.5705		0.7795
% Error (+/- 0.5)			%	PASS	0.308%	PASS	0.171%	PASS	0.039%	PASS	0.069%	PASS	0.357%

HORIZON ENGINEERING 16-5702


Secondary Standard

M5 1.0031

DATE: 7/22/2015

Operator: Joe Ward

Meter No: 2299046				Meter Box ΔH@ 0.0000						Meter Box Yd 1.0031			Barometric Pressure: 29.71					
				Standard Meter Gas Volume (V _s)			Meter Box Gas Volume (V _{dg})			Std. Meter Temperature (t _s)			Meter Box Temperature (t _d)					
Q	P	H	Yds	Initial	Final	Vf	Initial	Final	Vf	Inlet	Outlet	Avg.	Inlet	Outlet	Avg.	Time	Yd	Run #
1.21	-1.60	0.00	1.0000	0.0	5.005	5.005	192.235	197.290	5.055	72.0	72.0	72.0	76.0	76.0	76.0	4.08	1.0015	1
1.21	-1.60	0.00	1.0000	0.0	6.025	6.025	197.290	203.386	6.096	72.0	72.0	72.0	76.0	76.0	76.0	4.91	0.9997	1
1.21	-1.60	0.00	1.0000	0.0	5.005	5.005	203.386	208.775	5.059	72.0	72.0	72.0	76.0	76.0	76.0	4.09	1.0007	1
0.40	-0.60	0.00	1.0000	0.0	9.145	9.145	255.492	264.670	9.178	72.0	72.0	72.0	76.0	76.0	76.0	22.49	1.0054	2
0.40	-0.60	0.00	1.0000	0.0	5.000	5.000	264.670	269.691	5.021	72.0	72.0	72.0	76.0	76.0	76.0	12.29	1.0048	2
0.40	-0.60	0.00	1.0000	0.0	6.000	6.000	269.691	275.726	6.035	72.0	72.0	72.0	76.0	76.0	76.0	14.73	1.0032	2
0.62	-0.80	0.00	1.0000	0.0	5.000	5.000	279.510	284.532	5.022	72.0	72.0	72.0	77.0	77.0	77.0	8.00	1.0070	3
0.62	-0.80	0.00	1.0000	0.0	5.005	5.005	284.532	289.565	5.033	72.0	72.0	72.0	77.0	77.0	77.0	8.01	1.0058	3
0.62	-0.80	0.00	1.0000	0.0	5.015	5.015	289.565	294.610	5.045	72.0	72.0	72.0	77.0	77.0	77.0	8.01	1.0054	3
0.83	-1.40	0.00	1.0000	0.0	6.005	6.005	307.368	313.408	6.040	72.0	72.0	72.0	76.0	76.0	76.0	7.17	1.0052	4
0.83	-1.40	0.00	1.0000	0.0	9.025	9.025	313.408	322.502	9.094	72.0	72.0	72.0	76.0	76.0	76.0	10.75	1.0034	4
0.83	-1.40	0.00	1.0000	0.0	5.000	5.000	322.502	327.531	5.029	72.0	72.0	72.0	76.0	76.0	76.0	5.97	1.0052	4
1.00	-1.50	0.00	1.0000	0.0	9.300	9.300	331.290	340.710	9.420	72.0	72.0	72.0	76.0	76.0	76.0	9.15	0.9984	5
1.00	-1.50	0.00	1.0000	0.0	5.005	5.005	340.710	345.770	5.060	72.0	72.0	72.0	76.0	76.0	76.0	4.92	1.0003	5
1.00	-1.50	0.00	1.0000	0.0	5.005	5.005	345.770	350.831	5.061	72.0	72.0	72.0	76.0	76.0	76.0	4.95	1.0001	5
AVERAGE																1.0031		

Operator Signature 

Millennium Instruments Inc.
 2402 Springridge Drive unit A
 Spring Grove IL. 60081
 PHONE#(815)675-3225
 FAX#(815)675-6965
 E-mail: millennium@millinst.com
 www.millinst.com

HORIZON ENGINEERING 16-5702

Probe ID: 2-4
 Date: 02/02/16
 Operator: SH
 Procedure: Method 2 Section 10.0

Std. Manometer ID 610/611/584
 Std. P-Types Pitot 160-18

Run #	DpP (P-Type)	DpS (S-Type)	Cp	dS	Avg Cp	S <0.01		
1	0.180	0.250	0.8400	0.004	0.8363	0.002	Cp Limits	Pass
2	0.470	0.660	0.8354	0.001			MAX/MIN	Pass
3	0.880	1.240	0.8340	0.002			S Limits	Pass
4	1.440	2.020	0.8359	0.000				


Method 2 Passing Criteria 10.14.3/12.4



Client: Bullseye
 Project No: 5762

Type S Pitot Tube Inspection Form


PITOT TUBE/PROBE # 2-4



Complete this section for all pitot tubes:

Parameter	Value	Allowable Range	Check
Assembly Level?	Y	Yes	✓
Ports Damaged?	N	No	✓
α_1	1	$-10^\circ < \alpha_1 < +10^\circ$	✓
α_2	1	$-10^\circ < \alpha_2 < +10^\circ$	✓
β_1	0	$-5^\circ < \beta_1 < +5^\circ$	✓
β_2	0	$-5^\circ < \beta_2 < +5^\circ$	✓
γ	0	NA	NA
θ	0	NA	NA
$Z_1 = A \tan \gamma$	0	$Z_1 \leq .125"$	✓
$W_1 = A \tan \theta$	0	$W_1 \leq .031"$	✓
D_T	3.75	.188" to .375"	✓
$A/(2D_T)$.25	$1.05 \leq P_A/D_T \leq 1.5$	✓
A	7.5	$2.1D_T \leq A \leq 3D_T$	✓

$2.1 D_T =$ _____ $3D_T =$ _____



Complete this section for pitot tubes attached to Method 5 probes:

W_2	3.250	$W_2 > 3"$	✓
	—	$W_2 > 2"$	—
Z_2	—	$Z_2 > 0.75"$	—
Y	3.25	$Y \geq 3"$	✓

Certification

I certify that pitot tube/probe number 2-4 meets or exceeds all specifications, criteria and/or applicable design features. See 40 CFR Pt. 60, App. A, EPA Method 2.

Certified by:

[Signature]
 Personnel (Signature/Date)

Probe ID: 3-5
 Date: 02/02/16
 Operator: SH
 Procedure: Method 2 Section 10.0

Std. Manometer ID 610/611/584
 Std. P-Types Pitot 160-18

Run #	DpP (P-Type)	DpS (S-Type)	Cp	dS	Avg Cp	S <0.01		
1	0.200	0.270	0.8521	0.005	0.8472	0.004	Cp Limits	Pass
2	0.470	0.650	0.8418	0.005			MAX/MIN	Pass
3	0.890	1.220	0.8456	0.002			S Limits	Pass
3	1.480	2.010	0.8495	0.002				


Method 2 Passing Criteria 10.14.3/12.4



Client: Bullseye
 Project No: 5702

Type S Pitot Tube Inspection Form


PITOT TUBE/PROBE # 3-5



Complete this section for all pitot tubes:

Parameter	Value	Allowable Range	Check
Assembly Level?	<u>YES</u>	Yes	<input checked="" type="checkbox"/>
Ports Damaged?	<u>NO</u>	No	<input checked="" type="checkbox"/>
$\alpha 1$	<u>1</u>	$-10^\circ < \alpha 1 < +10^\circ$	<input checked="" type="checkbox"/>
$\alpha 2$	<u>0</u>	$-10^\circ < \alpha 2 < +10^\circ$	<input checked="" type="checkbox"/>
$\beta 1$	<u>0</u>	$-5^\circ < \beta 1 < +5^\circ$	<input checked="" type="checkbox"/>
$\beta 2$	<u>-1</u>	$-5^\circ < \beta 2 < +5^\circ$	<input checked="" type="checkbox"/>
γ	<u>0</u>	NA	NA
θ	<u>0</u>	NA	NA
$Z_1 = A \tan \gamma$	<u>0</u>	$Z_1 \leq .125"$	<input checked="" type="checkbox"/>
$W_1 = A \tan \theta$	<u>0</u>	$W_1 \leq .031"$	<input checked="" type="checkbox"/>
D_T	<u>.248</u>	$.188" \text{ to } .375"$	<input checked="" type="checkbox"/>
$A/(2D_T)$	<u>1.285</u>	$1.05 \leq P_A/D_T \leq 1.5$	<input checked="" type="checkbox"/>
A	<u>.6375</u>	$2.1D_T \leq A \leq 3D_T$	<input checked="" type="checkbox"/>

$2.1 D_T = \underline{\hspace{2cm}}$ $3D_T = \underline{\hspace{2cm}}$



Complete this section for pitot tubes attached to Method 5 probes:

W_2	<u>2.10</u>	$W_2 > 3"$	<u>NO</u>
		$W_2 > 2"$	<input checked="" type="checkbox"/>
Z_2		$Z_2 > 0.75"$	<u>NO</u>
Y	<u>3.585</u>	$Y \geq 3"$	<input checked="" type="checkbox"/>

Certification

I certify that pitot tube/probe number 3-5 meets or exceeds all specifications, criteria and/or applicable design features. See 40 CFR Pt. 60, App. A, EPA Method 2.

Certified by:

[Signature]
 Personnel (Signature/Date)

Probe ID: 3-6
 Date: 02/03/16
 Operator: SH
 Procedure: Method 2 Section 10.0

Std. Manometer ID 610/611/584
 Std. P-Types Pitot 160-18

Run #	DpP (P-Type)	DpS (S-Type)	Cp	dS	Avg Cp	S <0.01		
1	0.200	0.280	0.8367	0.001	0.8378	0.002	Cp Limits	Pass
2	0.490	0.690	0.8343	0.004			MAX/MIN	Pass
3	0.870	1.210	0.8395	0.002			S Limits	Pass
4	1.500	2.080	0.8407	0.003				

Method 2 Passing Criteria 10.14.3/12.4




Client: Bullseye
Project No: 5762

Type S Pitot Tube Inspection Form


PITOT TUBE PROBE # 3-6

Complete this section for all pitot tubes:



Parameter	Value	Allowable Range	Check
Assembly Level?	YES	Yes	✓
Ports Damaged?	NO	No	✓
α_1	1	$-10^\circ < \alpha_1 < +10^\circ$	✓
α_2	1	$-10^\circ < \alpha_2 < +10^\circ$	✓
β_1	1	$-5^\circ < \beta_1 < +5^\circ$	✓
β_2	0	$-5^\circ < \beta_2 < +5^\circ$	✓
γ	1	NA	NA
θ	0	NA	NA
$Z_1 = A \tan \gamma$	0.13	$Z_1 \leq .125"$	✓
$W_1 = A \tan \theta$	0	$W_1 \leq .031"$	✓
D_T	0.252	.188" to .375"	✓
$A/(2D_T)$	1.99	$1.05 \leq P_A/D_T \leq 1.5$	✓
A	0.754	$2.1D_T \leq A \leq 3D_T$	✓

$2.1 D_T =$ _____ $3D_T =$ _____



Complete this section for pitot tubes attached to Method 5 probes:

W_2	5.5	$W_2 > 3"$	✓
		$W_2 > 2"$	—
Z_2	1.25	$Z_2 > 0.75"$	✓
Y	4.5	$Y \geq 3"$	✓

Certification

I certify that pitot tube/probe number 3-6 meets or exceeds all specifications, criteria and/or applicable design features. See 40 CFR Pt. 60, App. A, EPA Method 2.

Certified by:

[Signature] 5/3/16
Personnel (Signature/Date)



Client: Bullseye
 Project No: 5702
 Date: 5/3/16

Differential Pressure Gauge Calibration Form

MAGNEHELIC/SHORTRIDGE ID

(circle one)

Parameter	Value	Allowable Range	Check
P _{gauge,1} (in.w.c.)	2.424	NA	NA
P _{std,1} (in.w.c.)	2.4	NA	NA
Difference ₁ (in.w.c.)	.024	NA	NA
Difference ₁ (%)		5%	

Difference = |P_{std} - P_{gauge}|
 % Difference = |P_{std} - P_{gauge}| ÷ P_{std}

Parameter	Value	Allowable Range	Check
P _{gauge,2} (in.w.c.)	1.014	NA	NA
P _{std,2} (in.w.c.)	1.0	NA	NA
Difference ₂ (in.w.c.)	.014	NA	NA
Difference ₂ (%)		5%	

std man 537
 64°
 29.99"
 System Leak ✓
 0.00 @ 6.7

Parameter	Value	Allowable Range	Check
P _{gauge,3} (in.w.c.)	3.020	NA	NA
P _{std,3} (in.w.c.)	3.0	NA	NA
Difference ₃ (in.w.c.)	.020	NA	NA
Difference ₃ (%)		5%	

Parameter	Value	Allowable Range	Check
Max Difference (%)		5%	

Certification

I certify that magnehelic/Shortridge number 1 meets or exceeds all specifications, criteria and/or applicable design features. See 40 CFR Pt. 60, App. A, EPA Method 2 Section 6.2.

Certified by:

[Signature]
 Personnel (Signature/Date)



Client: Bullseye
 Project No: 6702
 Date: 5-2-16

Differential Pressure Gauge Calibration Form

MAGNEHELIC/SHORTRIDGE ID: SR#5
 (circle one)

Parameter	Value	Allowable Range	Check
P _{gauge1} (in.w.c.)	<u>2.413</u>	NA	NA
P _{std1} (in.w.c.)	<u>2.400</u>	NA	NA
Difference ₁ (in.w.c.)	<u>.013</u>	NA	NA
Difference ₁ (%)		5%	

Difference = |P_{std} - P_{gauge}|
 % Difference = |P_{std} - P_{gauge}| ÷ P_{std}

Parameter	Value	Allowable Range	Check
P _{gauge2} (in.w.c.)	<u>.9013</u>	NA	NA
P _{std2} (in.w.c.)	<u>.90</u>	NA	NA
Difference ₂ (in.w.c.)	<u>.0013</u>	NA	NA
Difference ₂ (%)		5%	

Std man: 53T
 64°
 29.99"
 System Leak ✓
 0.000 @ 6.7"

Parameter	Value	Allowable Range	Check
P _{gauge3} (in.w.c.)	<u>.4208</u>	NA	NA
P _{std3} (in.w.c.)	<u>.42</u>	NA	NA
Difference ₃ (in.w.c.)	<u>.0008</u>	NA	NA
Difference ₃ (%)		5%	

Parameter	Value	Allowable Range	Check
Max Difference (%)		5%	

Certification

I certify that magnehelic/Shortridge number 5 meets or exceeds all specifications, criteria and/or applicable design features.
 See 40 CFR Pt. 60, App. A, EPA Method 2 Section 6.2.

Certified by: [Signature]
 Personnel (Signature/Date)



Client: Bullseye
 Project No: 5702
 Date: 5/31/16

Differential Pressure Gauge Calibration Form

MAGNEHELIC/SHORTRIDGE ID: 97

(circle one)

Parameter	Value	Allowable Range	Check
P _{gauge,1} (in.w.c.)	.25	NA	NA
P _{std,1} (in.w.c.)	.25	NA	NA
Difference ₁ (in.w.c.)	0	NA	NA
Difference ₁ (%)		5%	

Difference = |P_{std} - P_{gauge}|
 % Difference = |P_{std} - P_{gauge}| / P_{std}

Parameter	Value	Allowable Range	Check
P _{gauge,2} (in.w.c.)	.19	NA	NA
P _{std,2} (in.w.c.)	.19	NA	NA
Difference ₂ (in.w.c.)	0	NA	NA
Difference ₂ (%)		5%	

std man 537
 64°
 29.99"
 system LEAK ✓
 0.00 @ 6.7

Parameter	Value	Allowable Range	Check
P _{gauge,3} (in.w.c.)	.05	NA	NA
P _{std,3} (in.w.c.)	.05	NA	NA
Difference ₃ (in.w.c.)	0	NA	NA
Difference ₃ (%)		5%	

Parameter	Value	Allowable Range	Check
Max Difference (%)		5%	

Certification

I certify that magnehelic/Shortridge number 97 meets or exceeds all specifications, criteria and/or applicable design features. See 40 CFR Pt. 60, App. A, EPA Method 2 Section 6.2.

Certified by: [Signature]
 Personnel (Signature/Date)

Sample Box Thermocouple Calibrations

Month:		Tester/Standard: PB,BW			Location: Horizon Shop/Auburn shop/Bellingham			Fluke 526	
Sample Box - impinger out	Date	Ambient			Ice				
		Standard, °F	Measured, °F	Difference %	Standard, °F	Measured, °F	Difference %		
I-01	4/7/2016	64.3	68.3	-0.76%	pass	34.7	34.3	0.08%	pass
I-02									
I-03	4/7/2016	66.3	66.0	0.06%	pass	33.1	32.7	0.08%	pass
I-04	1/27/2016	69.0	68.9	0.02%	pass	31.7	31.9	-0.04%	pass
I-05	10/7/2015	68.7	67.3	0.26%	pass	36.9	35.2	0.34%	pass
I-06	1/27/2016	57.7	55.7	0.39%	pass	31.7	32.6	-0.18%	pass
I-07	10/7/2015	68.7	67.3	0.26%	pass	37.1	37.6	-0.10%	pass
I-08	4/7/2016	63.8	65.1	-0.25%	pass	35.0	34.2	0.16%	pass
I-09	10/7/2015	68.6	66.6	0.38%	pass	37.2	36.8	0.08%	pass
I-10	1/27/2016	69.1	67.4	0.32%	pass	31.7	32.0	-0.06%	pass
I-11	1/27/2016	57.7	55.7	0.39%	pass	31.7	33.3	-0.33%	pass
I-12	4/7/2016	66.3	67.9	-0.30%	pass	33.2	33.7	-0.10%	pass
I-13	4/7/2016	64.4	63.5	0.17%	pass	33.0	32.9	0.02%	pass
I-14	4/7/2016	64.0	64.3	-0.06%	pass	33.5	32.7	0.16%	pass
I-15									
I-16	2/26/2016	64.0	65.0	-0.19%	pass	32.0	33.0	-0.20%	pass
I-17	10/7/2015	68.5	67.3	0.23%	pass	37.1	37.1	0.00%	pass
I-18									
I-19									
I-20	4/6/2016	66.8	66.5	0.06%	pass	33.1	33.1	0.00%	pass
I-21									
I-22	3/14/2016	88.8	89.0	-0.04%	pass	31.9	32.0	-0.02%	pass
I-23	4/7/2016	66.1	64.8	0.25%	pass	33.1	33.8	-0.14%	pass
I-24	10/7/2015	68.6	67.1	0.28%	pass	36.5	36.4	0.02%	pass
I-25	2/26/2016	64.0	64.0	0.00%	pass	32.0	34.0	-0.41%	pass
I-26	4/7/2016	65.6	66.5	-0.17%	pass	34.7	34.4	0.06%	pass
I-27	4/7/2016	66.1	66.4	-0.06%	pass	34.3	33.3	0.20%	pass
I-28	4/7/2016	64.3	63.1	0.23%	pass	33.5	33.9	-0.08%	pass
I-29	1/27/2016	67.5	65.5	0.38%	pass	31.7	32.1	-0.08%	pass
I-30	4/6/2016	66.8	65.6	0.23%	pass	33.2	33.7	-0.10%	pass
I-31	4/7/2016	68.0	69.1	-0.21%	pass	35.1	33.3	0.36%	pass
I-32									
I-33									
I-34									
I-35	4/7/2016	64.0	63.6	0.08%	pass	33.1	32.1	0.20%	pass
I-36	10/7/2015	69.8	68.1	0.32%	pass				
I-37	4/7/2016	66.1	66.9	-0.15%	pass	33.8	33.4	0.08%	pass
I-38	4/7/2016	64.2	63.9	0.06%	pass	33.1	33.1	0.00%	pass
I-39	4/7/2016	66.0	66.2	-0.04%	pass	34.7	34.0	0.14%	pass
I-40	4/7/2016	64.3	62.7	0.31%	pass	33.1	32.0	0.22%	pass
I-41	4/7/2016	64.0	62.2	0.34%	pass	33.0	33.3	-0.06%	pass
GS-02	4/6/2016	66.5	65.1	0.27%	pass	36.6	35.6	0.20%	pass
GS-03	4/6/2016	66.4	64.7	0.32%	pass	35.7	33.4	0.46%	pass
GS-202-01	4/7/2016	64.0	62.8	0.23%	pass	33.1	32.5	0.12%	pass
GS-202-02	4/7/2016	65.6	66.9	-0.25%	pass	32.7	33.5	-0.16%	pass
GA-05	11/3/2015	50.5	48.5	0.39%	pass	33.0	33.5	-0.10%	pass
GN-2	1/27/2016	57.7	57.2	0.10%	pass	31.8	31.9	-0.02%	pass
GN-7	4/6/2016	66.5	65.0	0.29%	pass	33.8	33.1	0.14%	pass
4721	11/3/2015	54.2	53.0	0.23%	pass	35.1	34.8	0.06%	pass
SEA-GN-1	4/7/2016	64.0	62.1	0.36%	pass	33.0	33.5	-0.10%	pass
		50.5	48.5	0.39%	pass	33.0	33.5	-0.10%	pass
		50.5	48.5	0.39%	pass	33.0	33.5	-0.10%	pass
		50.5	48.5	0.39%	pass	33.0	33.5	-0.10%	pass
		50.5	48.5	0.39%	pass	33.0	33.5	-0.10%	pass

Sample Box Thermocouple Calibrations

Month:		4/4/2016			Tester/Standard: PB,BW			Location: Horizon Shop/Auburn shop/Bellingham			Fluke 526	
	Date	Ambient				Heated						
		Standard, °F	Measured, °F	Difference %		Standard, °F	Measured, °F	Difference %				
Sample Box - oven												
017	4/5/2016	65.1	65.3	-0.04%	pass	254.0	259.0	-0.70%	pass			
018	4/4/2016	63.4	62.7	0.13%	pass	257.0	258.0	-0.14%	pass			
019	4/6/2016	59.6	57.1	0.48%	pass	227.0	228.0	-0.15%	pass			
020	4/6/2016	60.1	58.3	0.35%	pass	235.0	237.0	-0.29%	pass			
156	DECONST											
172	10/7/2015	72.2	70.1	0.39%	pass	212.0	217.0	-0.74%	pass			
173	12/22/2015	64.0	64.0	0.00%	pass	248.0	249.0	-0.14%	pass			
184	DECONST											
185	10/7/2015	71.8	69.9	0.36%	pass	224.0	225.0	-0.15%	pass			
186	4/5/2016	64.7	65.4	-0.13%	pass	263.0	261.0	0.28%	pass			
187	DECONST											
188	10/7/2015	70.0	69.1	0.17%	pass	226.0	224.6	0.20%	pass			
189	10/7/2015	70.6	68.6	0.38%	pass	222.0	226.1	-0.60%	pass			
190	DECONST											
229	2/26/2016	65.0	64.0	0.19%	pass	228.0	225.0	0.44%	pass			
230												
323	4/7/2016	68.5	68.0	0.09%	pass	262.0	259.0	0.42%	pass			
327	4/5/2016	64.9	65.4	-0.10%	pass	258.0	258.0	0.00%	pass			
328												
329	4/6/2016	59.8	58.0	0.35%	pass	210.0	209.0	0.15%	pass			
331	DECONST											
412												
413	2/1/2016	54.3	54.3	0.00%	pass	232.0	230.0	0.29%	pass			
450	4/7/2016	66.6	67.0	-0.08%	pass	273.0	272.0	0.14%	pass			
451	4/7/2016	65.7	65.0	0.13%	pass	280.0	281.2	-0.16%	pass			
452	4/6/2016	65.6	67.0	-0.27%	pass	265.0	265.0	0.00%	pass			
531	5/17/2016	61.4	64.3	-0.56%	pass	200.1	199.8	0.05%	pass			
453	1/27/2016	56.9	55.3	0.31%	pass	224.0	229.0	-0.73%	pass			
473	4/7/2016	65.3	67.0	-0.32%	pass	261.0	263.2	-0.31%	pass			
479	4/7/2016	62.0	60.1	0.36%	pass	254.0	252.0	0.28%	pass			
524	4/7/2016	60.1	64.0	-0.75%	pass	218.0	218.0	0.00%	pass			
525	4/7/2016	58.4	60.0	-0.31%	pass	257.0	261.0	-0.56%	pass			
609	4/5/2016	64.6	64.2	0.08%	pass	259.0	256.0	0.42%	pass			
649	4/7/2016	58.0	59.0	-0.19%	pass	261.0	260.0	0.14%	pass			
OP-01	11/3/2015	71.0	71.0	0.00%	pass	260.0	262.0	-0.28%	pass			
OS-02	10/23/2015	62.2	60.3	0.36%	pass	183.4	191.0	-1.18%	pass			
OS-16	4/4/2016	64.8	64.3	0.10%	pass	254.0	253.0	0.14%	pass			
OS-30	4/5/2016	61.6	60.3	0.25%	pass	260.0	258.0	0.28%	pass			
OS-31	1/27/2016	57.2	55.8	0.27%	pass	227.0	231.0	-0.58%	pass			
OS-51	4/4/2016	65.9	65.5	0.08%	pass	260.0	261.0	-0.14%	pass			
OS-52	4/5/2016	63.6	63.1	0.10%	pass	263.0	261.0	0.28%	pass			
PDX OS-01	4/7/2016	64.8	66.0	-0.23%	pass	269.0	267.0	0.27%	pass			
SEA OS-01	4/5/2016	63.5	63.7	-0.04%	pass	252.0	250.0	0.28%	pass			
SEA OS-02	11/2/2015	62.6	65.1	-0.48%	pass	185.1	185.3	-0.03%	pass			
SEA OS-03	4/7/2016	64.1	65.0	-0.17%	pass	260.0	258.2	0.25%	pass			



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001

Cert. No.: 4039-6313610

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

Model: 9327K16 S/N: 140754307 Manufacturer: Control Company

JF

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	128	3/12/15	15-CJ73J-4-1
Temperature Calibration Bath TC-309	B3A444		
Digital Thermometer	140073820	1/28/15	4000-5580560

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/31/14 Due Date: 10/31/16
Test Conditions: 23.0°C 43.0 %RH 1021 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.3	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.7	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using instruments traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Justice
Aaron Justice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (AZLA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001

163



Cert. No.: 4039-5554528

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Cust ID: Horizon Engineering, 13585 NE Whitaker Way, Attn. Joe Heffernan III, Portland, OR 97230 U.S.A. (RMA:982686)

Instrument Identification:

JH

ID: CS Model: 90205-22 S/N: 111896552 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/13/14	1000332071
Temperature Probe	128	2/20/14	6-B48Z9-30-1
Temperature Calibration Bath TC-218	A73332		
Thermistor Module	A27129	10/25/14	1000346002
Temperature Probe	5202	11/30/14	15-B15PW-1-1

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 12/03/13 Cal Due: 12/03/15
 Test Conditions: 24.5°C 44.0 %RH 1007 mBar

Calibration Data:

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.5	Y	-1.0	1.0	0.100	>4:1
°C		N.A.		100.000	99.7	Y	99.0	101.0	0.059	>4:1

This instrument was calibrated using instruments traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
 Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
 Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
 International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-7216692

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Cust ID: Horizon Engineering, 13585 NE Whitaker Way, , Portland, OR 97230 U.S.A. (RMA:1000681)

Instrument Identification:

JL

Model: 90205-22 S/N: 240289961 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	3/03/16	1000371058
Temperature Probe	3039	4/02/16	15--A0P2S-20-1
Temperature Calibration Bath TC-231	A79341		
Digital Thermometer	130070752	2/20/16	4000-6561724

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 11/16/15 Due Date: 11/16/16
Test Conditions: 24.9°C 50.0 %RH 1011 mBar

Calibration Data:

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C	0.000	-0.2	Y	0.000	-0.2	Y	-1.0	1.0	0.10	>4:1
°C	100.000	100.0	Y	100.000	100.0	Y	99.0	101.0	0.059	>4:1

This instrument was calibrated using instruments traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judica
Aaron Judica, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be effected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-6313618

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

Model: 9327K16 S/N: 140754311 Manufacturer: Control Company

CH

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	128	3/12/15	15-CJ73J-4-1
Temperature Calibration Bath TC-309	B3A444		
Digital Thermometer	140073820	1/28/15	4000-5680560

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/31/14 Due Date: 10/31/16
Test Conditions: 23.0°C 43.0 %RH 1021 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.5	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.7	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be effected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AO-HOU-RVA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001

Cert. No.: 4039-6313622

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

Model: 9327K16 S/N: 140754314 Manufacturer: Control Company

BC

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	128	3/12/15	15-CJ73J-4-1
Temperature Calibration Bath TC-309	B3A444		
Digital Thermometer	140073820	1/28/15	4000-5680560

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/31/14 Due Date: 10/31/16
Test Conditions: 23.0°C 43.0 %RH 1021 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.5	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.7	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor $k=2$ to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Justice
Aaron Justice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-6313605

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

Model: 9327K16 S/N: 140754303 Manufacturer: Control Company

BS

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	128	3/12/15	15-CJ73J-4-1
Temperature Calibration Bath TC-309	B3A444		
Digital Thermometer	140073820	1/28/15	4000-5680560

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/31/14 Due Date: 10/31/16
Test Conditions: 23.0°C 43.0 %RH 1021 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.2	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.5	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-6313611

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

Model: 9327K16 S/N: 140754308 Manufacturer: Control Company

MV

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	128	3/12/15	15-CJ73J-4-1
Temperature Calibration Bath TC-309	B3A444		
Digital Thermometer	140073820	1/28/15	4000-5680560

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/31/14 Due Date: 10/31/16
Test Conditions: 23.0°C 43.0 %RH 1021 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.3	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.8	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using instruments traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-7216695

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Cust ID: Horizon Engineering, 13585 NE Whitaker Way, , Portland, OR 97230 U.S.A. (RMA:1000681)

Instrument Identification:

Model: 90205-22 S/N: 130301083 Manufacturer: Control Company

PB

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	3/03/16	1000371058
Temperature Probe	3039	4/02/16	15-A0P2S-20-1
Temperature Calibration Bath TC-231	A79341		
Digital Thermometer	130070752	2/20/16	4000-6561724

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 11/16/15 Due Date: 11/16/16
Test Conditions: 24.9°C 50.0 %RH 1011 mBar

Calibration Data:

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C	0.000	-0.3	Y	0.000	-0.3	Y	-1.0	1.0	0.10	>4:1
°C	100.000	99.8	Y	100.000	99.8	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Justice
Aaron Justice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2006-AQ-HOU-RVA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-7216696

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Cust ID: Horizon Engineering, 13585 NE Whitaker Way, Portland, OR 97230 U.S.A. (RMA:1000681)

Instrument Identification:

SH

Model: 90205-22 S/N: 130306869 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	3/03/16	1000371058
Temperature Probe	3039	4/02/16	15-A0P2S-20-1
Temperature Calibration Bath TC-231	A79341		
Digital Thermometer	130070752	2/20/16	4000-6561724

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 11/16/15 Due Date: 11/16/16
Test Conditions: 24.9°C 50.0 %RH 1011 mBar

Calibration Data:

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C	0.000	-0.2	Y	0.000	-0.2	Y	-1.0	1.0	0.10	>4:1
°C	100.000	99.8	Y	100.000	99.8	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-6506386

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

PAT

Model: 9327K16 S/N: 150067645 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-231	A79341		
Thermistor Module	A27129	11/04/15	1000365407
Temperature Probe	5202	11/19/16	6-CV9Y2-1-1
Thermistor Module	A17118	2/24/15	1000351744
Temperature Probe	3039	3/12/15	15-CJ73J-1-1
Temperature Calibration Bath TC-179	A45240		

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 1/28/15 Due Date: 1/28/17
 Test Conditions: 25.0°C 32.0 %RH 1022 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.4	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	99.4	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
 Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
 Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AQ-HOU-RvA.
 International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).



Calibration
Certificate No. 1750.01

Calibration complies with ISO/IEC
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 4039-7175480

Traceable® Certificate of Calibration for Water-Proof Thermometer °F/°C

Manufactured for and distributed by: Thomas Scientific, Box 99, 99 High Hill Road, Swedeboro, NJ 08085-0099 U.S.A.

Instrument Identification:

JM

Model: 9327K16 S/N: 151830463 Manufacturer: Control Company

Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Temperature Calibration Bath TC-179	A45240		
Thermistor Module	A17118	3/03/16	1000371058
Temperature Probe	3039	4/02/16	15-A0P2S-20-1
Temperature Calibration Bath TC-231	A79341		
Thermistor Module	A27129	11/04/15	1000365407
Temperature Probe	5202	11/19/16	6-CV9Y2-1-1

Certificate Information:

Technician: 68 Procedure: CAL-03 Cal Date: 10/30/15 Due Date: 10/30/17
Test Conditions: 24.4°C 50.0 %RH 1012 mBar

Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
°C		N.A.		0.000	-0.3	Y	-1.0	1.0	0.10	>4:1
°C		N.A.		100.000	100.2	Y	99.0	101.0	0.059	>4:1

This Instrument was calibrated using Instruments Traceable to National Institute of Standards and Technology.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min = As Left Nominal(Rounded) - Tolerance; Max = As Left Nominal(Rounded) + Tolerance; Date=MM/DD/YY

Nicol Rodriguez
Nicol Rodriguez, Quality Manager

Aaron Judice
Aaron Judice, Technical Manager

Maintaining Accuracy:

In our opinion once calibrated your Water-Proof Thermometer °F/°C should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Water-Proof Thermometer °F/°Cs change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 4455 Rex Road Friendswood, TX 77546 USA
Phone 281 482-1714 Fax 281 482-9448 service@control3.com www.control3.com

Control Company is an ISO 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.
Control Company is ISO 9001:2008 Quality Certified by (DNV) Det Norske Veritas, Certificate No. CERT-01805-2008-AQ-HOU-RvA.
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

Horizon Shop
2016 Calibrations
JH

BAROMETER CALIBRATIONS ELEVATION OF STANDARD 30 FT	inHg	inHg NWS	mew	
			Diff %	inHg

TV 1		#N/A	#N/A	#N/A
TV 2		#N/A	#N/A	#N/A
TV 3	1/8/2016	30.10	30.02	0.3% 0.08
TV 4	1/15/2016	30.20	30.06	0.5% 0.14
TV 5	1/8/2016	30.20	30.02	0.6% 0.18
Portland Shop Barometer		#N/A	#N/A	#N/A
Shortridge #1 (HE 276)	1/8/2016	30.30	30.02	0.9% 0.28
Shortridge #2 (HE 028)	1/8/2016	30.00	30.02	-0.1% -0.02
Shortridge #3 (HE 226)	1/8/2016	30.00	30.02	-0.1% -0.02
Shortridge #4 (HE 325)	1/13/2016	29.93	29.90	0.1% 0.03
Shortridge #5 (HE 414)	1/15/2016	29.99	30.06	-0.2% -0.07
Shortridge #6	1/13/2016	29.93	29.80	0.4% 0.13
Shortridge #7 (HE 324)	1/8/2016	30.10	30.02	0.3% 0.08
Shortridge #8		#N/A	#N/A	
CARL SLIMP		#N/A	#N/A	

QA/QC Documentation Procedures



Quality Assurance/Quality Control

Introduction The QA procedures outlined in the U. S. Environmental Protection Agency (EPA) test methods are followed, including procedures, equipment specifications, calibrations, sample extraction and handling, calculations, and performance tolerances. Many of the checks performed have been cited in the Sampling section of the report text. The results of those checks are on the applicable field data sheets in the Appendix.

Continuous Analyzer Methods Field crews operate the continuous analyzers according to the test method requirements, and Horizon's additional specifications. On site quality control procedures include:

- Analyzer calibration error before initial run and after a failed system bias or drift test (within $\pm 2.0\%$ of the calibration span of the analyzer for the low, mid, and high-level gases or 0.5 ppmv absolute difference)
- System bias at low-scale (zero) and upscale calibration gases (within $\pm 5.0\%$ of the calibration span or 0.5 ppmv absolute difference)
- Drift check (within $\pm 3.0\%$ of calibration span for low, and mid or high-level gases, or 0.5 ppmv absolute difference)
- System response time (during initial sampling system bias test)
- Checks performed with EPA Protocol 1 or NIST traceable gases
- Leak free sampling system
- Data acquisition systems record 10-second data points or one-minute averages of one second readings
- NO_2 to NO conversion efficiency (before each test)
- Purge time (≥ 2 times system response time and will be done before starting run 1, whenever the gas probe is removed and re-inserted into the stack, and after bias checks)
- Sample time (at least two times the system response time at each sample point)
- Sample flow rate (within approximately 10% of the flow rate established during system response time check)
- Interference checks for analyzers used will be included in the final test report
- Average concentration (run average \leq calibration span for each run)
- Stratification test (to be done during run 1 at three(3) or twelve(12) points according to EPA Method 7E; Method 3A, if done for molecular weight only, will be sampled near the centroid of the exhaust; stratification is check not normally applicable for RATAs)

Quality Assurance/Quality Control

Manual Equipment QC Procedures On site quality control procedures include pre- and post-test leak checks on trains and pitot systems. If pre-test checks indicate problems, the system is fixed and rechecked before starting testing. If post-test leak checks are not acceptable, the test run is voided and the run is repeated. Thermocouples and readouts are verified in the field to read ambient prior to the start of any heating or cooling devices.

Sample Handling Samples taken during testing are handled to prevent contamination from other runs and ambient conditions. Sample containers are glass, Teflon™, or polystyrene (filter petri dishes) and are pre-cleaned by the laboratory and in the Horizon Engineering shop. Sample levels are marked on containers and are verified by the laboratory. All particulate sample containers are kept upright and are delivered to the laboratory by Horizon personnel.

Data Processing Personnel performing data processing double-check that data entry and calculations are correct. Results include corrections for field blanks and analyzer drift. Any abnormal values are verified with testing personnel and the laboratory, if necessary.

After results are obtained, the data processing supervisor validates the data with the following actions:

- verify data entry
- check for variability within replicate runs
- account for variability that is not within performance goals (check the method, testing, and operation of the plant)
- verify field quality checks

Equipment Calibrations Periodic calibrations are performed on each piece of measurement equipment according to manufacturers' specifications and applicable test method requirements. The Oregon Department of Environmental Quality (ODEQ) Source Testing Calibration Requirements sheet is used as a guideline. Calibrations are performed using primary standard references and calibration curves where applicable.

Dry Gas Meters Dry gas meters used in the manual sampling trains are calibrated at three rates using a standard dry gas meter that is never taken into the field. The standard meter is calibration verified by the Northwest Natural Gas meter shop once every year. Dry gas meters are post-test calibrated with documentation provided in test reports.

Quality Assurance/Quality Control

Thermocouples Sample box oven and impinger outlet thermocouples are calibration checked against an NIST traceable thermocouple and indicator system every six months at three points. Thermocouple indicators and temperature controllers are checked using a NIST traceable signal generator. Readouts are checked over their usable range and are adjusted if necessary (which is very unusual). Probe thermocouples are calibrated in the field using the ALT-011 alternate Method 2 calibration procedure, which is documented on the field data sheet for the first run the probe thermocouple was used.

Pitots Every six months, S-type pitots are calibrated in a wind tunnel at three points against a standard pitot using inclined manometers. They are examined for dents and distortion to the alignment, angles, lengths, and proximity to thermocouples before each test. Pitots are protected with covers during storage and handling until they are ready to be inserted in the sample ports.

Nozzles Stainless steel nozzles are calibrated twice each year by checking for nicks or dents and making diameter measurements in triplicate. Quartz and borosilicate glass nozzles (and often stainless steel nozzles) are commonly calibrated in the field by taking the average of three consecutive diameter measurements. These field calibrations are recorded on the field data sheet for the first run the nozzle was used.

Correspondence
Source Test Plan and Correspondence





13585 NE Whitaker Way • Portland, OR 97230
 Phone (503) 255-5050 • Fax (503) 255-0505
www.horizonengineering.com

March 24, 2016

Project No. 5702

Mr. George Davis
 Oregon Department of Environmental Quality
 Northwestern Region – Portland Office
 700 NE Multnomah St., Suite 600
 Portland, OR 97232

Mr. Michael Eisele, P.E.
 Oregon Department of Environmental Quality
 Western Region – Salem Office
 4026 Fairview Industrial Drive
 Salem, OR 97302

Re: Source Testing: Bullseye Glass Co.
 3722 SE 21st Ave
 Portland, OR 97202

This correspondence is notice that Horizon Engineering is to do source testing for the above-referenced facility, tentatively scheduled for April 2016. This will serve as the Source Test Plan unless changes are requested prior to the start of testing.

1. **Source to be Tested:** Glass Furnace T7
2. **Test Locations:** Baghouse BH-1 Inlet and Outlet
3. **Purpose of the Testing:** Performance testing for new baghouse
4. **Source Description:** Source description will be included in the final report.
5. **Pollutants to be Tested:** particulate matter (PM), Total Cr, and Cr⁺⁶.
6. **Test Methods to be Used:** Testing will be conducted in accordance with EPA methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, from the Electronic Code of Federal Regulations (www.ecfr.gov), January, 2014; Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, April, 2015.

Flow Rate: EPA Methods 1 and 2 (S-type pitot w/ isokinetic traverses)
CO₂ and O₂: EPA Method 3A (NDIR and paramagnetic analyzers)¹
Moisture: EPA Method 4 (incorporated w/ ODEQ Method 5)
PM: ODEQ Method 5 (filterable and condensable PM; isokinetic impinger train technique)
Total Cr & Cr⁺⁶: SW-846 Method 0061 (isokinetic recirculatory impinger train technique with Cr⁺⁶ analysis by IC with Post-Column Derivatization-Visible Absorption and Total Cr analysis by ICP-MS)

7. **Continuous Analyzer Data Recording:** Data acquisition system (DAS) will be used. Strip chart records may be used as backup. One-minute averages of one-second readings are logged. Run averages, tabulated data and the graphic outputs from the DAS are included in the test reports.
8. **Continuous Analyzer Gas Sampling:** EPA Method 3A will be sampled at one point near the exhaust centroid because it is not done for a correction. Particulate and gas sampling will be simultaneous.
9. **Criteria Location:** It is assumed today, but it will be confirmed on or before the test day, that each test port location meets criteria in EPA Methods 1 and 2.
10. **Quality Assurance/Quality Control (QA/QC):** Method-specific quality assurance/quality control procedures must be performed to ensure that the data is valid for determining source compliance. Documentation of the procedures and results will be presented in the source test report for review. Omission of this critical information may result in rejection of the data, requiring a retest. This documentation will include at least the following:

Continuous analyzer procedures: Field crews will operate the analyzers according to the test method requirements with additional data backup. On-site procedures include:

EPA Method 3A:

- Analyzer calibration error before initial run and after a failed system bias or drift test (within $\pm 2.0\%$ of the calibration span of the analyzer for the low, mid, and high-level gases or 0.5 ppmv absolute difference)
- System bias at low-scale (zero) and upscale calibration gases (within $\pm 5.0\%$ of the calibration span or 0.5 ppmv absolute difference)
- Drift check (within $\pm 3.0\%$ of calibration span for low, and mid or high-level gases, or 0.5 ppmv absolute difference)
- System response time (during initial sampling system bias test)
- Checks performed with EPA Protocol 1 or NIST traceable gases except zero gas
- Zero gas meets the definition for zero air material as defined by 40 CFR 72.2
- Leak free sampling system
- Data acquisition systems record 10-second data points or one-minute averages of one second readings

¹ EPA Method 3A will only be measured at the baghouse outlet.

- Purge time (≥ 2 times system response time and will be done before starting run 1, whenever the gas probe is removed and re-inserted into the stack, and after bias checks)
- Sample time (at least two times the system response time at each sample point)
- Sample flow rate (within approximately 10% of the flow rate established during system response time check)
- Interference checks for analyzers used will be included in the final test report
- Average concentration (run average \leq calibration span for each run)
- Stratification test (to be done during run 1 at three(3) or twelve(12) points according to EPA Method 7E; EPA Method 3A if done for molecular weight only will be sampled near the centroid of the exhaust; and stratification check not normally applicable for RATAs)

Manual equipment procedures: Field crews will operate the manual testing equipment according to the test method requirements. On-site procedures include:

- Operators will perform pre- and post-test leak checks on the sampling system and pitot lines.
- Thermocouples attached to the pitots and probes are calibrated in the field using EPA Alternate Method 11. A single-point calibration on each thermocouple system using a reference thermometer is performed. Thermocouples must agree within $\pm 2^{\circ}\text{F}$ with the reference thermometer. Also, prior to use, thermocouple systems are checked for ambient temperature before heaters are started.
- Nozzles are inspected for nicks or dents and pitots are examined before and after each use to confirm that they are still aligned.
- Pre- and post-test calibrations on the meter boxes will be included with the report, along with semi-annual calibrations of critical orifices, pitots, nozzles and thermocouples (sample box impinger outlet and oven, meter box inlet and outlet, and thermocouple indicators).
- Blank reagents are submitted to the laboratory with the samples. Liquid levels are marked on sample jars in the field and are verified by the laboratory.
- The Oregon Method 5, 7, and 17 minimum sample volume shall be the greater of 31.8 dscf or sufficient to ensure a minimum ISDL of one-half (1/2) the emission standard.

SW-846 Method 0061: Field crews will operate the manual testing equipment according to the test method requirements. On-site procedures include:

- 0.5 M KOH will be used to ensure that the pH of the solution is above 8.5 after sampling.
- pH of the impinger solution will be checked during sample recovery.
- The sample train will be purged with N_2 at a rate of 10 L/min for 30 minutes.
- If the stack temperature is above 200°F , the Teflon sample and recirculating lines may be placed in an ice bath to keep the recirculated reagent cool enough so it does not turn to steam.

Audit Sample Requirement: The EPA Stationary Source Audit Sample Program was restructured and promulgated on September 30, 2010 and was made effective 30 days after that date. The Standard requires that the Facility or their representative must order audit samples if they are available, with the exception of the methods listed in 40 CFR 60, 60.8(g)(1). The TNI website is referred to for a list of available accredited audit Providers and audits (www.nelac-institute.org/ssas/). If samples are not available from at least two accredited Providers they are not required. Currently, accredited Providers offer audit samples for EPA Methods 6, 7, 8, 12, 13A, 13B, 26, 26A, 29 and 101A. Based on the above, Bullseye Glass is not required to obtain audit samples for this test program.

11. **Number of Sampling Replicates and their Duration:** One (1) test run of approximately sixteen hours at each location. Inlet and outlet testing will be simultaneous. In no case will sampling replicates be separated by twenty-four (24) or more hours, unless prior authorization is granted by the Department.
12. **Reporting Units for Results:** Results will be expressed as concentrations (ppmv, $\mu\text{g}/\text{dscm}$. or gr/dscf), as rates (lb/hr), and on a production basis if that information is provided.
13. **Horizon Engrg. Contact:** Thomas Rhodes or
 (503) 255-5050
 Fax (503) 255-0505
 E-mail trhodes@montrose-env.com
14. **Consultant:** John Browning
 (503) 212-2515
 Cell (503) 412-9842
 E-mail jbrowning@bridgeh2o.com
15. **Source Site Personnel:** Dan Schwoerer
 (503) 232-8887
 Fax (503) 238-9963
 E-mail danschwoerer@bullseyeglass.com
16. **Regulatory Contacts:** George Davis
 (503) 229-5534
 Fax (503) 229-6945
 Email davis.george@deq.state.or.us
- Michael Eisele
 (503) 378-5070
 Fax (503) 378-4196
 E-mail EISELE.Michael@deq.state.or.us
17. **Applicable Process/Production/Control Information:** Operating data that characterize the source are considered to be:
- Type and quantity of material being processed – 1,200 to 1,350 pounds of batch materials to make dark green cathedral glass with a chromium content greater than 1.00%

HORIZON ENGINEERING

- Furnace temperature – Furnace to be regulated between the temperature of 2,100⁰F and 2,575⁰F as per usual production parameters.
- Redox settings – Combustion gasses to be mixed at a ratio of 1.02 to 1.20 parts natural gas for 2.0 parts oxygen as per usual production parameters
- Baghouse pressure drop – Pressure readings will be tracked during the testing cycle
- All normally recorded process information

Process/Production/Control information is to be gathered for each test run by the Source Site Personnel and provided to Horizon for inclusion in the report.

The source must operate at the rate specified in the Permit during testing. Rates not in agreement with those stipulated in the Permit can result in test rejection for application to determine compliance or emission factor verification. Imposed process limitations could also result from atypical rates.

If the Permit does not specify a process rate for testing, we recommend a normal maximum rate.

18. **Source Test Audit Report:** Source Test Audit Report forms will be submitted along with the source test report for this testing.
19. **Plant Entry & Safety Requirements:** The test team will follow internal safety policies and abide by any site specific safety and entry requirements.
20. **Responsibilities of Test Personnel:** The test team will consist of one Project Manager and eight Technicians.
21. **Tentative Test Schedule:**
- Day 1: Mobilize
 - Day 2: Test
 - Day 3: Demobilize
22. **Other Considerations:** The testing locations for the baghouse inlet are on a horizontal section of ducting. Depending on the port orientation, to prevent the recirculating impinger solution from draining out of the nozzle, the SW-846 Method 0061 sample train may only be sampled from the horizontal port.
23. **Administrative Notes:** Unless notified prior to the start of testing, this test plan is considered to be approved for compliance testing of this source. A letter acknowledging receipt of this plan and agreement on the content (or changes as necessary) would be appreciated.

The Department will be notified of any changes in source test plans prior to testing. It is recognized that significant changes not acknowledged, which could affect accuracy and reliability of the results, could result in test report rejection.

Source test reports will be prepared by Horizon Engineering and will include all results and example calculations, field sampling and data reduction procedures, laboratory analysis reports, and QA/QC documentation. Source

HORIZON ENGINEERING

test reports will be submitted to you within 45 days of the completion of the field work, unless another deadline is agreed upon. Bullseye Glass should send one (1) hardcopy of the completed source test report to you at the address above.

Any questions or comments relating to this test plan should be directed to me.

Sincerely,



Thomas Rhodes, QSTI
District Manager
Horizon Engineering, an affiliate of Montrose Environmental Group, Inc.

For information on Horizon Engineering and Montrose Environmental, go to www.montrose-env.com

THIS IS THE LAST PAGE OF THE DOCUMENT



13585 NE Whitaker Way • Portland, OR 97230
 Phone (503) 255-5050 • Fax (503) 255-0505
www.horizonengineering.com

April 8, 2016

Project No. 5702

Mr. George Davis
 Oregon Department of Environmental Quality
 Northwestern Region – Portland Office
 700 NE Multnomah St., Suite 600
 Portland, OR 97232

Mr. Michael Eisele, P.E.
 Oregon Department of Environmental Quality
 Western Region – Salem Office
 4026 Fairview Industrial Drive
 Salem, OR 97302

Re: Source Testing: Bullseye Glass Co.
 3722 SE 21st Ave
 Portland, OR 97202

This correspondence is notice that Horizon Engineering is to do source testing for the above-referenced facility, tentatively scheduled for April 2016. This will serve as the Source Test Plan unless changes are requested prior to the start of testing.

1. **Source to be Tested:** Glass Furnace T7
2. **Test Locations:** Baghouse BH-1 Inlet and Outlet
3. **Purpose of the Testing:** Performance testing for new baghouse. Cr⁺⁶ emissions will be estimated using the Cr⁺⁶ inlet results and the PM removal efficiency.
4. **Source Description:** Source description will be included in the final report.
5. **Pollutants to be Tested:** particulate matter (PM), Total Cr, and Cr⁺⁶.
6. **Test Methods to be Used:** Testing will be conducted in accordance with EPA methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, from the Electronic Code of Federal Regulations (www.ecfr.gov), January, 2014; Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, April, 2015.

Baghouse Inlet

Flow Rate: EPA Methods 1 and 2 (S-type pitot w/ isokinetic traverses)
 CO₂ and O₂: Assume same molecular weight as the outlet
 Moisture: EPA Method 4 (incorporated w/ ODEQ Method 5)
 PM: ODEQ Method 5 (filterable and condensable PM; isokinetic impinger train technique)
 Total Cr & Cr⁺⁶: SW-846 Method 0061 (isokinetic recirculatory impinger train technique with Cr⁺⁶ analysis by IC with Post-Column Derivatization-Visible Absorption and Total Cr analysis by ICP-MS)

Baghouse Outlet

Flow Rate: EPA Methods 1 and 2 (S-type pitot w/ isokinetic traverses)
 Fixed Gases: EPA Method 3C (Tedlar bags with analysis by GC/TCD for CH₄, N₂, O₂, & CO₂)¹
 Moisture: EPA Method 4 (incorporated w/ ODEQ Method 5)
 PM: ODEQ Method 5 (filterable and condensable PM; isokinetic impinger train technique)

7. **Continuous Analyzer Data Recording:** Data acquisition system (DAS) will be used. Strip chart records may be used as backup. One-minute averages of one-second readings are logged. Run averages, tabulated data and the graphic outputs from the DAS are included in the test reports.
8. **Continuous Analyzer Gas Sampling:** EPA Method 3A will be sampled at one point near the exhaust centroid because it is not done for a correction. Particulate and gas sampling will be simultaneous.
9. **Criteria Location:** It is assumed today, but it will be confirmed on or before the test day, that each test port location meets criteria in EPA Methods 1 and 2.
10. **Quality Assurance/Quality Control (QA/QC):** Method-specific quality assurance/quality control procedures must be performed to ensure that the data is valid for determining source compliance. Documentation of the procedures and results will be presented in the source test report for review. Omission of this critical information may result in rejection of the data, requiring a retest. This documentation will include at least the following:

Manual equipment procedures: Field crews will operate the manual testing equipment according to the test method requirements. On-site procedures include:

- Operators will perform pre- and post-test leak checks on the sampling system and pitot lines.
- Thermocouples attached to the pitots and probes are calibrated in the field using EPA Alternate Method 11. A single-point calibration on each thermocouple system using a reference thermometer is performed. Thermocouples must agree within $\pm 2^{\circ}\text{F}$ with the reference thermometer.

¹ It is anticipated that several Tedlar bag samples will be taken during the run to encompass the entire length of the test run.

Also, prior to use, thermocouple systems are checked for ambient temperature before heaters are started.

- Nozzles are inspected for nicks or dents and pitots are examined before and after each use to confirm that they are still aligned.
- Pre- and post-test calibrations on the meter boxes will be included with the report, along with semi-annual calibrations of critical orifices, pitots, nozzles and thermocouples (sample box impinger outlet and oven, meter box inlet and outlet, and thermocouple indicators).
- Blank reagents are submitted to the laboratory with the samples. Liquid levels are marked on sample jars in the field and are verified by the laboratory.
- The Oregon Method 5, 7, and 17 minimum sample volume shall be the greater of 31.8 dscf or sufficient to ensure a minimum ISDL of one-half (1/2) the emission standard.

SW-846 Method 0061: Field crews will operate the manual testing equipment according to the test method requirements. On-site procedures include:

- 0.5 M KOH will be used to ensure that the pH of the solution is above 8.5 after sampling.
- pH of the impinger solution will be checked during sample recovery.
- pH of the impinger solution may be checked periodically during the test run. The sample train will be leak check before and after any disassembly that may be required. If additional KOH is added, the volume will be recorded.
- The sample train will be purged with N₂ at a rate of 10 L/min for 30 minutes.
- If the stack temperature is above 200 °F, the Teflon sample and recirculating lines may be placed in an ice bath to keep the recirculated reagent cool enough so it does not turn to steam.

Audit Sample Requirement: The EPA Stationary Source Audit Sample Program was restructured and promulgated on September 30, 2010 and was made effective 30 days after that date. The Standard requires that the Facility or their representative must order audit samples if they are available, with the exception of the methods listed in 40 CFR 60, 60.8(g)(1). The TNI website is referred to for a list of available accredited audit Providers and audits (www.nelac-institute.org/ssas/). If samples are not available from at least two accredited Providers they are not required. Currently, accredited Providers offer audit samples for EPA Methods 6, 7, 8, 12, 13A, 13B, 26, 26A, 29 and 101A. Based on the above, Bullseye Glass is not required to obtain audit samples for this test program.

11. Number of Sampling Replicates and their Duration: Three (3) test runs of approximately sixteen hours at each location. Inlet and outlet testing will be simultaneous. In no case will sampling replicates be separated by twenty-four (24) or more hours, unless prior authorization is granted by the Department.

12. Reporting Units for Results: Results will be expressed as concentrations (ppmv, µg/dscm. or gr/dscf), as rates (lb/hr), removal efficiency (%), and on a production basis if that information is provided.

- 13. **Horizon Engrg. Contact:** Thomas Rhodes or
 (503) 255-5050
 Fax (503) 255-0505
 E-mail trhodes@montrose-env.com
- 14. **Consultant:** John Browning
 (503) 212-2515
 Cell (503) 412-9842
 E-mail jbrowning@bridgeh2o.com
- 15. **Source Site Personnel:** Dan Schwoerer
 (503) 232-8887
 Fax (503) 238-9963
 E-mail danschwoerer@bullseyeglass.com
- 16. **Regulatory Contacts:** George Davis
 (503) 229-5534
 Fax (503) 229-6945
 Email davis.george@deq.state.or.us
 Michael Eisele
 (503) 378-5070
 Fax (503) 378-4196
 E-mail EISELE.Michael@deq.state.or.us

17. Applicable Process/Production/Control Information: Operating data that characterize the source are considered to be:

- Type and quantity of material being processed – 1,200 to 1,350 pounds of batch materials to make dark green cathedral glass with a high chromium content. Cullet will not be used during the source test.
- Furnace temperature – Furnace to be regulated between the temperature of 2,100⁰F and 2,575⁰F as per usual production parameters.
- Redox settings – Combustion gasses to be mixed at a ratio of 1.00 parts natural gas for 1.90 to 1.80 parts oxygen as per usual production parameters, in a furnace plumbed with natural gas and liquid oxygen
- Baghouse pressure drop – Pressure readings will be tracked during the testing cycle
- All normally recorded process information

Process/Production/Control information is to be gathered for each test run by the Source Site Personnel and provided to Horizon for inclusion in the report.

The source must operate at the rate specified in the Permit during testing. Rates not in agreement with those stipulated in the Permit can result in test rejection for application to determine compliance or emission factor verification. Imposed process limitations could also result from atypical rates.

If the Permit does not specify a process rate for testing, we recommend a normal maximum rate.

18. Source Test Audit Report: Source Test Audit Report forms will be submitted along with the source test report for this testing.

19. Plant Entry & Safety Requirements: The test team will follow internal safety policies and abide by any site specific safety and entry requirements.

20. Responsibilities of Test Personnel: The test team will consist of one Project Manager and up to eight Technicians.

21. Tentative Test Schedule:

April 25 (Mon): Mobilize and setup
April 26 (Tues): Begin test Run 1
April 27 (Wed): Begin test Run 2
April 28 (Thurs): Begin test Run 3
April 29 (Fri): Complete testing and demobilize

22. Other Considerations: None known

23. Administrative Notes: Unless notified prior to the start of testing, this test plan is considered to be approved for compliance testing of this source. A letter acknowledging receipt of this plan and agreement on the content (or changes as necessary) would be appreciated.

The Department will be notified of any changes in source test plans prior to testing. It is recognized that significant changes not acknowledged, which could affect accuracy and reliability of the results, could result in test report rejection.

Source test reports will be prepared by Horizon Engineering and will include all results and example calculations, field sampling and data reduction procedures, laboratory analysis reports, and QA/QC documentation. Source test reports will be submitted to you within 45 days of the completion of the field work, unless another deadline is agreed upon. Bullseye Glass should send one (1) hardcopy of the completed source test report to you at the address above.

Any questions or comments relating to this test plan should be directed to me.

Sincerely,



Thomas Rhodes, QSTI
District Manager
Horizon Engineering, an affiliate of Montrose Environmental Group, Inc.

For information on Horizon Engineering and Montrose Environmental, go to www.montrose-env.com

THIS IS THE LAST PAGE OF THE DOCUMENT

HORIZON ENGINEERING



Oregon

Kate Brown, Governor

191

Department of Environmental Quality

Western Region Salem Office
4026 Fairview Industrial Dr SE
Salem, OR 97302
(503) 378-8240
FAX (503) 373-7944
TTY 711

April 12, 2016

Eric Durrin
Bullseye Glass Company
3722 SE 21st Ave
Portland, OR 97202

Thomas Rhodes
Horizon Engineering
13585 NE Whitaker Way
Portland, OR 97230

Re: Bullseye Glass Company
ACDP Permit 26-3135-ST-01
Source Test Plan

Eric Durrin and Thomas Rhodes:

DEQ originally received the source test plan for testing the emissions from glass furnace T7 located at Bullseye Glass in Portland, OR on March 21, 2016. DEQ received the first revised plan on March 25, 2016, and final revised plan on April 8, 2016. The final plan details the methods and approach to determine the emission rate and removal efficiency of particulate matter (PM) from the baghouse inlet and exhaust, and the measurement of total chromium (Cr) and hexavalent chromium (Cr⁺⁶) at the baghouse inlet. DEQ has reviewed the source test plan and is approving it with the following conditions:

GENERAL PROCESS CONDITIONS

- 1.) Only regular operating staff may adjust the production process and emission control parameters during the source performance tests and within two (2) hours prior to the tests. Any operating adjustments made during the source performance tests, which are a result of consultation during the tests with source testing personnel, equipment vendors or consultants, may render the source performance test invalid. Any adjustments made during the test must be recorded and included in the test report.
- 2.) Testing shall be performed while the furnace is making glass with the highest percentage of chromium normally used. The furnace must also be fired in the most oxidizing condition under which chromium containing glass is normally made. The ingredients in the batch must be the most oxidizing ingredients normally used to make chromium containing glass. Documentation stating and explaining this must be provided in the test report.



- 3.) During source testing the following process parameters must be monitored, recorded, and documented in the source test report. The process parameters below are to be reported for each individual test run and averaged for all test runs, if appropriate.
- Amount of total chromium in the batch (lbs)
 - Type and quantity of material being processed
 - Oxygen usage (quantity used, hourly minimum)
 - Natural gas usage (quantity used, hourly minimum)
 - Furnace temperature (°F, hourly minimum)
 - Baghouse pressure drop (inches of water column, twice per test run)
 - Weight of charges during each batch (lbs)
 - Time of charges
 - Weight of finished product (lbs)
 - Duration of the charging period (hrs)
 - Duration of refining period (hrs)
 - All other normally recorded information

TOTAL CHROMIUM & HEXAVALENT CHROMIUM (EPA SW-846 METHOD 0061) CONDITIONS

- 4.) During sampling, make sure other sampling equipment is not interfering with isokinetic sampling.
- 5.) Take steps to minimize the blockage effects of the sampling probe in the test duct/stack.
- 6.) Testing must be performed using two ports located 90 degrees from each other.
- 7.) The sample shall be collected in a different plane (i.e., different set of ports and a port at a different angle) than the inlet particulate sample.
- 8.) To ensure that representative chromium samples are collected during these extended test intervals (~16 hours), four sequential traverses should be performed on each of the two ports. For example, sampling points should be moved every ten minutes (120 minutes per traverse), rather than performing a single traverse (40 minutes per point). The test run only needs to include one port change.
- 9.) Ensure the recirculating KOH cannot be lost out the sampling nozzle.
- 10.) With the exception of the sampling nozzle (glass) and the silica gel impinger, all of the sampling train components (including connecting fittings) shall be Teflon.

- 11.) In Section 10, Horizon notes that the pH of the KOH sample solution will be measured after the completion of the testing, which is required by the method. Given the duration of the testing you may, to make sure the pH of the absorbing solution remains above 8.5, momentarily pause the test to check the pH periodically throughout the run (e.g., every few hours). Any pH data collected shall be documented on the field data sheet. Leak checks must be completed any time the sampling system is opened. Leak checks of the equipment and any gain in volume by the dry gas meter due to the leak checks must also be documented on the field data sheets. Correct the final sample volume by the amount collected during the leak checks and use the corrected sample volume amount for emissions calculations.
- 12.) Equation 7.6.4 of the method has an error. If Horizon opts to perform a blank correction, please use the following equation:
- $$m = [(S, \text{ug/ml} * V_{ls}, \text{ml}) - (B, \text{ug/ml} * 300 \text{ ml})] \times d$$
- (Note: The above equation assumes that the impingers are initially charged with 300 mls of the KOH reagent)
- 13.) Verify the KOH recirculation rate is at least 50 ml/min.
- 14.) Record the nitrogen purge rate and duration.
- 15.) Following purging and filtration, the sample solution is to be transferred to polyethylene sample bottles.
- 16.) Following the test, the impinger solution shall be purged with nitrogen and filtered through an acetate membrane filter (0.45 um pore size); refer to Section 5.4.3 of the method.
- 17.) The volume of DI water used to rinse the sampling train directly affects the detection limit. The volume should be sufficient to quantitatively rinse the train; it should not be excessive. We recommend that a pre-measured volume of rinse water (e.g., 100 mls) be provided to the sample recovery person so that the same amount of rinse is used for each test.
- 18.) Take steps to make sure the level of hexavalent chromium in the KOH reagent is as low as possible before testing begins.
- 19.) Meticulously follow the procedures in section 7.1.2 to make sure the sampling trains are free of contaminates.
- 20.) The hexavalent chromium analyses are to be completed within 14 days of sample collection (Section 6.3 of the method).
- 21.) Hexavalent and total chromium test results must be reported as indicated below for each individual test run and averaged for all three test runs. Hand calculations must be provided for at least one test run.
- ng/dscm
 - lbs/hr
 - lbs/ton of chromium processed
 - lbs/ton of glass produced

- 22.) Use the particulate removal efficiency to calculate the emission rate of hexavalent and total chromium emissions. Report results as indicated below for each individual test run and averaged for all three test runs. Hand calculations must be provided for at least one test run.
- ng/dscm
 - lbs/hr
 - lbs/ton of chromium processed
 - lbs/ton of glass produced

Note that Item 22 data (baghouse *exhaust* chromium emissions) shall be clearly denoted in the report's summary table(s) as 'calculated (vs. measured) values'.

FLOW RATE AND MOISTURE (EPA METHODS 1, 2, & 4) CONDITIONS

- 23.) The exhaust duct configurations and flow measurements must meet the EPA Methods 1/1A & 2 criteria. Documentation including clear diagrams must be provided in the source test report.
- 24.) The sample locations must be checked for cyclonic flow. Documentation of this must be provided in the test report.
- 25.) Ensure that the manometer used to record pressure readings meets the criteria of Method 2 Section 6.2.
- 26.) Moisture content of the exhaust stack gas must be determined by EPA Method 4 for each test run. In addition, Section 12.1.7 of EPA Method 4 states "In saturated or moisture droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one using a value based upon the saturated conditions (alternate method) and one based upon the results of the impinger analysis (EPA Method 4). If this is the case, then ODEQ Method 4 (wet bulb/dry bulb) shall be used as the alternative method. At a minimum, two measurements of moisture content using ODEQ Method 4 shall be made for each run and averaged for the run. The lower of the two values as determined by EPA Method 4 and ODEQ Method 4 shall be considered correct for each run.

EXHAUST GAS COMPOSITION (EPA METHOD 3C/ASTM METHODS 1946) CONDITIONS

- 27.) N_2 , O_2 , CO_2 , CO , CH_4 , C_2H_6 , and C_3H_8 concentrations must be determined to calculate the molecular weight of the exhaust. Collect sample at a constant rate over the duration of the test run. Record the sampling rate on the field data sheet.
- 28.) Immediately after the completion of the test run, close the bag valve and keep the bag under positive pressure until the sample is analyzed to ensure any leakage of the bag will not dilute the sample. A band around the bag should be sufficient to accomplish this although other measures may be taken that accomplish the same result. In the event that multiple bags are collected, record the start and end times of the collection periods.
- 29.) Analyze each bag separately and time weight the concentrations to get an average molecular weight over the duration of each test run.

- 30.) EPA Method 3A is cited in the test plan, DEQ understands that this is an inaccuracy and that Method 3A will not be used during this testing program. The methods referenced in this section will be used to determine the molecular weight in place of Method 3A.

PARTICULATE MATTER (EPA/ ODEQ METHOD 5) CONDITIONS


- 31.) During sampling, make sure other equipment is not interfering with isokinetic sampling.
- 32.) Additional (i.e., empty) impingers may be added between the second and fourth impinger to collect condensate from the flue gas.
- 33.) At the inlet sampling location, the particulate sample shall be collected in a different plane (i.e., different set of ports and a port at a different angle) than the chromium sample is being collected.
- 34.) Take steps to minimize the blockage of the sampling location with sampling equipment.
- 35.) To ensure that representative particulate samples are collected during these extended test intervals (~16 hours), four sequential traverses should be performed on each of the two ports. For example, sampling points should be moved every ten minutes (120 minutes per traverse), rather than performing a single traverse (40 minutes per point). The test run only needs to include one port change.
- 36.) If the filter becomes plugged to the point in which isokinetics can no longer be maintained pause the inlet and outlet sampling. Leak check the sampling system with the clogged filter; replace the filter; repeat the check the sampling system; make note of the dry gas meter's volume displacement caused by the leak checks; and continue testing. Correct the final sample volume by the amount collected during the leak checks and use the corrected sample volume amount for emissions calculations.
- 37.) For ODEQ Method 5, the method quantifiable limit (MQL) is 7 mg of PM, which should be taken into consideration when targeting a minimum sample volume and when calculating results. If less than 7 mg is collected, calculations shall be based not on the actual mass of PM collected but on the MQL of 7 mg as a "less than quantifiable limit" value.
- 38.) For both the inlet and outlet of the baghouse provide filterable, condensable and total PM test results. The results must be reported as follows for each test run and averaged for all three test runs. Complete hand calculations must be provided for at least one test run.
- gr/dscf
 - lb/hour
 - lb/ton of glass produced
 - % removal efficiency based on lb/hour of the inlet and outlet results

GENERAL TESTING CONDITIONS

- 39.) The ODEQ must be notified of any changes in the source test plan and/or the specified methods prior to testing. Significant changes not acknowledged by the DEQ could be basis for invalidating an entire test run and potentially the entire testing program. Documentation of any deviations must include an evaluation of the impact of the deviation on the test data. Deviations may result in rejection of the data, requiring a retest.
- 40.) Method-specific quality assurance/quality control (QA/QC) procedures must be performed to ensure that the data is valid. Documentation of the procedures and results shall be presented in the source test report for review. Omission of this critical information will result in rejection of the data, requiring a retest.
- 41.) A copy of a completed Source Test Audit Report (STAR) for all applicable Methods performed must accompany the submittal of the Source Test Report. A copy of the STAR forms is available electronically from the regional source test coordinator.
- 42.) In an attempt to conserve natural resources and to minimize storage space requirements, the test report should be printed on both sides of each page within the document. DEQ recognizes this may not be feasible for some supporting documentation (i.e. figures, maps, etc.).
- 43.) The source test report shall be submitted to the DEQ within 45 days following the completion of the source test.

DEQ understands that the source test is scheduled for April 26-28, 2016. If you have any questions, please contact me at (503) 378-5070.

Sincerely,




Mike Eisele, PE
AQ Source Test Coordinator
Western Region-Salem

cc: George Davis, DEQ: NWR-AQ File



Quality Assurance Documentation
MAQS QSTI/QI Certification Dates
Qualified Individual (QI) Certificates
QMS Statement of Conformance



QSTI Certification Expiration Dates

QSTI Employee 26 April 2016	Cert. No.	Group 1 Expirations		Group 2 Expirations		Group 3 Expirations	
		Certificate	Exam (QI)	Certificate	Exam (QI)	Certificate	Exam (QI)
Andy Vella	2008-247	24 December 2017	24 June 2017	24 June 2017	24 June 2017	25 June 2017	25 June 2017
Brett Sherwood	-	-	25 February 2021	-	26 February 2021	-	-
Carl Slimp	2009-362	22 May 2018	22 May 2018	26 March 2018	26 March 2018	31 July 2018	31 July 2018
C. David Bagwell	2005-022	29 March 2020	29 March 2020	-	17 December 2020	29 March 2020	29 March 2020
Chris Hinson	2014-830	5 September 2018	5 September 2018	27 October 2018	27 October 2018	21 November 2018	21 November 2018
Danny Phipps	2016-915	16 December 2020	16 December 2020	17 December 2020	17 December 2020	16 March 2021	17 March 2021
David Wagner	2012-658	3 April 2017	3 April 2017	3 April 2017	3 April 2017	3 April 2017	3 April 2017
Jason French	2013-771	19 March 2018	5 August 2017	19 March 2018	11 December 2017	19 March 2018	6 August 2017
Joe Heffernan III	2009-325	16 December 2020	16 December 2020	16 December 2020	16 December 2020	23 March 2019	25 March 2018
John Lewis	2011-550	28 January 2020	28 July 2020	29 January 2020	29 January 2020	-	25 February 2021
Mark Stanfield	2009-337	25 January 2020	25 January 2020	-	-	5 April 2020	5 April 2020
Mihai Voivod	2016-916	25 February 2021	26 February 2021	29 July 2020	29 July 2020	17 December 2020	17 December 2020
Robert Rusi	2012-656	19 March 2017	19 March 2017	19 March 2017	19 March 2017	19 March 2017	19 March 2017
Scott Chesnut	2012-655	19 March 2017	19 March 2017	19 March 2017	19 March 2017	19 March 2017	19 March 2017
Tom Lyons	2012-721	30 July 2017	24 June 2017	30 July 2017	24 June 2017	30 July 2017	25 June 2017
Thomas Rhodes	2010-408	16 December 2020	16 December 2020	17 December 2020	17 December 2020	14 April 2020	25 March 2018

QSTI Employee 26 April 2016	Cert. No.	Group 4 Expirations		Group 5 Expirations	
		Certificate	Exam (QI)	Certificate	Exam (QI)
Andy Vella	2008-247	9 March 2020	9 March 2020	-	-
Brett Sherwood	-	-	-	-	-
Carl Slimp	2009-362	22 December 2018	22 December 2018	-	-
C. David Bagwell	2005-022	-	11 December 2017	-	-
Chris Hinson	2014-830	9 February 2019	9 February 2019	-	-
Danny Phipps	2016-915	17 March 2021	18 March 2021	-	-
David Wagner	2012-658	3 April 2017	3 April 2017	-	-
Jason French	2013-771	19 March 2018	11 December 2017	-	-
Joe Heffernan III	2009-325	17 December 2020	17 December 2020	-	-
John Lewis	2011-550	24 August 2016	26 February 2021	-	-
Mark Stanfield	2009-337	5 April 2020	5 April 2020	-	-
Mihai Voivod	2016-916	-	-	-	-
Robert Rusi	2012-656	19 March 2017	19 March 2017	-	-
Scott Chesnut	2012-655	19 March 2017	19 March 2017	-	-
Tom Lyons	2012-721	30 July 2017	25 June 2017	-	-
Thomas Rhodes	2010-408	9 March 2020	9 March 2020	-	-

****Red type indicates expired certification or QI as of date above****

****Orange type indicates certification/QI within 6 months of expiration from date above****

****Green type indicates certification/QI valid for greater than 6 months from date above****

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

JASON T. FRENCH

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 20TH DAY OF MARCH 2013 AND EFFECTIVE UNTIL MARCH 19TH, 2018

Peter R. Westlin, QST/QSTO Review Board


Peter S. Pakalnis, QST/QSTO Review Board

David Ranwall, QST/QSTO Review Board

Karen D. Kajiya-Mills, QST/QSTO Review Board

Glenn C. England, QST/QSTO Review Board

APPLICATION
NO.
2013-771



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

JOSEPH M. HEFFERNAN, III

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 17TH DAY OF DECEMBER 2015 AND EFFECTIVE UNTIL DECEMBER 16TH, 2020

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakainis, QSTI/QSTO Review Board


Theresa Lowe, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE
NO.
2009-325



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

JOHN S. LEWIS

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED
EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES
ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

**MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE
SAMPLING METHODS**

ISSUED THIS 29TH DAY OF JULY 2015 AND EFFECTIVE UNTIL JULY 28TH, 2020

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa Lowe, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

CERTIFICATE
NO.
2011-550



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

CHRISOPHER J. HINSON

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 6TH DAY OF SEPTEMBER 2013 AND EFFECTIVE UNTIL SEPTEMBER 5TH, 2018

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa Lowe, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

APPLICATION
NO.
2014-830



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

MIHAI V. VOIVOD

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 26TH DAY OF FEBRUARY 2016 AND EFFECTIVE UNTIL FEBRUARY 25TH, 2021

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa Lowe, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE
NO.
2016-916



From: Theresa Lowe <tf_lowe@yahoo.com>
Sent: Wednesday, March 9, 2016 5:34:32 PM
To: Brett Sherwood
Cc: Gail Westlin
Subject: QSTI Score - Brett M. Sherwood

THIS EMAIL IS THE OFFICIAL NOTIFICATION OF YOUR SES QUALIFIED SOURCE TESTING INDIVIDUAL OR OBSERVER (QSTI/QSTO) EXAM(S) RESULTS (Please Print Out for Your Records)

To:	<i>Brett M. Sherwood</i>
Employed by:	<i>Montrose Environmental</i>
Phone:	<i>503-255-5050</i>
Email:	<i>bsherwood@montrose-env.com</i>

The Source Evaluation Society, through its contract with Eastern Technical Associates, has received the score of the exam(s) you completed on the date(s) as listed below. You are required to receive a score of 40 to pass an exam. As noted below, a "P" indicates you passed the exam, a "DNP" indicates that you did not pass the exam.

<i>Group #</i>	<i>Exam</i>	<i>Date of Exam</i>	<i>Exam #</i>	<i>Score</i>	<i>Status</i>
1	EPA Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods	2/25/16	12713		P
1A	Stack Gas Flow Rate Measurements Sampling Methods				
2	EPA Manual Gaseous Pollutants Source Sampling Methods	2/26/16	12715		P
3	EPA Gaseous Pollutants Instrumental Methods				
4	EPA Hazardous Metals Measurement Methods				
5	Part 75 CEMS RATA Testing				

NOTE: (1) The ECMPs AETB reporting requirements include a provision for an email address to be noted for the exam provider. Your exam provider is the Source Evaluation Society. Please use the following email address: qstiprogram@gmail.com. (2) Your exam score(s), per ASTM D7036-04, will be applicable for five years. **You will need to re-take your exam(s) before expiration in order to maintain a current status.** You are responsible for keeping track of scheduling for your re-test.


If you passed one or more exams, you are eligible to apply for your SES QSTI/QSTO qualification approval(s). To complete the qualification process, you will need to do the following: **For New Applications / Additional Group Certificates / Renewals:** Please check the SES Website (www.sesnews.org) under the link for the "SES QSTI/QSTO Program" for directions on how to apply for your certificate or contact Gail Westlin at gail_westlin@yahoo.com or Theresa Lowe at tf_lowe@yahoo.com.

If a QSTI/QSTO candidate receives notice that he or she did not pass a SES methods group exam(s), the QSTI/QSTO candidate ask the Committee for a review of their exam(s). Any review request should be sent to gail_westlin@yahoo.com or tf_lowe@yahoo.com. As part of the review, the Committee will provide references to methods for those questions missed.



Quality Management System Conformance Statement

I Jason French, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.



Employee Signature

7-27-15
Date



Quality Management System Conformance Statement

I CHRIS HINSON, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.




Employee Signature

8/14/15
Date



Quality Management System Conformance Statement

I John Sterling Lewis, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.


Employee Signature

8/10/15
Date



Quality Management System Conformance Statement

I Joe Messner, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.


Joe Messner
Employee Signature

9/12/15
Date



Quality Management System Conformance Statement

I, Brett Sherwood, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.


Employee Signature

9/17/15
Date



Quality Management System Conformance Statement

I BRANDON CRAWFORD, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.

Brandon Crawford
Employee Signature

1/31/15
Date



Quality Management System Conformance Statement

I Mihai Voivod, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.

M. Voivod
Employee Signature

7/27/15
Date



Quality Management System Conformance Statement

I, Patrick Todd, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.

A handwritten signature in cursive script, appearing to read "Patrick Todd", written over a horizontal line.

Employee Signature

A handwritten date "7/27/15" written in cursive script, positioned above a horizontal line.

Date



Quality Management System Conformance Statement

I Paul L. Berce, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.

Paul L. Berce
Employee Signature

2/17/16
Date



Quality Management System Conformance Statement

I Josh Muswieck, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.



Employee Signature

2-17-16
Date



Quality Management System Conformance Statement

I Steiglet Halley, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.



Employee Signature


2/25/16
Date



Quality Management System Conformance Statement

MICHAEL WALLACE

I , as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.


Employee Signature

5/23/16
Date



Quality Management System Conformance Statement

I Mauri Fabio, as an employee of Montrose Air Quality Services, LLC (MAQS), sign this Quality Management System Conformance Statement to verify that I have read and understand the requirements set forth in the MAQS Quality Policy Statement and in the MAQS Quality Manual. Furthermore, I understand my role in the company as it pertains to the Quality Management System.

A handwritten signature in black ink, appearing to read "Mauri Fabio", written over a horizontal line.

Employee Signature

A handwritten date "5/17/2016" written in black ink over a horizontal line.

Date

Personnel Qualifications



**JASON T. FRENCH, QSTI
PROJECT MANAGER**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Qualified Source Test Individual (QSTI) Application #2013-771
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gas Source Sampling Methods*
 - Group III, *Gaseous Pollutants Instrumental Methods*
 - Group IV, *Hazardous Metals Measurements*
- B.S. in Mechanical Engineering from the University of South Florida in Tampa, Florida, 2004
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Certified Visible Emissions Evaluator
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)

PROFESSIONAL EXPERIENCE

Jason French joined Horizon Engineering in February 2011. His previous experience includes working for 5 years as a staff engineer with an environmental and construction company based in Tallahassee, Florida as well as working for the Florida Department of Environmental Protection. He performs source emission testing and related activities, including writing quotes and source test protocols, field sampling, test equipment maintenance and calibration, equipment preparation, in-field data recording, calculations and training. He is thoroughly trained in all EPA source testing procedures and also experienced using methods from the National Council for Air & Stream Improvement (NCASI), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), American Society for Testing and Materials (ASTM) and many regional (Pacific Northwest and Northern California) agency methods.

**JOHN S. LEWIS, QSTI (GI, II, IV)
FIELD TECHNICIAN II**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Qualified Source Test Individual (QSTI)
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gaseous Pollutants Source Sampling Methods*
 - Group IV, *Hazardous Metals Measurements*
- B.S. in Social Science and Geography from Frostburg State University, 1998
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)

PROFESSIONAL EXPERIENCE

John Lewis has been with Horizon Engineering since 2008. He brings six years of prior experience working in education, transportation, and roof restoration system installation. He has performed source tests at hundreds of industrial sources. He performs source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is thoroughly trained in all EPA source test procedures 2008-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**JOSEPH M. HEFFERNAN III, QSTI (GI-IV)
PROJECT MANAGER/TEAM LEADER**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Qualified Source Test Individual (QSTI)
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gas Source Sampling Methods*
 - Group III, *Gaseous Pollutants Instrumental Methods*
 - Group IV, *Hazardous Metals Measurements*
- B.S. in Physical Education from Northern Illinois University, 1999
- Minor in Marketing, with emphasis in Sports Marketing
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL DEVELOPMENT

- Stationary Source Sampling and Analysis for Air Pollutants (SSSAAP) Conference, 2008, 2011

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)

PROFESSIONAL EXPERIENCE

Joe Heffernan has been with Horizon Engineering since 2004. He brings four prior years experience from another air pollution testing organization in Illinois for a total of more than 12 years of professional experience in the field of air quality. He has performed source tests at hundreds of industrial sources domestically and internationally and has developed the skills necessary to earn the title of Project Manager. He performs source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is thoroughly trained in all EPA source test procedures 2000-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

Chris Hinson, E.I.T., QSTI (GI-IV)
PROJECT MANAGER

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Qualified Source Test Individual (QSTI)
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gas Source Sampling Methods*
 - Group III, *Gaseous Pollutants Instrumental Sampling Methods*
 - Group IV, *Hazardous Metals Measurement Sampling Methods*
- Engineer in Training (E.I.T.) Certification
- Bachelors of Science, Nuclear Engineering, 2012 – Purdue University
- Certified Visible Emissions Evaluator
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL EXPERIENCE

Chris Hinson has been with Horizon Engineering, LLC since 2014. He has performed source tests at hundreds of industrial sources. He performs source emission testing and activities related to source emission testing, including field sampling, laboratory analysis, test equipment maintenance and calibration, equipment preparation, in-field data recording and calculations. Chris has performed greenhouse gas testing and monitoring at many different facilities. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**MIHAI VOIVOD
FIELD TECHNICIAN II****EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING**

- Qualified Individual (QI)
 - Group II, *Manual Gas Source Sampling Methods*, (passed exam, application pending)
- B.S. in Biotechnical and Ecological Systems Engineering from Babes Bolyai University in Cluj, Romania, 2009
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL EXPERIENCE

Mihai Voivod has been with Horizon Engineering since September 2012. He brings 3 years of prior professional experience in the electronics manufacturing industry working for Silicon Forest Electronics in Vancouver, Washington and during an internship at a Romanian laboratory. At Horizon, he performs source emission testing and activities related to source emission testing, including field sampling, test equipment fabrication, maintenance, and calibration, equipment preparation, and in-field data recording. He is being trained to perform all EPA source test procedures and is also learning methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

His experience in the electronics manufacturing industry included operating a selective solder machine and an automated optical inspection (AOI) machine. His education specialty was laboratory sampling analysis and instrumentation operation and troubleshooting.

**BRANDON CRAWFORD
FIELD TECHNICIAN I**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- B.S. in Environmental Science from Oregon State University, Corvallis, Oregon, 2013, Specialized in Environmental Conservation and Sustainability
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- DOT dangerous goods ground shipping training
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL EXPERIENCE

Brandon Crawford has been with Horizon Engineering since June 2014. He brings previous industrial experience as an intern for ATI Albany Operations/Wah Chang. He is being trained to perform source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is being trained in all EPA source test procedures 2002-present. He is also learning to use methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**BRETT SHERWOOD
FIELD TECHNICIAN I****EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING**

- B.S. in Environmental Science from Washington State University, Pullman, Washington, 2012
- Certificate in Geographic Information Systems, University of Washington, 2013
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL EXPERIENCE

Brett Sherwood has been with Horizon Engineering, LLC since June 2014. His previous experience included survey work performing APS surveying and mapping, working as an environmental technician for the King County Department of Natural Resources and Parks performing surface and groundwater sampling, and working as a technician with the State of Washington Department of Fish and Wildlife ocean sampling program. He is being trained to perform source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is receiving training in all EPA source test procedures from 2002 to present. He is also learning to use methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

PATRICK A. TODD
SHOP STEWARD/FIELD TECHNICIAN

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Working towards Associates of Facility Maintenance Technology at Portland Community College
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL EXPERIENCE

Patrick Todd has been with Horizon Engineering since 2009. He is the shop steward and equipment maintenance expert. He performs source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is thoroughly trained in all EPA source test procedures 2009-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

Josh Muswieck
FIELD TECHNICIAN I

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- B.S. in Environmental Science, Oregon Institute of Technology, Klamath Falls, Or 2015
- Opacity & Visual Emissions Certified (EPA Method 9)
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protections, MSDS review, toxic and hazardous substances)
- DOT Medical Card
- Transportation Worker Identification Credential (TWIC) approved
- Respirator Fit-Tested
- Red Cross First Aid & CPR Certified
- Aerial Boom/Scissor Lift Certified Operator

PROFESSIONAL EXPERIENCE

Josh Muswieck joined Horizon Engineering in 2016. He has previous work experience as a Biological Science Technician for the USGS and Research Assistant for Oregon Tech Environmental Science Department. He is receiving training in all EPA source test procedures and is also learning to use methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**PAUL LAWAI'A BERCE
FIELD TECHNICIAN I**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- B.S. in Environmental Science from Oregon State University, Corvallis, Oregon, 2015
- C-Stop certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- DOT Medical Card
- Transportation Worker Identification Credential (TWIC) approved
- Respirator fit tested
- Lift equipment operator certified

PROFESSIONAL EXPERIENCE

Paul Berce has been with Montrose Air Quality Service since February 2016. His previous experience included work as an invasive species eradication Field Associate 1 for the Maui Invasive Species Committee, a non-profit, community and county funded organization on Maui, Hawaii. There, he led field crews on eradication and containment of target plant and animal species through survey methodologies and point source treatment. He was trained in the proper identification/handling of chemicals (pesticides and herbicides) and their responsible and proper application. He is receiving training in all EPA source test procedures and is learning to use methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**SLEIGHT HALLEY
FIELD TECHNICIAN I****EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING**

- B.S. in Chemistry from Carroll College, Helena, Montana, 2012
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- DOT Medical Card
- Transportation Worker Identification Credential (TWIC) Approved

PROFESSIONAL EXPERIENCE

Sleight Halley has been with Horizon Engineering since January, 2016. His previous experience included work as an analytical chemist with Analytical 360 LLC in Yakima, Washington. He is receiving training in all EPA source test procedures and is also learning to use methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

THOMAS A. RHODES, E.I.T., QSTI (GI-IV)
DISTRICT MANAGER

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Qualified Source Test Individual (QSTI)
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gaseous Pollutants Source Sampling Methods*
 - Group III, *Gaseous Pollutants Instrumental Methods*
 - Group IV, *Hazardous Metals Measurements*
- Engineer in Training (E.I.T.) Certification, 2001
- B.S. in Chemical Engineering from University of California in Santa Barbara, 2001
- Attended Allan Hancock College in Santa Maria, California, 1996-1998
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- North Slope Training Co-operative class for Unescorted North Slope Safety Orientation (Awareness Level)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL DEVELOPMENT

- Stationary Source Sampling and Analysis for Air Pollutants (SSSAAP) Conference, 2008

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)
- American Chemical Society (ACS)

PROFESSIONAL EXPERIENCE

Thomas Rhodes has been with Horizon Engineering since 2002. He brings three prior years experience as an engineering associate and engineering intern for several companies. He has performed source tests at hundreds of industrial sources. He performs source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, and in-field data recording. He is thoroughly trained in all EPA source test procedures 2002-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**MICHAEL E. WALLACE, P.E.
SENIOR ENGINEER**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Professional Engineer (P.E.) from the State of Oregon, 2002-present
- B.S. in Mechanical Engineering from Oregon State University in Corvallis, Oregon, 1989
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL DEVELOPMENT

- Stationary Source Sampling and Analysis for Air Pollutants (SSSAAP) Conference, approximately 5 years

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)

PROFESSIONAL EXPERIENCE

Mike Wallace has been with Horizon Engineering since 1991. He is responsible for performing calculations, formulating spreadsheets, quality assurance review, and operating Horizon's gas chromatograph. He is thoroughly trained in all EPA source test procedures 1991-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**ANDY VELLA, P.E., QSTI (GI-IV)
ENGINEER
TECHNICAL WRITER**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- Professional Engineer (P.E.) Oregon license #87091PE
- Qualified Source Test Individual (QSTI)
 - Group I, *Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods*
 - Group II, *Manual Gas Source Sampling Methods*
 - Group III, *Gaseous Pollutants Instrumental Sampling Methods*
 - Group IV, *Hazardous Metals Measurement Sampling Methods*
- B.S. in Chemical Engineering from University of Illinois in Urbana, IL, 2005
- Minor in Mathematics
- Certified Visible Emissions Evaluator
- C-Stop Certified (includes refinery operations, industrial accident prevention, PPE, LOTO, HAZCOM/HAZMAT, confined space, emergency response, respiratory protection, MSDS review, toxic and hazardous substances)
- Aerial Platform Certified
- Transportation Worker Identification Credential (TWIC) Approved
- International Air Transport Association (IATA) Trained
- Respirator Fit-Tested
- Adult CPR Certified
- Standard First Aid Certified

PROFESSIONAL MEMBERSHIPS

- Source Evaluation Society (SES)

PROFESSIONAL EXPERIENCE

Andras Vella has been with Horizon Engineering since 2011. He brings six prior years experience from Clean Air Engineering in Illinois. His primary duty before joining Horizon was FTIR repair, operation, and data review. He has performed source tests at hundreds of industrial sources. He performs source emission testing and activities related to source emission testing, including field sampling, test equipment maintenance and calibration, equipment preparation, in-field data recording, data reduction and analysis, quality assurance review and report preparation. He is thoroughly trained in all EPA source test procedures 2005-present. He is also experienced using methods from the National Council for Air & Stream Improvement (NCASI), Oregon Department of Environmental Quality (ODEQ), California Air Resource Board (CARB), National Institute for Occupational Health and Safety (NIOSH), Occupational Safety and Health Administration (OSHA), and the American Society for Testing and Materials (ASTM).

**MAURI FABIO
TECHNICAL REPORT WRITER**

EDUCATION/PROFESSIONAL CERTIFICATIONS/TRAINING

- B.A. in Geology from University of Hawaii at Manoa in Honolulu, HI, 2011
- Certified Visible Emissions Evaluator
- Adult CPR Certified
- Standard First Aid Certified


PROFESSIONAL EXPERIENCE

Mauri Fabio joined Horizon Engineering in 2016. Her current responsibilities include data reduction and analysis, quality assurance review, and report preparation. She has a year experience with the United States Geological Survey (USGS) with laboratory analysis, data collection and processing, testing, field research, report preparation, and mapping preparation. She has experience with laboratory instrumentation such as a scanning electron microscopy (SEM) and energy dispersive x-ray microanalysis (EDS). Field work and data collection in Death Valley and worked with the deformation group at the USGS on Mt. Hood for reconnoitering potential sites for remote instrumentation.

**Total Chromium & Hexavalent Chromium Data
Collection**

Description of Total Chromium & Hexavalent
Chromium Testing

Raw Analytical Test Results for Cr & Cr⁺⁶
Field Data Sheets Relating to Cr & Cr⁺⁶ Testing



Total Chromium and Hexavalent Chromium Data Collection

The source testing of Glass Furnace T7 and Baghouse BH-1 on April 26-29, 2016 included testing of total chromium and chromium VI per EPA Method 0061. The purpose of this testing was to establish a maximum allowable chromium III usage rate based on potential chromium VI emissions pursuant to temporary rules provided in OAR 340-244-9040.

Bullseye is not proposing to use the April 26-29, 2016 Method 0061 testing to establish a maximum allowable chromium III usage rate. The preliminary data received and a subsequent evaluation of the operating parameters during the test indicate the data is inconclusive and is not representative of past or future operating conditions.

Analytical data for total chromium and chromium VI and field data collected during the testing is included in this report. The data shows significant variation of potential chromium emissions across the three test runs indicating inconclusive results. In addition, chromium VI was detected in most of the samples at concentrations above the total chromium results indicating potential interference.

Further, in order to lower the furnace exhaust gas temperatures to protect the Teflon probes required by Method 0061, ambient air was introduced into the furnace exhaust stream prior to entering the baghouse. Introducing ambient air into the furnace exhaust likely influenced the detected levels of chromium VI during the test. The furnace exhaust configuration combined with the ambient air cooling methods used during the source test is not representative of past or future source operation planned at the facility and Bullseye is not requesting that DEQ approve a chromium usage rate based on these results. If Bullseye seeks a future maximum chromium III usage rate pursuant to the procedures described in OAR 340-244-9040, a new source test plan will be submitted to DEQ for review and approval.

HORIZON ENGINEERING

PROJECT: 57202-BULLSEYE GLASS

CLIENT # H007

REPORT # 16-271

SUBMITTED BY:

CHESTER LabNet

12242 S.W. GARDEN PLACE

TIGARD, OR 97223

(503)624-2183/FAX (503)624-2653

www.ChesterLab.Net

CHESTER LabNet

12242 SW Garden Place ❖ Tigard, OR 97223-8246 ❖ USA
Telephone 503-624-2183 ❖ Fax 503-624-2653 ❖ www.chesterlab.net

Case Narrative


Date: May 5, 2016

General Information

Client: Horizon Engineering
Client Number: H007
Report Number: 16-271
Sample Description: Impinger Trains
Sample Numbers: 16-S425 – 14-S447

Analysis

Analytes: Cr VI, Total Cr
Analytical Protocols: SW-846 Method 0061
Analytical Notes: IC-PCR was used to measure hexavalent chromium and ICP was used to measure total chromium. The filter and probe rinse samples were digested per EPA method 29 and taken to 250 mL prior to analysis by ICP. Results have not been blank corrected.
QA/QC Review: All of the data have been reviewed by the analysts performing the analyses and the project manager. All of the quality control and sample-specific information in this package is complete and meets or exceeds the minimum requirements for acceptability.
Comments: If you have any questions or concerns regarding this analysis, please feel free to contact the project manager.
Disclaimer: This report shall not be reproduced, except in full, without the written approval of the laboratory. The results only represent that of the samples as received into the laboratory.


Project Manager Date
Paul Duda 5/5/16

Client: H007 - Horizon Engineering
Report Number: 16-271

238

Lab ID: 16-S425
Client ID: 1A Teflon Filter Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	32.4	0.500	8.11	0.125

Lab ID: 16-S426
Client ID: 1A HNO3 Rinse Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	45.8	0.500	11.5	0.125

Lab ID: 16-S427
Client ID: 1A KOH Imp Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 500. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	1040	0.020	518.	0.010
Total Cr	1070	0.500	536.	0.250

Lab ID: 16-S428
Client ID: 1B Teflon Filter Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	82.0	0.500	20.5	0.125

Lab ID: 16-S429
Client ID: 1B HNO3 Rinse Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	16.7	0.500	4.17	0.125

Client: H007 - Horizon Engineering
Report Number: 16-271

239

Lab ID: 16-S430
Client ID: 1B KOH Imp Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 460. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	559.	0.020	257.	0.009
Total Cr	549.	0.500	253.	0.230

Lab ID: 16-S431
Client ID: 1C Teflon Filter Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	35.1	0.500	8.78	0.125

Lab ID: 16-S432
Client ID: 1C HNO3 Rinse Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	18.3	0.500	4.57	0.125

Lab ID: 16-S433
Client ID: 1C KOH Imp Inlet
Site: Bullseye Glass
Sample Date: 4/27/16
Sample Volume: 485. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	2050	0.020	994.	0.010
Total Cr	1990	0.500	964.	0.242

Lab ID: 16-S434
Client ID: 2 Teflon Filter Inlet
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	33.6	0.500	8.39	0.125

Client: H007 - Horizon Engineering
Report Number: 16-271

240

Lab ID: 16-S435
Client ID: 2 HNO3 Rinse Inlet
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	8.04	0.500	2.01	0.125

Lab ID: 16-S436
Client ID: 2 KOH Imp Inlet
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 480. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	2160	0.020	1,030	0.010
Total Cr	2020	0.500	972.	0.240

Lab ID: 16-S437
Client ID: 3 Teflon Filter Inlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	36.9	0.500	9.22	0.125

Lab ID: 16-S438
Client ID: 3 HNO3 Rinse Inlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	2.74	0.500	0.684	0.125

Lab ID: 16-S439
Client ID: 3 KOH Imp Inlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 545. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	790.	0.020	431.	0.011
Total Cr	790.	0.500	431.	0.272

Client: H007 - Horizon Engineering
Report Number: 16-271

241

Lab ID: 16-S440
Client ID: 3 Teflon Filter Outlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	26.1	0.500	6.52	0.125

Lab ID: 16-S441
Client ID: 3 HNO3 Rinse Outlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	1.10	0.500	0.276	0.125

Lab ID: 16-S442
Client ID: 3 KOH Imp Outlet
Site: Bullseye Glass
Sample Date: 4/29/16
Sample Volume: 485. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	205.	0.020	99.4	0.010
Total Cr	198.	0.500	95.8	0.242

Lab ID: 16-S443
Client ID: Filter Blank #1
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	< MDL	0.500	< MDL	0.125

Lab ID: 16-S444
Client ID: Filter Blank #2
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	< MDL	0.500	< MDL	0.125

Client: H007 - Horizon Engineering
Report Number: 16-271

242

Lab ID: 16-S445
Client ID: H2O Blank
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	< MDL	0.500	< MDL	0.125

Lab ID: 16-S446
Client ID: 0.1N HNO3 Blank
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 250. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Total Cr	< MDL	0.500	< MDL	0.125

Lab ID: 16-S447
Client ID: KOH Blank
Site: Bullseye Glass
Sample Date: 4/28/16
Sample Volume: 790. mL

Analyte	µg/L		µg/sample	
	Conc.	MDL	Conc.	MDL
Cr VI	1.06	0.020	0.837	0.016
Total Cr	0.843	0.500	0.666	0.395

QA/QC Report

Client Name: Horizon Engineering
 Project Number: H007
 Analytical Technique: ICP - Optima 8300
 Sample Description: SW-846 0061 filter and probe rinse
 Report Number: 16-271
 =====

Blank Data

Analyte	Sample ID	Measured Conc. µg/L	MDL Conc. µg/L
Cr	ICB	< MDL	0.500
Cr	Prep_Blk	< MDL	0.500
Cr	CCB	< MDL	0.500
Cr	CCB	< MDL	0.500
Cr	CCB	< MDL	0.500

*: Method Blank concentration in µg/filter

Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cr	ICV	2500	2510	100.3
Cr	CRI	2.50	2.74	109.6
Cr	CCV	2500	2420	96.7
Cr	CCV	2500	2450	98.0
Cr	CCV	2500	2380	95.4
Cr	CCV	2500	2320	92.8

CRI Limits: 70% - 130% Recovery

Replicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
Cr	16-S425	32.45	34.73	6.79
Cr	16-S426	45.84	45.12	1.58
Cr	16-S440	26.07	26.78	2.69
Cr	16-S441	1.105	0.820	29.6 #

RPD = $\frac{(\text{sample} - \text{replicate})}{[(\text{sample} + \text{replicate})/2]} \times 100$

N/C: RPD is not calculated when sample or replicate is below detection limit

#: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

Laboratory Control Sample/Matrix Post Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Cr	16-S428	82.05	2451.	2500.	94.8
Cr	16-S429	16.68	2374.	2500.	94.3
Cr	16-S440	26.07	2461.	2500.	97.4
Cr	16-S441	1.105	2376.	2500.	95.0

Percent Recovery = $\frac{(\text{spike} - \text{sample})}{\text{spike amount}} \times 100$

*: per EPA CLP protocol, control limits do not apply if spike concentration is less than 25% of the sample concentration

QA/QC Limits

Continuing Calibration: ± 10%

Duplicates: 20% RPD

LCS: ± 20%

Spikes: ± 25%

QA/QC Report

Client Name: Horizon Engineering
 Project Number: H007
 Analytical Technique: IC-PCR
 Sample Description: SW-846 Method 0061 Impinger Catch
 Report Number: 16-271
 =====

Blank Data

Analyte	Sample ID	Measured Conc. µg/L	MDL Conc. µg/L
Cr VI	ICB	< MDL	0.020
Cr VI	CCB	< MDL	0.020

*: Method Blank concentration in µg/filter

Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cr VI	ICV	1.00	0.98	97.9
Cr VI	CCV	1.00	0.95	95.2

Duplicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
Cr VI	16-S427	1040	1010	2.64

RPD = $\frac{(\text{sample} - \text{duplicate})}{[(\text{sample} + \text{duplicate}) / 2]} \times 100$

N/C: RPD is not calculated when sample or duplicate is below detection limit

#: per EPA CLP protocol, control limits do not apply if sample and/or duplicate concentration is less than 5x the detection limit

Laboratory Control Sample/Matrix Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Cr VI	16-S439	790.	1810	1000	102.

*: per EPA CLP protocol, control limits do not apply if spike concentration is less than 25% of the sample concentration

QA/QC Limits

Continuing Calibration: ± 10%

Replicates: ± 20% RPD

LCS: ± 20%

Post Spikes: ± 25%

QA/QC Report

Client Name: Horizon Engineering
 Project Number: H007
 Analytical Technique: ICP - Optima 8300
 Sample Description: SW-846 Method 0061 Impinger Catch
 Report Number: 16-271
 =====

Blank Data

Analyte	Sample ID	Measured Conc. µg/L	MDL Conc. µg/L
Cr	ICB	< MDL	0.500
Cr	CCB	< MDL	0.500

*: Method Blank concentration in µg/filter

Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cr	ICV	2500	2480	99.4
Cr	CRI	2.50	2.55	102.2
Cr	CCV	2500	2510	100.5

CRI Limits: 70% - 130% Recovery

Duplicate Data

Analyte	Sample ID	Sample Conc. µg/L	Duplicate Conc. µg/L	RPD
Cr	16-S427	1071.	1075.	0.37

RPD = $\frac{(\text{sample} - \text{duplicate})}{[(\text{sample} + \text{duplicate}) / 2]} \times 100$

N/C: RPD is not calculated when sample or duplicate is below detection limit

#: per EPA CLP protocol, control limits do not apply if sample and/or duplicate concentration is less than 5x the detection limit

Laboratory Control Sample/Matrix Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Cr	16-S430	549.3	2821.	2500.	90.9

*: per EPA CLP protocol, control limits do not apply if spike concentration is less than 25% of the sample concentration

QA/QC Limits

Continuing Calibration: ± 10%
 Duplicates: 20% RPD

LCS: ± 20%
 Spikes: ± 25%

CHESTER LABNET
SOURCE SAMPLE RECEIPT CHECKLIST

Client Horizon

Date 5/2/16

Runs 6 + BIKs

Report # _____

Custody Seals Inspected, If Present

NA

Chain-of-Custody Form Inspected

CoC present with samples?

✓

CoC indicate analytical methodology to be used? (eg M29 etc)

✓ *

CoC indicate if compliance testing? (esp. M26)

✓ !!

M26 samples have Thiosulfate added in field?

Not stated !!

M29 indicate FH/BH separate or combined?

NA !!

Has Form Been Signed?

NA !!

Have Date and Time Custody Released Been Noted on Form?

✓

✓

All Sample Containers Inspected

Does Number of Samples Match Number on CoC Form?

✓

Do All Sample ID Numbers Match Those on the CoC Form?

✓ !!

Did client mark sample volumes prior to shipment?

✓ !!

If required by method, did client vent samples prior to shipment?

✓ *

Are the Sample Containers Intact?

NA

Are signs of leakage present?

✓ !!

NO *

Chain-of-Custody Form Signed and Dated by CLN

✓

Corrective Actions

Client Contacted Due to Mismatching Sample ID Numbers

Client Contacted Due to Broken Sample Container(s)

Client Contacted Due to Leaking Sample Container(s)

Client contacted for verification of methodology?

Corrective Actions Documented?

Corrective Actions Accomplished?

~~✓~~

~~✓~~

~~✓~~

~~✓~~

~~✓~~

~~✓~~

Items marked !! shall be addressed prior to any analytical work being started.

Items marked * shall be noted in case narrative upon reporting of results to client.

Signed Lin Ball

Notes _____

Company Name <i>Horizon Eng.</i>		
Contact <i>Thomas Rhodes</i>	Phone <i>503-255-6050</i>	
E-Mail Address <i>+rhodes@montrose-env.com</i>	Fax	
Report Address <i>13585 NE Whitaker Way</i>		
City <i>Portland</i>	State <i>OR</i>	Zip <i>97230</i>
Billing Address <i>Same</i>		
City	State	Zip
PO #	Project <i>57202 - Bullseye Glades</i>	

CHESTER LabNet
 12242 SW Garden Place
 Tigard, OR 97223
 (503) 624-2183
 Fax (503) 624-2653
 cln@chesterlab.net

CHAIN-OF-CUSTODY RECORD

Analysis Requested							
							Turn Around Time <input type="checkbox"/> Standard <input checked="" type="checkbox"/> Rush <u>ASAP</u> Specify

LabNet ID	Field Sample ID	Site	Sample Date	Volume (m³)	Particle Size	Remarks
16-5425	1A teflon filter	Inlet	4/27/16	—	—	
426	1A HNO ₃ Rinse	Inlet	"	—	—	
427	1A KOH Imp.	Inlet	"	—	—	
428, 429, 430	1B (Same as 1A)	Inlet	"	—	—	3 samples
431, 432, 433	1C (Same as 1A)	Inlet	"	—	—	3 samples
434, 435, 436	2 (Same as 1A)	Inlet	4/28/16	—	—	3 samples
437, 438, 439	3 (Same as 1A)	Inlet	4/28/16	—	—	3 samples
440, 441, 442	3 (Same as 1A)	Outlet	4/29/16	—	—	3 samples
16-5445	H ₂ O Blank	—	4/28/16	—	—	
5446	0.1 N HNO ₃ Blank	—	4/28/16	—	—	
5447	KOH Blank	—	4/28/16	—	—	
443, 444	Filter Blanks (x2)	—	4/28/16	—	—	Total Samples: 2 samples

SEE NOTES

Relinquished By: (Signature) Date/Time <i>[Signature]</i> 5/2/16	Received By: (Signature) Date/Time <i>[Signature]</i> 5/2/16	Notes: Total Samples: 23 EPA 006! Analysis on ALL samples for Cr ⁶⁺ & Total Cr
Relinquished By: (Signature) Date/Time <i>[Signature]</i> 5-2-16 13:35	Received By: (Signature) Date/Time <i>[Signature]</i> 5-2-16 13:40	

HORIZON ENGINEERING 16-5702

247
Total Cr

RAW DATA

Available upon request

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

PAGE 1 OF 4
Glass Nozzle Measurements
1 3100
2 3100 } 3103
3 3110

Client: Bullseye Glass
Facility Location: Portland, OR
Source: Furnace T-7
Sample Location: Inlet of Baghouse

Date 4/26/16
Test Method OCG1
Concurrent Testing OBEQ S
Run # 1

Probe 2-2 (G/S) Cp 8364 Heat Set - °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0@6 Post @
in H2O@in H2O Lo 0@6 @

Operator Sdmk Support Joe H.
Temperature, Ambient (Ta) 83°F
Moisture ~1090 Tdb - Twb -
Press., Static (Pstat) 30 Press., Bar (Ph) 29.96
Cyclonic Flow Expected? NO If yes, avg. null angle degrees

ALT-011
Std TC (ID/F) 3L/83
Stack TC (ID/F) 2-2/83
Continuity Check or ↓

Nozzle 3107/3103 Oven - Imp. Outlet 1-35
Filter - Heat Set - °F
Meter Box 2 dH@ 1.97675 Y 0.99949
Meter Pretest: .005 cfm 15 inHg
Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading out (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)	
							T (Ts)	T (Tp)	T (To)	T (Ti)	Inlet Avg. T (Tm-in)	Outlet T (Tm-out)		
		1730	363.109											
1	12	10	365.29	.020	.169	.17	172				67	82	82	4
2	11	20		.115	.989	.99	119				67	82	81	4
3	10	30	374.61	.080	.694	.69	112				61	86	81	4
4	9	40	377.38	.032	.268	.27	138				60	90	82	3
5	8	50	380.67	.050	.419	.42	187				63	89	83	3
6	7	60	383.96	.046	.373	.37	161				62	92	84	3
7	6	70	385.935	.016	.132	.13	151				62	93	85	2
8	5	80	389	.051	.383	.38	212				64	91	87	3
9	4	90	392.45	.050	.375	.38	215				63	94	89	3
10	3	100	394.80	.013	.097	.10	215				60	96	89	2
11	2	110	397.00	.023	.180	.18	186				63	96	89	2
12	1	120	399.88	.033	.278	.28	141				63	95	91	3
13	1	130	406.01	.181	1.37	1.4	209				61	97	91	5
14	2	140	409.38	.033	.245	.25	227				56	91	92	3
15	3	150	413.84	.106	.781	.78	232				58	98	92	5
16	4	160	417.96	.075	.558	.56	227				59	102	92	4
17	5	170		.045	.350	.35	193				61	101	93	3
18	6	180	424.05	.044	.342	.34	193				63	99	92	3
19	7	190	426.89	.030	.248	.25	153				63	98	93	3
20	8	200	429.03	.019	.145	.15	204				63	96	93	3
21	9	210	431.11	.019	.139	.14	236				64	95	92	3
22	10	220	433.22	.021	.162	.16	195				65	95	92	3
23	11	230	435.651	.028	.216	.22	196				61	95	91	3
24	12	240	438.30	.029	.234	.23	165				51	94	91	3
25														

Notes:

1840 → Paused to check Ph, Resumed at 1850
2130 → Paused to check PHORZON ENGINEERING 16-5702

Revised by [Signature] 4/27/2016

B:\Shared files\Feld Data Sheets\Method 5_PDX-v1.pdf

Field Data Sheet

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

PAGE 2 OF 4

Client: Bullseye Glass
Facility Location: Portland, OR
Source: Furnace T-7
Sample Location: Inlet

Date 4/26/16
Test Method COCAL
Concurrent Testing DREQ 5
Run # 1

Glass Nozzle Measurements
1 3100
2 3100
3 3110
3103

Probe 2-2 (s) Cp, 8364 Heat Set - °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 6 Post 0 @ 5
in H2O@in H2O Lo 0 @ 6 0 @ 5

Operator John Support Joe H.
Temperature, Ambient (Ta) 74°F
Moisture 10% Tdb 229 Twb 114
Press., Static (Pstat) 30 Press., Bar (Pb) 29.9
Cyclonic Flow Expected? No If yes, avg. null angle - degrees

ALT-011
Std TC (ID/F) 3L/83
Stack TC (ID/F) 2-2/83
Continuity Check () or ()

Nozzle 3103 Oven - Imp. Outlet 1-35
Filter - Heat Set - °F
Meter Box 2 dH@1.97675 Y0.99949
Meter Pretest: .005 cfm 15 inHg
Leak Check Post: .010 cfm 12 inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (V _m)	Velocity Head in H ₂ O (dPa)	Orifice Pressure in H ₂ O DESIRED	Orifice Pressure H ₂ O ACTUAL (dPa)	STACK		PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg	METER Outlet	Pump Vacuum inHg (P _v)
							°F (Ta)	°F (Tp)	°F (To)	°F (T)	°F (Tm-in)	°F (Tm-out)		
1	12	250	438.30											
			2143	438.30										
1	12	250	441.02	.032	.266	.27	147				51	94	91	3
2	11	260		.039	.327	.363	143				51	95	90	3
3	10	270	447.59	.040	.370	.37	136				51	95	90	3
4	9	280	450.15	.022	.207	.21	127				51	96	91	3
5	8	290	453.12	.022	.183	.18	203				54	95	91	3
6	7	300	456.62	.041	.380	.38	120				66	89	87	3
7	6	310	460.15	.037	.425	.43	147				67	89	86	3
8	5	320	463.58	.049	.412	.41	180				66	90	86	3
9	4	330	466.73	.046	.361	.36	226				67	91	86	3
10	3	340	469.66	.040	.313	.31	227				65	91	85	3
11	2	350		.042	.331	.33	223				64	92	86	3
12	1	360	475.80	.043	.369	.37	169				62	93	87	3
13	1	370	480.26	.088	.757	.76	167				62	93	87	5
14	2	380	485.12	.094	.804	.80	172				60	95	87	4
15	3	390	489.875	.088	.760	.76	167				61	96	87	4
16	4	400	492.455	.023	.201	.20	161				60	96	87	3
17	5	410	494.97	.031	.257	.26	189				62	94	87	3
18	6	420	496.99	.019	.155	.16	201				63	92	88	3
19	7	430	499.381	.026	.226	.23	160				63	92	87	3
20	8	440	502.54	.040	.359	.36	141				62	91	88	3
21	9	450	505.561	.038	.335	.34	152				61	92	87	4
22	10	460	508.275	.029	.267	.27	125				61	93	87	4
23	11	470	510.80	.027	.251	.25	120				62	92	88	4
24	12	480	512.962	.018	.168	.17					63	92	87	3
25		490												

-6%

2225

Volume before resuming 450.697

Notes: 2225 -> At 282 min, 10 sec, paused to switch out trains
Volume 450.645
HORIZON ENGINEERING, INC. (503) 255-0707
B:\Shared files\field\Data Sheets\Method 5\Method 5_PDX-v1.pdf

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

PAGE 3 OF 84

Client: **HILLSIDE GLASS**
Facility Location: **PORTLAND OR**
Source: **FURNACE T7**
Sample Location: **INLET**

Date: **4/26/16 - 4/27/16**
Test Method: **0001**
Concurrent Testing: **M5**
Run #:

Glass Nozzle Measurements
1 .3100 } .3103
2 .3100 }
3 .3110 }

Probe: **2-2 @/s Cp .8364** Heat Set **→** °F
Post-Test Pitot Inspection (NC=no change, D=damaged)

Pitot Lk Rate Pre: Hi **0 @ 5** Post **@**
in H2O @ in H2O Lo **0 @ 5** @

Operator: **BC** Support: **JM, JF, BS**
Temperature, Ambient (Ta):

ALT-011
Std TC (ID/°F) **83° J2**
Stack TC (ID/°F) **83° 2-2**

Nozzle: **3103** Oven **→** Imp. Outlet **1-35**
Filter **→** Heat Set **→** °F

Moisture: **0%** Tdb Twb
Press., Static (Pstat) - **.30** Press., Bar (Pb) **29.9**

Continuity Check **⊙** or **↓**

Meter Box **2** dH@ **1.97675** Y0.99949
Meter Pretest: **0.006** cfm **15** inHg

Cyclonic Flow Expected? **N** If yes, avg. null angle **→** degrees

Meter Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading out (Vol)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump	
							°F (Ts)	°F (Tp)	Filter °F (To)	Outlet °F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)	Vacuum inHg (Pv)	
1	490	04:44	514.368	.034	.293	.29	156				62	81	79	3
2	500		519.443	.022	.189	.19	156				63	82	79	3
3	510		522.537	.039	.328	.33	173				60	84	79	3
4	520		524.533	.020	.172	.17	159				57	86	80	3
5	530		526.753	.023	.198	.20	160				56	87	80	3
6	540		529.358	.030	.258	.26	161				57	87	80	3
7	550		531.579	.026	.228	.23	149				58	87	81	3
8	560		533.648	.017	.146	*.15	162				57	86	81	2
9	570		536.757	.044	.367	.37	179				57	85	82	3
10	580		538.989	.022	.182	.18	184				56	86	81	3
11	590		541.114	.019	.168	.17	140				57	86	80	3
12	600		543.239	.018	.159	.16	142				56	85	82	3
13	610		545.363	.018	.158	.16	141				57	85	81	3
14	620	07:04	547.382	.017	.150	.15	143				56	86	81	3
15	630	07:10	549.625	.023	.200	.20	153				59	84	82	3
16	640		552.109	.0276	.238	.24	158				58	84	81	3
17	650		554.175	.020	.181	.18	129				57	85	82	3
18	660		556.566	.025	.224	.22	130				58	85	81	3
19	670		558.300	.015	.133	.13	140				58	86	82	3
20	680		559.973	.014	.122	.12	151				59	86	81	3
21	690		561.650	.015	.132	.13	149				60	87	82	3
22	700		563.749	.021	.185	.19	148				60	87	83	3
23	710		565.493	.015	.132	.13	150				61	86	82	3
24	720		567.165	.014	.123	.12	149				62	86	83	3
25	730		568.634	.012	.102	.10	170				62	87	83	3

Notes:

* LEAK CHECK / TRAIN CHANGE FROM 512.962 - 514.368

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

PAGE 4 OF 4
Glass Nozzle Measurements
1 } .310
2 } .310
3 } .310

Client: **BULLS-EYE GLASS**
Facility Location: **PORTLAND, OR**
Source: **FURNACE #3**
Sample Location: **#1 INLET**

Date: **4/26/16 - 4/27/16**
Test Method: **0801**
Concurrent Testing: **M5**
Run #: **1**

Probe: **2-2** (g/s) Cp: **83104** Heat Set: **—** °F
Post-Test Pitot Inspection: **(NC=no change, D=damaged)**
Pitot Lk Rate: Pre: Hi **0 @ 5** Post **0 @ 7**
in H2O@in H2O: **Lo 0 @ 5 0 @ 10**

Operator: **BC** Support: **JM, JF, BS**
Temperature, Ambient (Ta): **ALT-011**
Moisture: **6%** Tdb: Twb:
Press., Static (Pstat): **-.30** Press., Bar (Pb): **29.9**
Cyclonic Flow Expected? **N** If yes, avg. null angle: **—** degrees

Nozzle: **3103** Oven: **—** Imp. Outlet: **1-35**
Filter: **—** Heat Set: **—** °F
Meter Box: **2** dH@: **1.97675** **Y0.99949**
Meter: Pretest: **0.006** cfm **15** inHg
Leak Check: Post: **0.008** cfm **10** inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (TI)	°F (Tn-in)	°F (Tn-out)	
2	740		573.476	.017	.146	.15	161	/	/	61	87	84	3
3	750		572.584	.021	.182	.18	159	/	/	60	87	83	3
4	760	09:30	574.147	.020	.173	.17	158	/	/	58	87	84	3
5	770												
6	780												
7													
8													
9													
10													
11													
12													

Notes:

switched nozzles just before starting run

PAGE 1 of 4

Field Data Sheet

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Glass Nozzle Measurements
1 3100
2 3100
3 3110
2583 ← 2580
2580
2590

Client: Bullseye Glass
Facility Location: Portland, OR
Source: Furnace T-7
Sample Location: Inlet

Date 4/27/16
Test Method 0061
Concurrent Testing ODEQ 5
Run # 2

Probe 2-1 (g/s) Cp, 8248 Heat Set — °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 20 Post @
in H2O @ in H2O Lo 0 @ 12 @

Operator: Subh Support: Joe H.
Temperature, Ambient (Ta) 75°F
Moisture ~ 4% Tdb 202 Twb 105
Press., Static (Pstat) ~ 0.3 Press., Bar (Pb) 30.10

ALT-011
Std TC (ID/°F) 21/75
Stack TC (ID/°F) 21/74
Continuity Check () or 1

Nozzle 3103 Oven — Imp. Outlet 1-35
Filter — Heat Set — °F
Meter Box 2 dH@ 1,9765 X, 99949
Meter .001e7 Pretest: .012 cfm to inHg
Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK		PROBE		OVEN Filter		IMPINGER Outlet		METER Inlet/Avg		METER Outlet		Pump Vacuum inHg (Fv)	
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	°F (Tm-out)	°F (Tm-out)						
		1730	575.268																	
1	10			.036	.122	.12	141						67	78	78	2				
2	20		579.55	.053	.205	.21	147						62	80	78	2				
3	30		581.95	.055	.206	.21	166						59	81	78	2				
4	40		583.76	.031	.121	.12	197						57	84	79	2				
5	50		585.74	.040	.155	.16	203						58	84	80	2				
6	60		587.71	.035	.141	.14	182						56	86	82	2				
7	70			.040	.175	.18	129						56	87	83	2				
8	80		591.98	.038	.152	.15	186						56	88	84	2				
9	90		593.87	.033	.132	.13	188						56	89	84	2				
10	100		595.91	.036	.142	.14	195						58	89	85	2				
11	110		597.77	.033	.129	.13	204						56	89	86	2				
12	120		599.52	.030	.114	.11	226						57	89	85	2				
13	130		601.70	.044	.181	.18	169						58	88	85	2				
14	140		603.56	.035	.149	.15	149						55	89	86	2				
15	150	2000 2004	605.697 605.697	.035	.147	.15	159						57	89	85	2				
16	160		608.13	.045	.183	.18	176						54	88	85	2				
17	170		610.26	.034	.139	.14	173						55	89	85	2				
18	180		612.25	.036	.151	.15	161						56	89	86	2				
19	190		613.91	.022	.092	.09	160						56	90	86	2				
20	200		615.54	.023	.100	.10	134						58	90	86	2				
21	210			.023	.092	.09	188						58	90	86	2				
22	220		618.68	.021	.080	.08	218						58	89	86	2				
23	230		620.15	.020	.077	.08	217						58	89	86	2				
24	240	2134	621.77	.028	.107	.11	219						58	89	87	2				

changed nozzles


Notes: used the stack temp. of the ODEQ 5 for point #12 because the thermocouple was out of the stack.

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

* Paused at 150 min. to check the pH (2000)

Field Data Sheet

PAGE 2 of 4


 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Date 4/27/16
 Test Method 0061
 Concurrent Testing CDEFQ S
 Run # 2

Glass Nozzle Measurements

1 .2580
 2 .2580
 3 .2590

} **2583**

Client: Bullseye Glass
 Facility Location: Portland, OR
 Source: Furnace T-7
 Sample Location: Inlet

Probe 2221 (e/s) Cp, 8248 Heat Set - °F
 Post-Test Pitot Inspection (NC=no change, D=damaged)

Pitot Lk Rate Pre: Hi 0 @ 20 Post @
 in H2O @ in H2O Lo 0 @ 12 @

Operator Sohl Support Sie H
 Temperature, Ambient (Ta) 75°F
 Moisture ~3% Tdb 156 Twb 95
 Press., Static (Pstat) -0.3 Press., Bar (Pb) 30.1
 Cyclonic Flow Expected? NB If yes, avg. null angle - degrees

ALT-011
 Std TC (ID/°F) 32/75
 Stack TC (ID/°F) 2-1/74

Nozzle .2583 Oven - Imp. Outlet 1-35
 Filter - Heat Set - °F

Meter Box 2 dH @ 1.97675 Y 0.99949

Meter 001 @ 7 Pretest: 0.22 cfm @ 10 inHg
 Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (st)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vin)	Velocity Head in H2 (dPv)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	Inlet/Avg. °F (Tin-in)	Outlet °F (Tin-out)	
		2134	621.77				Amb:	Amb:	Amb:	Amb:	Amb:	Amb:	
1	250		623.74	.035	.139	.14	191			58	89	87	2
2	260	2156	625.73	.033	.143	.14	163			56	89	86	2
3	270	2159	627.97	.029	.126	.13	156			56	89	86	2
4	280		631	.023	.099	.10	167			52	89	86	2
5	290		631.50	.022	.093	.09	180			55	89	86	2
6	300	2241	633.14	.022	.090	.09	213			57	89	86	2
7	310	2310	634.58	.018	.071	.07	224			58	89	86	2
8	320		636.74	.038	.166	.17	156			60	85	85	2
9	330	2339	639.40	.055	.245	.25	144			56	85	85	2
10	340	2343	642.20	.058	.251	.25	162			52	86	83	2
11	350		644.81	.059	.245	.25	187			53	86	83	2
12	360	0009	647.37	.066	.265	.27	211			52	87	83	23
13	370		650.04	.064	.253	.25	221			51	87	83	3
14	380		652.71	.060	.235	.24	227			51	87	83	3
15	390		655.41	.065	.270	.27	188			53	87	83	3
16	400		657. -	.042	.185	.19	151			52	87	83	2
17	410		659.90	.044	.198	.20	137			54	87	83	2
18	420		661.77	.022	.098	.10	145			54	87	83	2
19	430		663.40	.021	.094	.09	139			56	87	83	2
20	440		664.885	.020	.0898	.09	139			56	87	83	2
21	450		666.186	.015	.062	.06	190			56	86	83	2
22	460		667.628	.022	.086	.09	209			57	86	83	2
23	470		668.985	.020	.079	.08	221			57	86	83	2
24	480	02109	670.246	.019	.079	.079	189			56	86	83	2
25					.08								

Notes on Back

Notes: 26.2 min. → paused to check pH (2157) (2156) Resumed at (2159)

HORIZON ENGINEERING 16-5702

More Notes on back


205... → Paused to allow plant personnel to purge (2241) → Resumed at (2310)

★ Paused ~~at~~ at 334 min, (2339) <Checking the ph again>
- Resumed at (2343)

255

Field Data Sheet

PAGE 3 of 4

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p>Glass Nozzle Measurements</p> <table style="width:100%;"> <tr> <td>1</td> <td>.2580</td> <td rowspan="3" style="font-size: 2em; vertical-align: middle;">}</td> <td rowspan="3" style="vertical-align: middle;">Teflon</td> </tr> <tr> <td>2</td> <td>.2580</td> </tr> <tr> <td>3</td> <td>.2590</td> </tr> </table>	1	.2580	}	Teflon	2	.2580	3	.2590	<p>Client: Bullseye Facility Location: Portland, OR Source: Furnace T-7 Sample Location: Inlet</p> <p>Probe 2-1 4-1 8-1 8-2 8-3 Heat Set — °F</p> <p>Post-Test Pitot Inspection (NC=no change, D=damaged)</p> <p>Pitot Lk Rate Pre: Hi 0 @ 20 Post @ in H2O @ in H2O Lo 0 @ 12 @</p> <p>Nozzle .2583 Oven — Imp. Outlet</p> <p>Filter — Heat Set — °F</p> <p>Meter Box 2 dH@ 1.97675 Y0.99949</p>
1	.2580	}	Teflon							
2	.2580									
3	.2590									

<p>Date 4/27/16 - 4/28/16</p> <p>Test Method 0061</p> <p>Concurrent Testing M5</p> <p>Run # 2</p>	<p>Operator <u>BC</u> Support <u>JM, JF, BS</u></p> <p>Temperature, Ambient (Ta) <u>ALT-011</u></p> <p>Moisture ~ 3% Tdb Twb</p> <p>Press., Static (Pstat) ~ 0.3 Press., Bar (Pb) 30.10</p> <p>Cyclonic Flow Expected? <u>N</u> If yes, avg. null angle — degrees</p>	<p>Std TC (ID/°F) <u>75° 2</u></p> <p>Stack TC (ID/°F) <u>74° 2-1</u></p> <p>Continuity Check <input checked="" type="radio"/> or ↓</p> <p>Meter Pretest: <u>01</u> cfm 7 inHg</p> <p>Leak Check Post: cfm inHg</p>
---	---	---

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vnd)	Velocity Head in H2O (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum	
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	inHg (Pv)	
		02:38	670 470246				Amb:	Amb:	Amb:	Amb:	Amb:	Amb:		
1	490		671.663	.017	.076	.08	138				56	82	83	2
2	500		673.173	.022	.098	.10	140				58	84	82	2
3	510		674.598	.021	.093	.09	143				56	84	81	2
4	520		675.813	.016	.073	.07	130				57	85	81	2
5	530		677.088	.017	.077	.08	133				57	84	82	2
6	540		678.319	.015	.067	.07	134				57	85	82	2
7	550		679.739	.021	.096	.10	127				58	85	82	2
8	560		681.490	.030	.132	.13	149				58	84	81	2
9	570		683.563	.036	.156	.16	156				58	85	81	2
10	580		685.064	.025	.108	.11	159				56	84	81	2
11	590		686.526	.022	.095	.10	160				57	84	81	2
12	600		688.095	.023	.100	.10	155				58	84	80	2
12	610		689.712	.022	.095	.10	161				57	84	81	2
11	620		691.371	.027	.117	.12	158				58	85	81	2
10	630		692.987	.026	.113	.11	159				58	85	82	2
9	640		694.599	.031	.133	.13	165				57	86	82	2
8	650		696.289	.030	.131	.13	153				57	84	81	2
7	660	05:30	697.900	.024	.105	.11	156				56	84	81	3
6	670	05:45	699.013	.016	.070	.07	149				58	82	79	3
5	680		700.240	.019	.084	.08	148				59	83	79	3
4	690		701.431	.015	.067	.07	140				60	84	80	3
3	700		702.445	.014	.063	.06	137				60	83	79	3
2	710		703.583	.015	.066	.07	145				60	83	80	3
1	720		704.724	.015	.067	.07	139				60	82	79	3
1	730		705.860	.013	.058	.06	142				61	82	79	3

★

Notes: ★ PAUSED for pH CHECK @ 05:30

Field Data Sheet

PAGE 1 of 4

MONTROSE
AIR QUALITY SERVICES
13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

- At 1735 did a wet bulb/dry bulb, Dry=205 wet=115 ~ 6.8%

Client: Bullseye Glass
Facility Location: Portland, OR.
Source: Furnace T-7
Sample Location: Inlet

Date: 4/28/16
Test Method: 0061
Concurrent Testing: ODEQ S
Run #: 3

Class Nozzle Measurements
1 2580
2 2580
3 2590
Teflon 2583

Probe 2-2 (4) Cp, 8364 Heat Set — °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 15 Post @
in H2O@in H2O Lo 0 @ 16 @

Operator: John Support: Joe H.
Temperature, Ambient (Ta): 86°F
Moisture ~ 3% Tdb — Twb —
Press., Static (Pstat) — 3 Press., Bar (Ph): 30.1
Cyclonic Flow Expected? NO If yes, avg. null angle — degrees

ALT-011
Std TC (ID/°F) 2 / 86°F
Stack TC (ID/°F) 2-2 / 86°F
Continuity Check () or ↓

Nozzle: 2583 Oven — Imp. Outlet 1-20
Filter — Heat Set — °F
Meter Box 2 dH@ 1,97673 Y 0,99949
Meter Prefest: 010 cfm 8 inHg
Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2O (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dPa)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum	
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tin-in)	°F (Tm-out)	inHg (Fv)	
		1700	727.156											
1	12	10	729.24	.039	.173	.17	151				66	85	84	2
2	11	20	731.36	.037	.163	.16	153				65	85	84	2
3	10	30	733.50	.041	.169	.17	197				65	86	84	2
4	9	40	735.48	.032	.131	.13	202				65	88	85	2
5	8	50	737.15	.021	.087	.09	198				64	90	87	2
6	7	60	738.82	.026	.102	.10	196				63	92	87	2
7	6	70	740.60	.025	.108	.11	153				62	93	89	2
8	5	80	742.26	.027	.102	.10	236				62	95	90	2
9	4	90	744.37	.043	.161	.16	249				63	95	91	2
10	3	100	746.19	.031	.116	.12	252				60	96	92	2
11	2	110	748.70	.061	.227	.23	256				62	97	93	3
12	1	120	751.60	.067	.282	.28	187				58	98	93	3
13	1	130	754.63	.071	.305	.31	174				56	100	94	3
14	2	140	757.35	.062	.245	.25	242				56	100	95	3
15	3	150	1930	.072	.279	.28	253				58	100	95	3
16	4	160	762.41	.038	.146	.15	262				55	100	95	3
17	5	170	764.71	.046	.180	.18	252				57	99	95	3
18	6	180	766.70	.030	.119	.12	243				56	98	95	2
19	7	190	768.72	.030	.137	.14	149				57	98	95	3
20	8	200	770.68	.030	.139	.14	138				58	97	95	3
21	9	210	772.19	.019	.081	.08	189				57	97	95	2
22	10	220	773.70	.020	.081	.08	223				60	97	94	2
23	11	230	2050 2118	.021	.082	.08	253				61	96	93	3
24	12	240	2128	.054	.226	.23	201				66	94	93	3
25														

Did a wet bulb/dry bulb on 4/28/16
 wet = 115 ~ 6.8%
 dry = 205
 →

52
 4/28/16

Notes: * Paused at 2050 to allow plant personnel to purge. (230 min. of run time) (Also checked the ph at this time)
 B:\Shared files\field\Data Sheets\Method 5\Method 5_PDX-v1.pdf - Resumed testing at 2118
 HORIZON ENGINEERING 16-5702

Field Data Sheet

PAGE 2 of 4

HORIZON ENGINEERING
 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Client: Bullsege Glass
 Facility Location: PostHwy, OR.
 Source: Furnace T-7
 Sample Location: Inlet

Date 4/28/16
 Test Method OOG1
 Concurrent Testing ODEQ 5
 Run # 3

Glass Nozzle Measurements
 1 .2580
 2 .2580
 3 .2590
 Tefflow 2583

Probe 2-2 (4+5) Cp .8364 Heat Set - °F
 Post-Test Pitot Inspection (NC=no change, D=damaged)
 Pitot Lk Rate Pre: Hi @ 15 Post @
 in H2O@in H2O Lo @ 16 @

Operator John L. Support Joe H.
 Temperature, Ambient (Ta) 76°F
 Moisture ~ 3% Tdb ~ Twb ~
 Press., Static (Pstat) ~ 0.3 Press., Bar (Pb) 30.10
 Cyclonic Flow Expected? NO If yes, avg. null angle - degrees

ALT-011 Glass Nozzle: 2583 Oven - Imp. Outlet 1-20
 Std TC (ID/°F) 2-2/86°F
 Stack TC (ID/°F) 2-2/86°F
 Filter - Heat Set - °F
 Meter Box 2 dH@ 1.97675 YO.99949

Meter Prefest: .010 cfm 8 inHg
 Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER Inlet/Avg	METER Outlet	Pump Vacuum	
							°F (Ts)	°F (Tp)	°F (To)	°F (Fi)	°F (Tm-in)	°F (Tm-out)	inHg (Fv)	
		2128	778.23											
1	250		780.55	.046	.195	.20	191				57	93	92	3
2	260		782.86	.040	.181	.18	152				57	94	91	3
3	270		784.71	.028	.119	.12	192				56	94	91	2
4	280		786.19	.023	.094	.09	215				59	93	91	2
5	290		787.61	.013	.053	.05	209				61	93	91	2
6	300		788.97	.020	.079	.08	233				64	93	91	3
7	310		790.70	.024	.098	.10	212				61	93	91	3
8	320		792.96	.042	.181	.18	182				58	94	91	4
9	330		795.74	.061	.270	.27	165				53	95	92	4
10	340			.069	.309	.31	158				50	96	91	4
11	350	2327	801.78	.074	.326	.33	169				50	96	91	5
12	360	2331	804.82	.081	.351	.35	179				49	96	92	5
13	370	2332	807.65	.068	.276	.28	222				53	95	92	5
14	380		810.50	.075	.300	.30	232				50	95	92	7.9
15	390		812.82	.047	.186	.19	240				49	95	92	6
16	400		815.24	.051	.215	.22	194				52	94	91	10
17	410		817.10	.029	.122	.12	170				52	94	91	8
18	420		818.72	.024	.107	.11	158				55	94	91	8
19	430	0046	820.11	.020	.089	.09	160				57	93	91	8
20	440	1302	822.08	.024	.114	.11	121				57	93	90	15
21	450		823.487	.023	.093	.09	220				63	91	89	2
22	460		824.885	.022	.089	.09	217				63	91	89	2
23	470		826.432	.028	.112	.11	230				61	91	89	2
24	480	0147	827.921	.026	.104	.10	226				62	91	89	2

Notes: * Paused at 2327 to check ph. - Resumed testing at 2332 2331 (359 min. of testing)
 Shared files\Field Data Sheets\Method 5\Method 5_v2.pdf
 * Paused at (434 min) 0046 - leak check .014 @ 10.11g to decrease the vacuum.
 HORIZON ENGINEERING 4652025/12a gel
 2821.032

4/28/16
 Vacuum 2.10 after

Leak check after shaking silica gel .011 @ 1 in Hg

SGM = 821,245 before resuming. → Resumed testing at 1302 ²⁶⁰

Field Data Sheet

PAGE 3 of 4

HORIZON ENGINEERING INC.
 13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505

Glass Nozzle Measurements

1 .2580 }
 2 .2580 } .2583
 3 .2593 }

Client: BULLS-EYE GLASS
 Facility Location: PORTLAND, OR
 Source: FURNACE T-7
 Sample Location: INLET

Date: 4/28/16 - 4/29/16
 Test Method: 5061
 Concurrent Testing: MS
 Run #: 3

Probe: 2-2 (2x) Cp, 8204 Heat Set: --- °F
 Post-Test Pitot Inspection: (NC=no change, D=damaged)
 Pitot Lk Rate: Pre: Hi 0 @ 15 Post: @
 in H2O @ in H2O: Lo 0 @ 16 @

Operator: BC Support: JM, CH, BS, PB

ALT-011
 Std TC (ID/F): 816 2L
 Stack TC (ID/F): 816 2-2

Nozzle: .2583 Oven: --- Imp. Outlet: ---
 Filter: --- Heat Set: --- °F

Temperature, Ambient (Ta): ---
 Moisture: 3% Tdb: --- Twb: ---

Continuity Check: 0 or ↓

Meter Box: 2 dH@: 1.97675 YQ: 99949

Press., Static (Pstat): 0.3 Press., Bar (Pb): 30.10
 Cyclonic Flow Expected? N If yes, avg. null angle: --- degrees

Meter: Pretest: 0.011 cfm 7 inHg

Leak Check: Post: --- cfm --- inHg


Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER Inlet/Avg.	METER Outlet	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)	
		02:14	827.991										
1	490		829.240	.016	.071	.07	162			62	90	88	2
2	500		830.600	.019	.084	.08	160			62	89	87	2
3	510		832.168	.022	.098	.10	158			62	88	86	2
4	520		833.589	.018	.081	.08	147			60	88	86	2
5	530		834.982	.020	.087	.09	170			59	88	86	2
6	540		836.070	.013	.056	.06	178			60	88	86	2
7	550		837.237	.014	.060	.06	177			61	88	86	2
8	560		838.152	.010	.043	.04	182			60	88	86	2
9	570		839.260	.014	.061	.06	167			61	89	86	2
10	580		840.332	.012	.053	.05	164			59	89	87	2
11	590		841.442	.016	.068	.07	182			60	89	87	2
12	600		842.576	.014	.062	.06	155			60	89	87	2
12	610		843.628	.014	.063	.06	147			58	89	87	2
11	620		844.856	.015	.067	.07	150			59	89	86	2
10	630		846.241	.020	.091	.09	146			60	89	86	2
9	640		847.539	.017	.076	.08	150			56	88	86	2
8	650		848.666	.014	.059	.06	182			56	88	86	2
7	660		849.745	.014	.063	.06	146			57	89	86	2
6	670		850.990	.017	.078	.08	137			56	89	86	2
5	680		852.087	.012	.055	.06	140			56	88	86	2
4	690		852.977	.011	.049	.05	157			57	88	86	2
3	700		854.138	.017	.075	.08	161			59	87	86	2
2	710	26:05	855.269	.013	.057	.06	167			59	88	86	2
1	720	26:13	856.347	.012	.052	.05	171			60	87	86	2
1	730		---	.015	.066	.07	163			59	86	84	2

Notes: B:\Shared files\Field Data Sheets\Method 5\Method 5_v2.pdf

PAUSE FOR pH CHECK

Field Data Sheet

PAGE 4 of 4

	13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505	Glass Nozzle Measurements 1 .2530 2 .2530 } .2533 3 .2590	Client: <u>BULLSEYE GLASS</u> Facility Location: <u>PORTLAND, OR</u> Source: <u>FURNACE T-7</u> Sample Location: <u>INLET</u>										
Date: <u>4/28/16 - 4/29/16</u> Test Method: <u>5501</u> Concurrent Testing: <u>MS</u> Run #: <u>3</u>		ALT-011 Std TC (ID/F): <u>36" 2</u> Stack TC (ID/F): <u>36" 2-2</u> Continuity Check: <input checked="" type="checkbox"/> or ↓											
Operator: <u>BC</u> Support: <u>JM, CH, BL, PB</u> Temperature, Ambient (Ta): _____ Moisture: <u>~3%</u> Tdb: _____ Twb: _____ Press., Static (Pstat): <u>0.3</u> Press., Bar (Pb): <u>30.10</u> Cyclonic Flow Expected? <input checked="" type="checkbox"/> If yes, avg. null angle = _____ degrees		Nozzle: <u>2533</u> Oven: _____ Imp. Outlet: <u>1-20</u> Filter: _____ Heat Set: _____ °F Meter Box: <u>2</u> dH@: <u>1.97615</u> Y: <u>0.99949</u>											
		Meter Pretest: <u>0.011</u> cfm 7 inHg Leak Check Post: <u>0.014</u> cfm 16 inHg											
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg. T (Tm-in)	METER Outlet T (Tm-out)	Pump Vacuum inHg (Pv)
							°F (Ts)	°F (Tp)	°F (To)	°F (Tf)	°F (Tm-in)	°F (Tm-out)	Amb:
2	740		858.599	.013	.057	.06	162			60	88	86	2
3	750		859.634	.012	.053	.05	163			58	87	85	2
4	760		860.735	.012	.053	.05	159			58	86	84	2
5	770		862.156	.015	.060	.07	161			58	86	84	2
6	780		863.542	.018	.079	.08	161			57	87	84	2
* 7	790	07:23	864.725	.013	.056	.06	179			58	87	84	2
8	800	07:26	866.200	.020	.085	.09	183			57	87	85	2
9	810		867.738	.022	.101	.10	134			58	87	85	2
10	820		869.219	.019	.087	.09	140			57	88	85	2
11	830		870.403	.011	.058	.06	138			59	88	86	2
12	840		871.714	.015	.071	.07	120			58	88	86	2
12	850		873.100	.016	.075	.08	124			60	89	86	2
11	860		874.597	.019	.089	.09	121			61	89	87	2
10	870		875.977	.016	.073	.07	145			60	90	86	2
9	880	07:20	876.368	.014	.061	.06	163			60	89	86	2
8	890												
7	890												
6													
5													
4													
3													
2													
1													

Notes: B:\Shared files\Field\Data Sheets\Method 5\Method 5_v2.pdf



MONTROSE

AIR QUALITY SERVICES

13585 NE Whitaker Way
 Portland, OR 97230
 Phone (503) 255-5050
 Fax (503) 255-0505
 www.montrose-env.com

Sample Recovery Worksheet

Method 0061

Client: Bullseye
 Facility Location: Portland, OR
 Operator: JF, JH

Date: 4/26-4/27/16
 Source: Glass Furnace T7
 Sample Location: Inlet

Balance Calibration (1000, 500, 200 g)
 Need one per each 3-run test

Tolerance must be within $\pm 1.0\%$
998 1499 1200

IMPINGER CONTENTS

	4/26/16 JH RUN 1a	RUN 21b	RUN 31c
Container, condensate & rinse, grams	<u>577 (606.2)</u>	<u>578</u>	<u>593</u>
Container & condensate, grams	<u>366</u>	<u>385</u>	<u>400</u>
Empty container, grams	<u>104.7</u>	<u>104.2</u>	<u>104.8</u>
Initial volume, ml	<u>300</u>	<u>300</u>	<u>300</u>
Initial contents	<u>5N KOH</u>	<u>KOH</u>	<u>KOH</u>
Initial concentration	<u>0.5 M</u>	<u>0.5 M</u>	<u>0.5 M</u>
Net water gain, ml			
Condensate appearance	<u>Clear</u>	<u>Clear</u>	<u>Clear</u>
Level marked on container	<u>✓</u>	<u>✓</u>	<u>✓</u>
pH of condensate	<u>~9</u>	<u>~9</u>	<u>~9.5</u>
Rinsed with	<u>DI H₂O / 0.1 N HNO₃</u>		
Solvent Name and Lot No.	<u>DI H₂O: 2122</u>		
Solvent Name and Lot No.	<u>HNO₃: 1856</u>		

SILICA GEL (w/impinger, top off)

	4/26/16 JH	4/27/16 JF	4/27/16 JH
Final weight, grams	<u>791</u>	<u>765</u>	<u>941</u>
Initial weight, grams	<u>761 520 620</u>	<u>520 745</u>	<u>520 926 4</u>
Net gain, grams			

TOTAL MOISTURE GAIN

Impingers and silica gel, grams

FILTERS

Front filter number
 Front filter appearance
 Back filter number

	<u>4/26</u>	<u>Purge 4/27</u>	<u>Purge 4/27</u>
	<u>2237</u>	<u>03:27-03:57</u>	<u>09:53-</u>
		<u>HORIZON/ENGINEERING</u>	<u>16/5702</u>

0061 264



MONTROSE

AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505
www.montrose-env.com

Sample Recovery Worksheet

Client: Bullseye Date: 4/20 - 4/28
Facility Location: Portland OR Source: F7
Operator: JF JH Sample Location: Inlet

Balance Calibration (1000, 500, 200 g)
Need one per each 3-run test

Tolerance must be within $\pm 1.0\%$
998 1499 1200

IMPINGER CONTENTS

Container, condensate & rinse, grams
Container & condensate, grams
Empty container, grams
Initial volume, ml
Initial contents
Initial concentration
Net water gain, ml
Condensate appearance
Level marked on container
pH of condensate
Rinsed with
Solvent Name and Lot No.
Solvent Name and Lot No.

	RUN 1	RUN 2	RUN 3
Container, condensate & rinse, grams		588	656
Container & condensate, grams		450	453.2
Empty container, grams		105	104
Initial volume, ml		300	300
Initial contents		KOH	KOH
Initial concentration		0.5 M	0.5 M
Net water gain, ml			
Condensate appearance		light grn tint	light green
Level marked on container			
pH of condensate		9.5	9.5
Rinsed with		DI H ₂ O / HNO ₃	→
Solvent Name and Lot No.		DI H ₂ O: 2122	→
Solvent Name and Lot No.		HNO ₃	

SILICA GEL (w/impinger, top off)

Final weight, grams
Initial weight, grams
Net gain, grams

Final weight, grams		830	904
Initial weight, grams	520	SF 520 797 4-28-11	520 881
Net gain, grams			

TOTAL MOISTURE GAIN

Impingers and silica gel, grams

FILTERS

Front filter number
Front filter appearance
Back filter number

Front filter number		NA	NA
Front filter appearance			
Back filter number			

Purge w/ N₂
09:45 - 10:15
10 g/min
Purge w/ N₂
09:27 - 09:57
HORIZON ENGINEERING, 16-5702

Field Data Sheet

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 253-0505

Date 4/28/16
Test Method 0061
Concurrent Testing 5, 3A (gaskets)
Run # 2

Operator MW Support PT, JH
Temperature, Ambient 73 (Ta)
Moisture 3% Tdb Twb
Press., Static (Pstat) | Press., Bar (Pb) 30.1
Cyclonic Flow Expected? No If yes, avg. null angle degrees

Glass Nozzle Measurements
1 256
2 256
3 255 } mv
 4/28/16

ALT-011
Std TC (ID/F) MV / 74
Stack TC (ID/F) 2-1 / 73
Continuity Check or ↓

Client: Biltsege Glass
Facility Location: Portland, OR
Source: Furnace T-7
Sample Location: outlet

Probe 2-1 (g/s) Cp 2248 Heat Set °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 6 Post @
in H2O @ in H2O Lo 0 @ 6 ° @


Nozzle 2556, 2096 Oven Imp. Outlet 1-35
Filter Heat Set °F
Meter Box 29 dH@ 1.739 Y 0.98764

Meter Pretest: 0.005 cfm 5 inHg
Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (d)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)		Velocity Head in H2 (dFs)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum inHg (Pv)
			°F (Ts)	°F (Tp)				°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)			
			463	489										
1	10	1700	465.39		.07	.11	.11	141			40	65	66	1
2	20		467.30		.07	.11	.11	139			63	68	67	1
3	30		469.01		.06	.10	.10	132			62	68	68	1
4	40		470.400		.04	.06	.06	150			62	68	68	1
5	50		472.491		.06	.094	.09	163			65	70	68	1
6	60		473.157		.02	.03	.03	167			63	71	69	1
7	1:10		474.678		.04	.06	.06	156			64	71	69	1
8	1:20		475.815		.03	0.05	0.05	155			63	72	70	1
9	1:30		477.128		.03	.05	.05	170			63	72	70	1
10	1:40		478.634		.04	.06	.06	172			63	73	71	1
11	1:50		480.040		.04	.06	.06	162			62	73	71	1
12	2:00		481.504		.05	.08	.08	120			60	68	68	1
13	2:10		483.165		.05	.08	.08	122			58	68	67	1
14	2:20		484.423		.04	.06	.06	143			57	67	65	1
15	2:30		485.885		.04	.06	.06	167			57	67	65	1
16	2:40		487.244		.04	.06	.06	178			57	66	64	1
17	2:50		488.726		.05	.075	.08	182			57	66	64	1
18	3:00		490.119		.04	.06	.06	176			57	66	64	1
19	3:10		491.421		.03	.046	.05	160			57	65	63	1
20	3:20		492.601		.04	.064	.06	140			57	65	63	1
21	3:30		493.840		.03	.047	.05	155			58	65	63	1
22	3:40		494.905		.05	.077	.08	166			58	65	63	1
23	3:50		496.610		.05	.076	.08	172			58	65	63	1
24	4:00		497.256		.01	.015	.02	176			57	65	63	1
25	4:10		497.887		.01	.015	.02	150			58	65	63	1

Notes:

Field Data Sheet

 <p>13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505</p>	<p>Glass Nozzle Measurements</p> <table style="width:100%;"> <tr> <td style="width:5%;">1</td> <td style="width:15%;">.210</td> <td rowspan="3" style="font-size: 2em; vertical-align: middle;">} .2096</td> </tr> <tr> <td>2</td> <td>.210</td> </tr> <tr> <td>3</td> <td>.209</td> </tr> </table>	1	.210	} .2096	2	.210	3	.209	<p>Client: <u>Bullseye Glass</u> Facility Location: <u>Portland, OR</u> Source: <u>Furnace T7</u> Sample Location: <u>outlet</u></p>
1	.210	} .2096							
2	.210								
3	.209								
<p>Date <u>4/28/16</u> Test Method <u>0061</u> Concurrent Testing <u>S, 3A (gasses)</u> Run # <u>3</u></p>	<p>Probe <u>2-1</u> (g/s) Cp <u>.8248</u> Heat Set <u> </u> °F Post-Test Pitot Inspection (NC=no change, D=damaged) Pitot Lk Rate Pre: Hi <u>0 @ 6</u> Post <u>@</u> in H2O@in H2O Lo <u>0 @ 6</u> @</p>	<p>Nozzle <u>.2096</u> Oven <u> </u> Imp. Outlet <u>1-35</u> Filter <u> </u> Heat Set <u> </u> °F Meter Box <u>29</u> dH@ <u>1.739</u> Y <u>0.98764</u></p>							

<p>Operator <u>MV</u> Support <u>PT, JH</u> Temperature, Ambient <u>73 (Ta)</u> Moisture <u>3%</u> Tdb <u> </u> Twb <u> </u> Press., Static (Pstat) <u> </u> Press., Bar (Pb) <u>30.1</u> Cyclonic Flow Expected? <u>N</u> If yes, avg. null angle <u> </u> degrees</p>	<p>ALT-011 Std TC (ID/F) <u>MV 74</u> Stack TC (ID/F) <u>2-1 73</u> Continuity Check <input checked="" type="checkbox"/> or <input type="checkbox"/></p>	<p>Meter Pretest: <u>0.005</u> cfm <u>5</u> inHg Leak Check Post: <u> </u> cfm <u> </u> inHg</p>
---	--	--


Traverse Point Number	Sampling Time min (d)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vm)	Velocity Head in H2 (dH)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK	PROBE	OVEN Filter	IMPINGER Outlet	METER Inlet/Avg.	METER Outlet	Pump Vacuum inHg (Pv)	
							°F (Ts)	°F (Tp)	°F (To)	°F (Ti)	°F (Tm-in)	°F (Tm-out)		
1	4:20		499.656	.06	.095	.01	151				59	65	63	1
2	4:30		500.951	.03	.047	.05	152				58	66	64	1
3	4:40		502.135	.03	.047	.05	154				58	66	65	1
4	4:50		503.825	.05	.081	.08	138				58	67	65	1
5	5:00		505.232	.05	.079	.08	130				57	67	65	1
6	5:10		506.616	.04	.062	.06	158				58	68	65	1
7	5:20		507.915	.04	.062	.06	163				59	68	65	1
8	5:30		509.440	.05	.078	.08	161				59	67	65	1
9	5:40		511.024	.05	.085	.09	110				57	66	65	1
10	5:50		512.666	.05	.085	.09	110				57	66	64	1
11	6:00		514.195	.05	.082	.08	127				57	66	64	1
12	6:10		515.800	.06	.097	0.0	135				57	66	64	1
13	6:20		517.621	.06	.10	0.10	120				57	66	64	1
14	6:30		519.307	.05	.08	.08	138				56	65	63	1
15	6:40		520.630	.04	.06	.06	152				56	65	62	1
16	6:50		521.888	.03	.046	.05	164				57	65	62	1
17	7:00		523.140	.03	.046	.05	167				57	65	62	1
18	7:10		524.380	.03	.047	.05	158				57	65	62	1
19	7:20		525.898	.05	.079	.08	147				57	65	63	1
20	7:30		527.341	.05	.080	.08	139				56	65	63	1
21	7:40		529.235	.06	.096	.10	136				55	64	62	1
22	7:50		531.022	.06	.099	.10	133				55	64	62	1
23	8:00	1:09	532.496	.05	.079	.08	144				54	64	62	1
24	8:10	1:33	532.751	.07	.11	.11	150				55	62	63	1
25	8:20		535.315	.07	.11	.11	142				55	64	63	1

Notes: Restart 24 (1:33) at 1:38 532.496 ? leak check 532.752 0.005 @ 5

HORIZON ENGINEERING 16-5702

2 of 4

Field Data Sheet



13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505

Glass Nozzle Measurements

1	.210
2	.210
3	.209

Client: Bulls eye Glass
Facility Location: Portland, OR
Source: Furnace T7
Sample Location: Outlet

Date: 4/28/16
Test Method: 0061
Concurrent Testing: S, gases
Run #: 3

Probe: 2-1 (g/s) Cp .8248 Heat Set — °F
Post-Test Pitot Inspection (NC=no change, D=damaged)
Pitot Lk Rate Pre: Hi 0 @ 6 Post @
in H2O@in H2O Lo 0 @ 6 @

Operator: MV Support: PT, JH
Temperature, Ambient (Ta) —
Moisture: 3% Tdb — Twb —
Press., Static (Pstat) / Press., Bar (Pb) 30.1
Cyclonic Flow Expected? NO If yes, avg. null angle — degrees

ALT-011
Std TC (ID/°F) MW 174
Stack TC (ID/°F) 2-1, 73
Continuity Check Ⓡ or ↓


Nozzle: 2096 Oven — Imp. Outlet 1-35
Filter — Heat Set — °F
Meter Box 29 dH@ 1.739 Y 0.98764
Meter Pretest: 0.025 cfm 15 inHg
Leak Check Post: cfm inHg

Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	H2O ACTUAL (dH)	STACK	PROBE	OVEN	IMPINGER	METER	METER	Pump Vacuum inHg (Pv)	
							°F (Ts)	°F (Tb)	°F (To)	Outlet °F (Ti)	Inlet/Avg. °F (Tm-in)	Outlet °F (Tm-out)		
1	8:30		537.164	.03	.048	.05	129				56	64	61	1
2	8:40		538.965	.08	.127	.13	135				57	64	60	1
3	8:50		—	.07	.111	.11	135				56	64	61	1
4	9:00		542.499	.07	.111	.11	132				54	65	62	1
5	9:10		544.364	.07	.111	.11	132				55	65	61	1
6	9:20		545.871	.07	.111	.11	130				54	62	60	1
7	9:30		547.105	.05	.079	.08	129				55	64	62	1
8	9:40		549.220	.08	.131	.13	131				56	64	60	1
9	9:50		550.462	.05	.082	.08	133				55	63	62	1
10	10:00		551.631	.04	.065	.07	133				56	64	61	1
11	10:10		552.789	.03	.049	.05	129				56	64	62	1
12	10:20		553.571	.03	.049	.05	125				56	64	63	1
13	10:30		555.037	.03	.049	.05	128				56	63	64	1
14	10:40		556.218	.03	.049	.05	121				56	63	63	1
15	10:50		—				131				54	65	64	1
16	11:00		558.509	.05	.082	.08	131				55	64	64	1
17	11:10		560.005	.03	.049	.05	131				56	63	62	1
18	11:20		561.527	.03	.049	.05	132				51	64	62	1
19	11:30		563.017	.03	.049	.05	134				56	62	61	1
20	11:40		564.096	.03	.049	.05	132				54	63	61	1
21	11:50		565.107	.03	.049	.05	130				55	62	61	1
22	12:00		566.062	.03	.049	.05	129				53	62	62	1
23	12:10		567.288	.03	.049	.05	128				54	64	62	1
24	12:20		568.133	.03	.049	.05	129				52	64	63	1
25	12:30		569.003	.03	.049	.05	129				53	62	62	1

Notes:

A

Field Data Sheet

 <p>MONTROSE AIR QUALITY SERVICES</p>		13585 NE Whitaker Way Portland, OR 97230 Phone (503) 255-5050 Fax (503) 255-0505		Glass Nozzle Measurements 1 <u>.210</u> 2 <u>.210</u> 3 <u>.209</u>		Client: <u>Oulseye Glass</u> Facility Location: <u>Portland, OR</u> Source: <u>Furnace #7</u> Sample Location: <u>Outlet</u>								
		Date <u>4/29/16</u> Test Method <u>5 0061</u> Concurrent Testing <u>5</u> Run # <u>3</u>				Probe <u>2-1</u> (g/s) Cp <u>.8248</u> Heat Set <u>—</u> °F Post-Test Pitot Inspection (NC=no change, D=damaged) Pitot Lk Rate Pre: Hi <u>0</u> @ <u>6</u> Post <u>0</u> @ <u>6</u> in H2O@in H2O Lo <u>0</u> @ <u>6</u> <u>0</u> @ <u>6</u>								
Operator <u>MV</u> Support <u>PT, JH</u> Temperature, Ambient (Ta) <u>—</u> Moisture <u>3%</u> Tdb <u>—</u> Twb <u>—</u> Press., Static (Pstat) <u>—</u> Press., Bar (Pb) <u>32.1</u> Cyclonic Flow Expected? <u>NO</u> If yes, avg. null angle <u>—</u> degrees		ALT-011 Std TC (ID/°F) <u>2-1 / 74</u> Stack TC (ID/°F) <u>MV / 73</u>		Nozzle <u>.2096</u> Oven <u>—</u> Imp. Outlet <u>-35</u> Filter <u>—</u> Heat Set <u>—</u> °F Meter Box <u>29</u> dH@ <u>1.739</u> Y <u>0.98764</u>										
				Continuity Check <u>6</u> or <u>↓</u>		Meter Prefest: <u>0.255</u> cfm <u>5</u> inHg Leak Check Post: <u>0.12</u> cfm <u>6</u> inHg								
Traverse Point Number	Sampling Time min (dt)	Clock Time (24 hr)	Dry Gas Meter Reading cuft (Vn)	Velocity Head in H2 (dPa)	Orifice Pressure in H2O DESIRED	Orifice Pressure H2O ACTUAL (dH)	STACK °F (Ts)	PROBE °F (Tp)	OVEN Filter °F (To)	IMPINGER Outlet °F (TI)	METER Inlet/Avg °F (Tin-in)	METER Outlet °F (Tin-out)	Pump Vacuum inHg (Pv)	
1	12:40		570.251	.03	.049	.05	127				52	62	62	1
2	12:50		572.113	.03	.049	.05	124				52	61	61	1
3	13:00		573.973	.03	.049	.05	123				52	60	61	1
4	13:10		574.149	.03	.049	.05	122				52	62	61	1
5	13:20		575.154	.03	.049	.05	123				51	61	61	1
6	13:30		576.164	.03	.049	.05	123				52	62	61	1
7	13:40		577.172	.03	.049	.05	123				52	61	61	1
8	13:50		579.223	.02	.0328	.03	125				56	63	62	1
9	14:00		580.435	.02	.0328	.03	125				57	65	64	1
10	14:10		581.561	.02	.0328	.03	125				58	64	64	1
11	14:20		582.627											
12	14:30		583.627	.03	.049	.05	123				58	66	65	1
13	14:40		584.721	.02	.328	.03	128				60	68	65	1
14	14:50		585.807	.02	.328	.03	115				60	67	66	1
15	15:00		586.009	.02	.328	.03	119				60	67	66	1
16	15:10	9:00	587.579	.02	.328	.03					59	66	67	1
17	15:20													
18	15:30													
19	15:40													
20	15:50													
21	16:00													
22	16:													
23														
24														
25														

Notes:

B:\Shared files\Field Data Sheets\Method 5\Method 5_PDX-v1.pdf

→ Pause @ 7:33

4 of 4

HORIZON ENGINEERING 16-5702



MONTROSE

AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505
www.montrose-env.com

269

0061

Sample Recovery Worksheet

Client: Bullseye Date: 4-29-16
 Facility Location: Portland, OR Source: Glass Furnace T7
 Operator: SF Sample Location: Outlet

Balance Calibration (1000, 500, 200 g)
 Need one per each 3-run test

Tolerance must be within $\pm 1.0\%$

999 1 499 1 500 ⁵¹⁴
200

IMPINGER CONTENTS

Container, condensate & rinse, grams
 Container & condensate, grams
 Empty container, grams
 Initial volume, ml
 Initial contents
 Initial concentration
 Net water gain, ml
 Condensate appearance
 Level marked on container
 pH of condensate
 Rinsed with
 Solvent Name and Lot No.
 Solvent Name and Lot No.

RUN 1	RUN 2	RUN 3
_____	_____	596
_____	_____	423
_____	_____	105
_____	_____	300
_____	_____	1504
_____	_____	0.5 M
_____	_____	Clear
_____	_____	✓
_____	_____	9.5
_____	_____	DI H ₂ O / HNO ₃
_____	_____	DI H ₂ O: 2122
_____	_____	HNO ₃ : 1856

SILICA GEL (w/impinger, top off)

Final weight, grams
 Initial weight, grams
 Net gain, grams

		759
520	520	520 756
_____	_____	_____

TOTAL MOISTURE GAIN

Impingers and silica gel, grams

_____	_____	_____
-------	-------	-------

FILTERS

Front filter number
 Front filter appearance
 Back filter number

_____	_____	NA
_____	_____	
_____	_____	_____

Purge w/ N₂
 10.40-11.10
 10 L/min

HORIZON ENGINEERING 16-5702



MONTROSE
AIR QUALITY SERVICES

13585 NE Whitaker Way
Portland, OR 97230
Phone (503) 255-5050
Fax (503) 255-0505
www.montrose-env.com

EPA METHOD 1

TRAVERSE POINT LOCATIONS

Client: Bullseye Glass Facility Location: Portland OR
Source: T7 - Baghouse outlet Sample Location: Roof
Date: 6/6/16 Initials: PR

Top Ports

Traverse Point Number	Traverse Point Location (inches)
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Duct Dimensions and Port Locations		E	W
Inside of far wall to outside of nipple, F		<u>14</u>	<u>13 7/8</u>
Inside of near wall to outside of nipple, N		<u>17 1/2</u>	<u>15 7/8</u>
Nearest downstream disturbance, A	<u>27 1/2</u>		
Nearest upstream disturbance, B	<u>69 1/2</u>		
Circular: Inside Diameter, F-N		<u>12 3/8</u>	<u>12 1/4</u>
Rectangular: Width	"	Depth	"
Rectangular Equiv. Diameter: (2*W*D)/(W+D)	"		
Number of Ports:	<u>2</u>		
Duct characteristics:			
Construction:	<input checked="" type="radio"/> Steel <input type="radio"/> PVC <input type="radio"/> Fiberglass <input type="radio"/> Other		
Shape:	<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Elliptical		
Orientation:	<input checked="" type="radio"/> Vertical <input type="radio"/> Horizontal <input type="radio"/> Diagonal (~ angle: ___°)		
Flow straighteners:	Yes <input checked="" type="radio"/> No		
Stack Extension:	Yes <input checked="" type="radio"/> No		
Cyclonic Flow Expected:	Yes <input checked="" type="radio"/> No		
Cyclonic Flow Measured & Documented:	<input checked="" type="radio"/> Yes <input type="radio"/> No		
Average Null Angle <20°:	Yes <input type="radio"/> No <input type="radio"/> N/A		
Meets EPA M-1 Criteria:	Yes <input type="radio"/> No (If "No", explain why)		

Test port sketch or comments

This is The Last Page of the Report

